

Date: 10 March 2025

The Executive Director: Water Services Department

Harry Gwala District Municipality

40 Main Street

Ixopo

3276

Attention: Basetsana Khathalib and Bheki Nene

FEBRUARY 2025 UNTREATED WATER (RAW) RESULTS

Please find February 2025 Untreated Water (Raw) results tabulated below for samples received during February 2025. Determinands marked with an asterix are unaccredited and are not included in uMngeni-uThukela Water's schedule of accreditation.

Please contact us immediately should you have any queries.

Yours' Sincerely

Mr M Sewcharan

Client Services Manager

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolu | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

Sample Date	Sample Number	Sampling Point	Description	Determinand	Result	UOM	Unit
03-Feb-25	2340068	TKK001	Kokstad River Raw	Al (AE)	422	±7.6%	µg Al/L
03-Feb-25	2340065	TKK001	Kokstad River Raw	Coliforms*	>2420	±22%	MPN/100mL
03-Feb-25	2340065	TKK001	Kokstad River Raw	Coliphages*	54	±8%	PFU/10ml
03-Feb-25	2340064	TKK001	Kokstad River Raw	Coll Time OS*	07:20	-	-
03-Feb-25	2340066	TKK001	Kokstad River Raw	Colour	15.5	±6.5%	mg Pt-Co/L
03-Feb-25	2340067	TKK001	Kokstad River Raw	Conductivity	14.6	±1.5%	mS/m
03-Feb-25	2340065	TKK001	Kokstad River Raw	E.coli*	79	±21%	MPN/100mL
03-Feb-25	2340068	TKK001	Kokstad River Raw	Fe (AE)	1.04	±5.4%	mg Fe/L
03-Feb-25	2340068	TKK001	Kokstad River Raw	Mn (AE)	0.13	±6.2%	mg Mn/L
03-Feb-25	2340066	TKK001	Kokstad River Raw	Odour*	Mild Earthy	-	-
03-Feb-25	2340064	TKK001	Kokstad River Raw	pH OS*	7.60	-	-
03-Feb-25	2340064	TKK001	Kokstad River Raw	Temperature OS*	20.3	-	°C
03-Feb-25	2340066	TKK001	Kokstad River Raw	Turbidity	11.3	±6.1%	NTU
03-Feb-25	2340079	TKK003	Kokstad Crystal Spring Raw	Al (AE)	988	±7.6%	µg Al/L
03-Feb-25	2340076	TKK003	Kokstad Crystal Spring Raw	Coliforms*	>2420	±22%	MPN/100mL
03-Feb-25	2340076	TKK003	Kokstad Crystal Spring Raw	Coliphages*	0	±8%	PFU/10ml
03-Feb-25	2340075	TKK003	Kokstad Crystal Spring Raw	Coll Time OS*	07:27	-	-
03-Feb-25	2340077	TKK003	Kokstad Crystal Spring Raw	Colour	3.60	±6.5%	mg Pt-Co/L
03-Feb-25	2340078	TKK003	Kokstad Crystal Spring Raw	Conductivity	11.4	±1.5%	mS/m
03-Feb-25	2340076	TKK003	Kokstad Crystal Spring Raw	E.coli*	12	±21%	MPN/100mL
03-Feb-25	2340079	TKK003	Kokstad Crystal Spring Raw	Fe (AE)	6.02	±5.4%	mg Fe/L
03-Feb-25	2340077	TKK003	Kokstad Crystal Spring Raw	Odour*	Mild Vegetation	-	-
03-Feb-25	2340075	TKK003	Kokstad Crystal Spring Raw	pH OS*	7.50	-	-
03-Feb-25	2340075	TKK003	Kokstad Crystal Spring Raw	Temperature OS*	21.2	-	°C
03-Feb-25	2340077	TKK003	Kokstad Crystal Spring Raw	Turbidity	11.6	±6.1%	NTU
04-Feb-25	2341021	TQU001	Mnqumeni Raw	Coliforms*	1553	±22%	MPN/100mL
04-Feb-25	2341020	TQU001	Mnqumeni Raw	Coll Time OS*	07:19	-	-
04-Feb-25	2341022	TQU001	Mnqumeni Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
04-Feb-25	2341023	TQU001	Mnqumeni Raw	Conductivity	11.5	±1.5%	mS/m
04-Feb-25	2341021	TQU001	Mnqumeni Raw	E.coli*	50	±21%	MPN/100mL
04-Feb-25	2341022	TQU001	Mnqumeni Raw	Odour*	Nil	-	-
04-Feb-25	2341020	TQU001	Mnqumeni Raw	pH OS*	7.10	-	-
04-Feb-25	2341020	TQU001	Mnqumeni Raw	Temperature OS*	23.9	-	°C
04-Feb-25	2341022	TQU001	Mnqumeni Raw	Turbidity	12.7	±6.1%	NTU
04-Feb-25	2341034	TSQ001	Esiqanduleni Raw	Al (AE)	732	±7.6%	µg Al/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

04-Feb-25	2341031	TSQ001	Esiqanduleni Raw	Coliforms*	>2420	±22%	MPN/100mL
04-Feb-25	2341031	TSQ001	Esiqanduleni Raw	Coliphages*	63	±8%	PFU/10ml
04-Feb-25	2341030	TSQ001	Esiqanduleni Raw	Coll Time OS*	07:50	-	-
04-Feb-25	2341033	TSQ001	Esiqanduleni Raw	Conductivity	9.04	±1.5%	mS/m
04-Feb-25	2341031	TSQ001	Esiqanduleni Raw	E.coli*	260	±21%	MPN/100mL
04-Feb-25	2341030	TSQ001	Esiqanduleni Raw	pH OS*	7.60	-	-
04-Feb-25	2341030	TSQ001	Esiqanduleni Raw	Temperature OS*	26.3	-	°C
04-Feb-25	2341032	TSQ001	Esiqanduleni Raw	Turbidity	150.0	±6.1%	NTU
05-Feb-25	2341548	TBU001	Bulwer Raw	Al (AE)	563	±7.6%	µg Al/L
05-Feb-25	2341545	TBU001	Bulwer Raw	Coliforms*	>2420	±22%	MPN/100mL
05-Feb-25	2341544	TBU001	Bulwer Raw	Coll Time OS*	10:47	-	-
05-Feb-25	2341546	TBU001	Bulwer Raw	Colour	6.90	±6.5%	mg Pt-Co/L
05-Feb-25	2341547	TBU001	Bulwer Raw	Conductivity	5.23	±1.5%	mS/m
05-Feb-25	2341545	TBU001	Bulwer Raw	E.coli*	921	±21%	MPN/100mL
05-Feb-25	2341548	TBU001	Bulwer Raw	Fe (AE)	1.11	±5.4%	mg Fe/L
05-Feb-25	2341544	TBU001	Bulwer Raw	pH OS*	7.50	-	-
05-Feb-25	2341544	TBU001	Bulwer Raw	Temperature OS*	24.6	-	°C
05-Feb-25	2341546	TBU001	Bulwer Raw	Turbidity	23.0	±6.1%	NTU
05-Feb-25	2341559	TCR001	Creighton Raw	Al (AE)	622	±7.6%	µg Al/L
05-Feb-25	2341556	TCR001	Creighton Raw	Coliforms*	1300	±22%	MPN/100mL
05-Feb-25	2341555	TCR001	Creighton Raw	Coll Time OS*	06:12	-	-
05-Feb-25	2341557	TCR001	Creighton Raw	Colour	10.6	±6.5%	mg Pt-Co/L
05-Feb-25	2341558	TCR001	Creighton Raw	Conductivity	6.38	±1.5%	mS/m
05-Feb-25	2341556	TCR001	Creighton Raw	E.coli*	75	±21%	MPN/100mL
05-Feb-25	2341559	TCR001	Creighton Raw	Fe (AE)	0.78	±5.4%	mg Fe/L
05-Feb-25	2341559	TCR001	Creighton Raw	Mn (AE)	0.01	±6.2%	mg Mn/L
05-Feb-25	2341557	TCR001	Creighton Raw	Odour*	Nil	-	-
05-Feb-25	2341555	TCR001	Creighton Raw	pH OS*	7.30	-	-
05-Feb-25	2341555	TCR001	Creighton Raw	Temperature OS*	20.2	-	°C
05-Feb-25	2341557	TCR001	Creighton Raw	Turbidity	22.7	±6.1%	NTU
05-Feb-25	2341567	THL001	Hlanganani Raw	Coliforms*	>2420	±22%	MPN/100mL
05-Feb-25	2341566	THL001	Hlanganani Raw	Coll Time OS*	10:47	-	-
05-Feb-25	2341568	THL001	Hlanganani Raw	Colour	10.1	±6.5%	mg Pt-Co/L
05-Feb-25	2341569	THL001	Hlanganani Raw	Conductivity	8.12	±1.5%	mS/m
05-Feb-25	2341567	THL001	Hlanganani Raw	E.coli*	411	±21%	MPN/100mL
05-Feb-25	2341568	THL001	Hlanganani Raw	Odour*	Nil	-	-
05-Feb-25	2341566	THL001	Hlanganani Raw	pH OS*	7.50	-	-
05-Feb-25	2341566	THL001	Hlanganani Raw	Temperature OS*	24.6	-	°C
05-Feb-25	2341568	THL001	Hlanganani Raw	Turbidity	47.3	±6.1%	NTU
05-Feb-25	2341606	TRV001	Riversside Raw	Al (AE)	3965	±7.6%	µg Al/L
05-Feb-25	2341603	TRV001	Riversside Raw	Coliforms*	365	±22%	MPN/100mL
05-Feb-25	2341602	TRV001	Riversside Raw	Coll Time OS*	07:27	-	-
05-Feb-25	2341604	TRV001	Riversside Raw	Colour	<1.00	±6.5%	mg Pt-Co/L

uMngeni-Uthukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

05-Feb-25	2341605	TRV001	Riversside Raw	Conductivity	7.50	±1.5%	mS/m
05-Feb-25	2341603	TRV001	Riversside Raw	E.coli*	23	±21%	MPN/100mL
05-Feb-25	2341606	TRV001	Riversside Raw	Fe (AE)	0.45	±5.4%	mg Fe/L
05-Feb-25	2341604	TRV001	Riversside Raw	Odour*	Nil	-	-
05-Feb-25	2341602	TRV001	Riversside Raw	pH OS*	7.50	-	-
05-Feb-25	2341602	TRV001	Riversside Raw	Temperature OS*	22.3	-	°C
05-Feb-25	2341604	TRV001	Riversside Raw	Turbidity	6.2	±6.1%	NTU
05-Feb-25	2341617	TST001	St Appollinaris Raw	Al (AE)	259	±7.6%	µg Al/L
05-Feb-25	2341614	TST001	St Appollinaris Raw	Coliforms*	>2420	±22%	MPN/100mL
05-Feb-25	2341613	TST001	St Appollinaris Raw	Coll Time OS*	09:12	-	-
05-Feb-25	2341615	TST001	St Appollinaris Raw	Colour	6.90	±6.5%	mg Pt-Co/L
05-Feb-25	2341616	TST001	St Appollinaris Raw	Conductivity	5.61	±1.5%	mS/m
05-Feb-25	2341614	TST001	St Appollinaris Raw	E.coli*	73	±21%	MPN/100mL
05-Feb-25	2341617	TST001	St Appollinaris Raw	Fe (AE)	0.50	±5.4%	mg Fe/L
05-Feb-25	2341615	TST001	St Appollinaris Raw	Odour*	Nil	-	-
05-Feb-25	2341613	TST001	St Appollinaris Raw	pH OS*	7.50	-	-
05-Feb-25	2341613	TST001	St Appollinaris Raw	Temperature OS*	24.3	-	°C
05-Feb-25	2341615	TST001	St Appollinaris Raw	Turbidity	22.8	±6.1%	NTU
05-Feb-25	2341628	TUN001	Underberg Raw	Al (AE)	423	±7.6%	µg Al/L
05-Feb-25	2341625	TUN001	Underberg Raw	Coliforms*	>2420	±22%	MPN/100mL
05-Feb-25	2341625	TUN001	Underberg Raw	Coliphages*	11	±8%	PFU/10ml
05-Feb-25	2341624	TUN001	Underberg Raw	Coll Time OS*	08:10	-	-
05-Feb-25	2341626	TUN001	Underberg Raw	Colour	5.40	±6.5%	mg Pt-Co/L
05-Feb-25	2341627	TUN001	Underberg Raw	Conductivity	4.61	±1.5%	mS/m
05-Feb-25	2341625	TUN001	Underberg Raw	E.coli*	91	±21%	MPN/100mL
05-Feb-25	2341628	TUN001	Underberg Raw	Fe (AE)	0.42	±5.4%	mg Fe/L
05-Feb-25	2341626	TUN001	Underberg Raw	Odour*	Nil	-	-
05-Feb-25	2341624	TUN001	Underberg Raw	pH OS*	7.30	-	-
05-Feb-25	2341624	TUN001	Underberg Raw	Temperature OS*	24.2	-	°C
05-Feb-25	2341626	TUN001	Underberg Raw	Turbidity	9.8	±6.1%	NTU
06-Feb-25	2342405	TMZ001	Umzimkhulu Raw	Al (AE)	552	±7.6%	µg Al/L
06-Feb-25	2342402	TMZ001	Umzimkhulu Raw	Coliforms*	>2420	±22%	MPN/100mL
06-Feb-25	2342402	TMZ001	Umzimkhulu Raw	Coliphages*	25	±8%	PFU/10ml
06-Feb-25	2342401	TMZ001	Umzimkhulu Raw	Coll Time OS*	07:00	-	-
06-Feb-25	2342404	TMZ001	Umzimkhulu Raw	Conductivity	7.34	±1.5%	mS/m
06-Feb-25	2342402	TMZ001	Umzimkhulu Raw	E.coli*	248	±21%	MPN/100mL
06-Feb-25	2342401	TMZ001	Umzimkhulu Raw	pH OS*	7.20	-	-
06-Feb-25	2342401	TMZ001	Umzimkhulu Raw	Temperature OS*	23.8	-	°C
06-Feb-25	2342403	TMZ001	Umzimkhulu Raw	Turbidity	51.5	±6.1%	NTU
06-Feb-25	2342416	TNO001	Nokweja Raw	Al (AE)	558	±7.6%	µg Al/L
06-Feb-25	2342413	TNO001	Nokweja Raw	Coliforms*	>2420	±22%	MPN/100mL
06-Feb-25	2342413	TNO001	Nokweja Raw	Coliphages*	41	±8%	PFU/10ml
06-Feb-25	2342412	TNO001	Nokweja Raw	Coll Time OS*	08:42	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

06-Feb-25	2342415	TNO001	Nokweja Raw	Conductivity	7.63	±1.5%	mS/m
06-Feb-25	2342413	TNO001	Nokweja Raw	E.coli*	1733	±21%	MPN/100mL
06-Feb-25	2342412	TNO001	Nokweja Raw	pH OS*	7.60	-	-
06-Feb-25	2342412	TNO001	Nokweja Raw	Temperature OS*	20.0	-	°C
06-Feb-25	2342414	TNO001	Nokweja Raw	Turbidity	53.5	±6.1%	NTU
10-Feb-25	2343729	TFR001	Franklin Raw	Al (AE)	536	±7.6%	µg Al/L
10-Feb-25	2343726	TFR001	Franklin Raw	Coliforms*	>2420	±22%	MPN/100mL
10-Feb-25	2343725	TFR001	Franklin Raw	Coll Time OS*	07:12	-	-
10-Feb-25	2343728	TFR001	Franklin Raw	Conductivity	10.2	±1.5%	mS/m
10-Feb-25	2343726	TFR001	Franklin Raw	E.coli*	866	±21%	MPN/100mL
10-Feb-25	2343725	TFR001	Franklin Raw	pH OS*	7.00	-	-
10-Feb-25	2343725	TFR001	Franklin Raw	Temperature OS*	20.2	-	°C
10-Feb-25	2343727	TFR001	Franklin Raw	Turbidity	64.1	±6.1%	NTU
10-Feb-25	2343754	TKK001	Kokstad River Raw	Al (AE)	428	±7.6%	µg Al/L
10-Feb-25	2343751	TKK001	Kokstad River Raw	Coliforms*	>2420	±22%	MPN/100mL
10-Feb-25	2343751	TKK001	Kokstad River Raw	Coliphages*	180	±8%	PFU/10ml
10-Feb-25	2343750	TKK001	Kokstad River Raw	Coll Time OS*	08:00	-	-
10-Feb-25	2343753	TKK001	Kokstad River Raw	Conductivity	15.3	±1.5%	mS/m
10-Feb-25	2343751	TKK001	Kokstad River Raw	E.coli*	240	±21%	MPN/100mL
10-Feb-25	2343750	TKK001	Kokstad River Raw	pH OS*	7.60	-	-
10-Feb-25	2343750	TKK001	Kokstad River Raw	Temperature OS*	20.2	-	°C
10-Feb-25	2343752	TKK001	Kokstad River Raw	Turbidity	21.8	±6.1%	NTU
10-Feb-25	2343765	TKK003	Kokstad Crystal Spring Raw	Al (AE)	30.0	±7.6%	µg Al/L
10-Feb-25	2343762	TKK003	Kokstad Crystal Spring Raw	Coliforms*	1414	±22%	MPN/100mL
10-Feb-25	2343762	TKK003	Kokstad Crystal Spring Raw	Coliphages*	0	±8%	PFU/10ml
10-Feb-25	2343761	TKK003	Kokstad Crystal Spring Raw	Coll Time OS*	08:20	-	-
10-Feb-25	2343764	TKK003	Kokstad Crystal Spring Raw	Conductivity	11.8	±1.5%	mS/m
10-Feb-25	2343762	TKK003	Kokstad Crystal Spring Raw	E.coli*	13	±21%	MPN/100mL
10-Feb-25	2343761	TKK003	Kokstad Crystal Spring Raw	pH OS*	7.50	-	-
10-Feb-25	2343761	TKK003	Kokstad Crystal Spring Raw	Temperature OS*	21.1	-	°C
10-Feb-25	2343763	TKK003	Kokstad Crystal Spring Raw	Turbidity	8.1	±6.1%	NTU
12-Feb-25	2345225	TBU001	Bulwer Raw	Al (AE)	546	±7.6%	µg Al/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

12-Feb-25	2345222	TBU001	Bulwer Raw	Coliforms*	>2420	±22%	MPN/100mL
12-Feb-25	2345221	TBU001	Bulwer Raw	Coll Time OS*	09:30	-	-
12-Feb-25	2345223	TBU001	Bulwer Raw	Colour	10.0	±6.5%	mg Pt-Co/L
12-Feb-25	2345224	TBU001	Bulwer Raw	Conductivity	3.93	±1.5%	mS/m
12-Feb-25	2345222	TBU001	Bulwer Raw	E.coli*	96	±21%	MPN/100mL
12-Feb-25	2345223	TBU001	Bulwer Raw	Odour*	Nil	-	-
12-Feb-25	2345221	TBU001	Bulwer Raw	pH OS*	7.20	-	-
12-Feb-25	2345221	TBU001	Bulwer Raw	Temperature OS*	26.8	-	°C
12-Feb-25	2345223	TBU001	Bulwer Raw	Turbidity	16.1	±6.1%	NTU
12-Feb-25	2345240	TCR001	Creighton Raw	Al (AE)	920	±7.6%	µg Al/L
12-Feb-25	2345237	TCR001	Creighton Raw	Coliforms*	2420	±22%	MPN/100mL
12-Feb-25	2345236	TCR001	Creighton Raw	Coll Time OS*	07:20	-	-
12-Feb-25	2345238	TCR001	Creighton Raw	Colour	13.7	±6.5%	mg Pt-Co/L
12-Feb-25	2345239	TCR001	Creighton Raw	Conductivity	6.66	±1.5%	mS/m
12-Feb-25	2345237	TCR001	Creighton Raw	E.coli*	31	±21%	MPN/100mL
12-Feb-25	2345236	TCR001	Creighton Raw	pH OS*	7.20	-	-
12-Feb-25	2345236	TCR001	Creighton Raw	Temperature OS*	19.0	-	°C
12-Feb-25	2345238	TCR001	Creighton Raw	Turbidity	27.1	±6.1%	NTU
12-Feb-25	2345258	THL001	Hlanganani Raw	Coliforms*	>2420	±22%	MPN/100mL
12-Feb-25	2345257	THL001	Hlanganani Raw	Coll Time OS*	10:12	-	-
12-Feb-25	2345260	THL001	Hlanganani Raw	Conductivity	6.43	±1.5%	mS/m
12-Feb-25	2345258	THL001	Hlanganani Raw	E.coli*	192	±21%	MPN/100mL
12-Feb-25	2345257	THL001	Hlanganani Raw	pH OS*	7.30	-	-
12-Feb-25	2345257	THL001	Hlanganani Raw	Temperature OS*	28.6	-	°C
12-Feb-25	2345259	THL001	Hlanganani Raw	Turbidity	39.8	±6.1%	NTU
12-Feb-25	2345292	TMQA001	Mqatsheni Raw	Coliforms*	0	±22%	MPN/100mL
12-Feb-25	2345291	TMQA001	Mqatsheni Raw	Coll Time OS*	08:50	-	-
12-Feb-25	2345293	TMQA001	Mqatsheni Raw	Colour	1.50	±6.5%	mg Pt-Co/L
12-Feb-25	2345294	TMQA001	Mqatsheni Raw	Conductivity	33.1	±1.5%	mS/m
12-Feb-25	2345292	TMQA001	Mqatsheni Raw	E.coli*	0	±21%	MPN/100mL
12-Feb-25	2345293	TMQA001	Mqatsheni Raw	Odour*	Nil	-	-
12-Feb-25	2345291	TMQA001	Mqatsheni Raw	pH OS*	9.10	-	-
12-Feb-25	2345291	TMQA001	Mqatsheni Raw	Temperature OS*	22.9	-	°C
12-Feb-25	2345293	TMQA001	Mqatsheni Raw	Turbidity	0.8	±6.1%	NTU
12-Feb-25	2345309	TRV001	Riversside Raw	Al (AE)	1919	±7.6%	µg Al/L
12-Feb-25	2345306	TRV001	Riversside Raw	Coliforms*	1733	±22%	MPN/100mL
12-Feb-25	2345305	TRV001	Riversside Raw	Coll Time OS*	08:01	-	-
12-Feb-25	2345307	TRV001	Riversside Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
12-Feb-25	2345308	TRV001	Riversside Raw	Conductivity	5.50	±1.5%	mS/m
12-Feb-25	2345306	TRV001	Riversside Raw	E.coli*	84	±21%	MPN/100mL
12-Feb-25	2345305	TRV001	Riversside Raw	pH OS*	7.60	-	-
12-Feb-25	2345305	TRV001	Riversside Raw	Temperature OS*	20.5	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

12-Feb-25	2345307	TRV001	Riversside Raw	Turbidity	15.2	±6.1%	NTU
12-Feb-25	2345324	TST001	St Appollinaris Raw	AI (AE)	354	±7.6%	µg AI/L
12-Feb-25	2345321	TST001	St Appollinaris Raw	Coliforms*	2420	±22%	MPN/100mL
12-Feb-25	2345320	TST001	St Appollinaris Raw	Coll Time OS*	08:25	-	-
12-Feb-25	2345323	TST001	St Appollinaris Raw	Conductivity	4.25	±1.5%	mS/m
12-Feb-25	2345321	TST001	St Appollinaris Raw	E.coli*	91	±21%	MPN/100mL
12-Feb-25	2345320	TST001	St Appollinaris Raw	pH OS*	7.60	-	-
12-Feb-25	2345320	TST001	St Appollinaris Raw	Temperature OS*	22.3	-	°C
12-Feb-25	2345322	TST001	St Appollinaris Raw	Turbidity	25.6	±6.1%	NTU
12-Feb-25	2345335	TUN001	Underberg Raw	AI (AE)	571	±7.6%	µg AI/L
12-Feb-25	2345332	TUN001	Underberg Raw	Coliforms*	1733	±22%	MPN/100mL
12-Feb-25	2345332	TUN001	Underberg Raw	Coliphages*	7	±8%	PFU/10ml
12-Feb-25	2345331	TUN001	Underberg Raw	Coll Time OS*	10:18	-	-
12-Feb-25	2345334	TUN001	Underberg Raw	Conductivity	3.82	±1.5%	mS/m
12-Feb-25	2345332	TUN001	Underberg Raw	E.coli*	58	±21%	MPN/100mL
12-Feb-25	2345331	TUN001	Underberg Raw	pH OS*	7.20	-	-
12-Feb-25	2345331	TUN001	Underberg Raw	Temperature OS*	20.4	-	°C
12-Feb-25	2345333	TUN001	Underberg Raw	Turbidity	8.3	±6.1%	NTU
13-Feb-25	2345926	TMZ001	Umzimkhulu Raw	AI (AE)	1939	±7.6%	µg AI/L
13-Feb-25	2345923	TMZ001	Umzimkhulu Raw	Coliforms*	>2420	±22%	MPN/100mL
13-Feb-25	2345923	TMZ001	Umzimkhulu Raw	Coliphages*	25	±8%	PFU/10ml
13-Feb-25	2345922	TMZ001	Umzimkhulu Raw	Coll Time OS*	06:57	-	-
13-Feb-25	2345924	TMZ001	Umzimkhulu Raw	Colour	10.9	±6.5%	mg Pt-Co/L
13-Feb-25	2345925	TMZ001	Umzimkhulu Raw	Conductivity	5.13	±1.5%	mS/m
13-Feb-25	2345923	TMZ001	Umzimkhulu Raw	E.coli*	158	±21%	MPN/100mL
13-Feb-25	2345926	TMZ001	Umzimkhulu Raw	Fe (AE)	1.17	±5.4%	mg Fe/L
13-Feb-25	2345924	TMZ001	Umzimkhulu Raw	Odour*	Mild Earthy	-	-
13-Feb-25	2345922	TMZ001	Umzimkhulu Raw	pH OS*	7.10	-	-
13-Feb-25	2345922	TMZ001	Umzimkhulu Raw	Temperature OS*	22.3	-	°C
13-Feb-25	2345924	TMZ001	Umzimkhulu Raw	Turbidity	79.5	±6.1%	NTU
13-Feb-25	2345953	TNO001	Nokweja Raw	AI (AE)	801	±7.6%	µg AI/L
13-Feb-25	2345950	TNO001	Nokweja Raw	Coliforms*	>2420	±22%	MPN/100mL
13-Feb-25	2345950	TNO001	Nokweja Raw	Coliphages*	0	±8%	PFU/10ml
13-Feb-25	2345949	TNO001	Nokweja Raw	Coll Time OS*	07:20	-	-
13-Feb-25	2345951	TNO001	Nokweja Raw	Colour	9.40	±6.5%	mg Pt-Co/L
13-Feb-25	2345952	TNO001	Nokweja Raw	Conductivity	5.06	±1.5%	mS/m
13-Feb-25	2345950	TNO001	Nokweja Raw	E.coli*	365	±21%	MPN/100mL
13-Feb-25	2345953	TNO001	Nokweja Raw	Fe (AE)	1.02	±5.4%	mg Fe/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

13-Feb-25	2345951	TNO001	Nokweja Raw	Odour*	Mild Earthy	-	-
13-Feb-25	2345949	TNO001	Nokweja Raw	pH OS*	7.60	-	-
13-Feb-25	2345949	TNO001	Nokweja Raw	Temperature OS*	21.3	-	°C
13-Feb-25	2345951	TNO001	Nokweja Raw	Turbidity	89.5	±6.1%	NTU
14-Feb-25	2346244	TIB001	Ibisi Raw	Al (AE)	870	±7.6%	µg Al/L
14-Feb-25	2346241	TIB001	Ibisi Raw	Coliforms*	>2420	±22%	MPN/100mL
14-Feb-25	2346241	TIB001	Ibisi Raw	Coliphages*	12	±8%	PFU/10ml
14-Feb-25	2346240	TIB001	Ibisi Raw	Coll Time OS*	07:52	-	-
14-Feb-25	2346242	TIB001	Ibisi Raw	Colour	21.3	±6.5%	mg Pt-Co/L
14-Feb-25	2346243	TIB001	Ibisi Raw	Conductivity	7.99	±1.5%	mS/m
14-Feb-25	2346241	TIB001	Ibisi Raw	E.coli*	291	±21%	MPN/100mL
14-Feb-25	2346244	TIB001	Ibisi Raw	Fe (AE)	1.78	±5.4%	mg Fe/L
14-Feb-25	2346242	TIB001	Ibisi Raw	Odour*	Nil	-	-
14-Feb-25	2346240	TIB001	Ibisi Raw	pH OS*	7.70	-	-
14-Feb-25	2346240	TIB001	Ibisi Raw	Temperature OS*	22.2	-	°C
14-Feb-25	2346242	TIB001	Ibisi Raw	Turbidity	75.4	±6.1%	NTU
17-Feb-25	2347290	TFR001	Franklin Raw	Al (AE)	495	±7.6%	µg Al/L
17-Feb-25	2347287	TFR001	Franklin Raw	Coliforms*	>2420	±22%	MPN/100mL
17-Feb-25	2347287	TFR001	Franklin Raw	Coliphages*	36	±8%	PFU/10ml
17-Feb-25	2347286	TFR001	Franklin Raw	Coll Time OS*	07:33	-	-
17-Feb-25	2347288	TFR001	Franklin Raw	Colour	6.40	±6.5%	mg Pt-Co/L
17-Feb-25	2347289	TFR001	Franklin Raw	Conductivity	8.86	±1.5%	mS/m
17-Feb-25	2347287	TFR001	Franklin Raw	E.coli*	517	±21%	MPN/100mL
17-Feb-25	2347290	TFR001	Franklin Raw	Fe (AE)	1.89	±5.4%	mg Fe/L
17-Feb-25	2347290	TFR001	Franklin Raw	Mn (AE)	0.08	±6.2%	mg Mn/L
17-Feb-25	2347288	TFR001	Franklin Raw	Odour*	Nil	-	-
17-Feb-25	2347286	TFR001	Franklin Raw	pH OS*	7.30	-	-
17-Feb-25	2347286	TFR001	Franklin Raw	Temperature OS*	19.4	-	°C
17-Feb-25	2347288	TFR001	Franklin Raw	Turbidity	56.9	±6.1%	NTU
17-Feb-25	2347310	TKK001	Kokstad River Raw	Al (AE)	589	±7.6%	µg Al/L
17-Feb-25	2347307	TKK001	Kokstad River Raw	Coliforms*	2420	±22%	MPN/100mL
17-Feb-25	2347307	TKK001	Kokstad River Raw	Coliphages*	10	±8%	PFU/10ml
17-Feb-25	2347306	TKK001	Kokstad River Raw	Coll Time OS*	08:21	-	-
17-Feb-25	2347309	TKK001	Kokstad River Raw	Conductivity	13.7	±1.5%	mS/m
17-Feb-25	2347307	TKK001	Kokstad River Raw	E.coli*	39	±21%	MPN/100mL
17-Feb-25	2347306	TKK001	Kokstad River Raw	pH OS*	7.50	-	-
17-Feb-25	2347306	TKK001	Kokstad River Raw	Temperature OS*	20.3	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

17-Feb-25	2347308	TKK001	Kokstad River Raw	Turbidity	17.5	±6.1%	NTU
17-Feb-25	2347321	TKK003	Kokstad Crystal Spring Raw	Al (AE)	54.1	±7.6%	µg Al/L
17-Feb-25	2347318	TKK003	Kokstad Crystal Spring Raw	Coliforms*	2420	±22%	MPN/100mL
17-Feb-25	2347318	TKK003	Kokstad Crystal Spring Raw	Coliphages*	0	±8%	PFU/10ml
17-Feb-25	2347317	TKK003	Kokstad Crystal Spring Raw	Coll Time OS*	08:17	-	-
17-Feb-25	2347320	TKK003	Kokstad Crystal Spring Raw	Conductivity	11.5	±1.5%	mS/m
17-Feb-25	2347318	TKK003	Kokstad Crystal Spring Raw	E.coli*	3	±21%	MPN/100mL
17-Feb-25	2347317	TKK003	Kokstad Crystal Spring Raw	pH OS*	7.60	-	-
17-Feb-25	2347317	TKK003	Kokstad Crystal Spring Raw	Temperature OS*	20.2	-	°C
17-Feb-25	2347319	TKK003	Kokstad Crystal Spring Raw	Turbidity	16.5	±6.1%	NTU
18-Feb-25	2348043	TQU001	Mnqumeni Raw	Coliforms*	>2420	±22%	MPN/100mL
18-Feb-25	2348042	TQU001	Mnqumeni Raw	Coll Time OS*	08:04	-	-
18-Feb-25	2348045	TQU001	Mnqumeni Raw	Conductivity	9.51	±1.5%	mS/m
18-Feb-25	2348043	TQU001	Mnqumeni Raw	E.coli*	276	±21%	MPN/100mL
18-Feb-25	2348042	TQU001	Mnqumeni Raw	pH OS*	7.60	-	-
18-Feb-25	2348042	TQU001	Mnqumeni Raw	Temperature OS*	26.3	-	°C
18-Feb-25	2348044	TQU001	Mnqumeni Raw	Turbidity	51.6	±6.1%	NTU
18-Feb-25	2348055	TSQ001	Esiqanduleni Raw	Al (AE)	552	±7.6%	µg Al/L
18-Feb-25	2348052	TSQ001	Esiqanduleni Raw	Coliforms*	>2420	±22%	MPN/100mL
18-Feb-25	2348052	TSQ001	Esiqanduleni Raw	Coliphages*	0	±8%	PFU/10ml
18-Feb-25	2348051	TSQ001	Esiqanduleni Raw	Coll Time OS*	07:47	-	-
18-Feb-25	2348054	TSQ001	Esiqanduleni Raw	Conductivity	8.20	±1.5%	mS/m
18-Feb-25	2348052	TSQ001	Esiqanduleni Raw	E.coli*	99	±21%	MPN/100mL
18-Feb-25	2348051	TSQ001	Esiqanduleni Raw	pH OS*	7.40	-	-
18-Feb-25	2348051	TSQ001	Esiqanduleni Raw	Temperature OS*	20.1	-	°C
18-Feb-25	2348053	TSQ001	Esiqanduleni Raw	Turbidity	38.2	±6.1%	NTU
19-Feb-25	2348620	TCR001	Creighton Raw	Al (AE)	402	±7.6%	µg Al/L
19-Feb-25	2348617	TCR001	Creighton Raw	Coliforms*	>2420	±22%	MPN/100mL
19-Feb-25	2348616	TCR001	Creighton Raw	Coll Time OS*	07:41	-	-
19-Feb-25	2348618	TCR001	Creighton Raw	Colour	6.20	±6.5%	mg Pt-Co/L
19-Feb-25	2348619	TCR001	Creighton Raw	Conductivity	7.06	±1.5%	mS/m
19-Feb-25	2348617	TCR001	Creighton Raw	E.coli*	17	±21%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

19-Feb-25	2348616	TCR001	Creighton Raw	pH OS*	7.50	-	-
19-Feb-25	2348616	TCR001	Creighton Raw	Temperature OS*	15.8	-	°C
19-Feb-25	2348618	TCR001	Creighton Raw	Turbidity	10.7	±6.1%	NTU
19-Feb-25	2348628	THL001	Hlanganani Raw	Coliforms*	>2420	±22%	MPN/100mL
19-Feb-25	2348627	THL001	Hlanganani Raw	Coll Time OS*	10:30	-	-
19-Feb-25	2348630	THL001	Hlanganani Raw	Conductivity	7.32	±1.5%	mS/m
19-Feb-25	2348628	THL001	Hlanganani Raw	E.coli*	548	±21%	MPN/100mL
19-Feb-25	2348627	THL001	Hlanganani Raw	pH OS*	7.60	-	-
19-Feb-25	2348627	THL001	Hlanganani Raw	Temperature OS*	18.3	-	°C
19-Feb-25	2348629	THL001	Hlanganani Raw	Turbidity	26.4	±6.1%	NTU
19-Feb-25	2348652	TMQA001	Mqatsheni Raw	Coliforms*	25	±22%	MPN/100mL
19-Feb-25	2348651	TMQA001	Mqatsheni Raw	Coll Time OS*	08:48	-	-
19-Feb-25	2348653	TMQA001	Mqatsheni Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
19-Feb-25	2348654	TMQA001	Mqatsheni Raw	Conductivity	31.9	±1.5%	mS/m
19-Feb-25	2348652	TMQA001	Mqatsheni Raw	E.coli*	0	±21%	MPN/100mL
19-Feb-25	2348651	TMQA001	Mqatsheni Raw	pH OS*	7.10	-	-
19-Feb-25	2348651	TMQA001	Mqatsheni Raw	Temperature OS*	19.7	-	°C
19-Feb-25	2348653	TMQA001	Mqatsheni Raw	Turbidity	0.6	±6.1%	NTU
19-Feb-25	2348664	TRV001	Riversside Raw	Al (AE)	2138	±7.6%	µg Al/L
19-Feb-25	2348661	TRV001	Riversside Raw	Coliforms*	2420	±22%	MPN/100mL
19-Feb-25	2348660	TRV001	Riversside Raw	Coll Time OS*	08:35	-	-
19-Feb-25	2348662	TRV001	Riversside Raw	Colour	1.20	±6.5%	mg Pt-Co/L
19-Feb-25	2348663	TRV001	Riversside Raw	Conductivity	5.73	±1.5%	mS/m
19-Feb-25	2348661	TRV001	Riversside Raw	E.coli*	62	±21%	MPN/100mL
19-Feb-25	2348660	TRV001	Riversside Raw	pH OS*	7.30	-	-
19-Feb-25	2348660	TRV001	Riversside Raw	Temperature OS*	16.0	-	°C
19-Feb-25	2348662	TRV001	Riversside Raw	Turbidity	15.2	±6.1%	NTU
19-Feb-25	2348675	TST001	St Appollinaris Raw	Al (AE)	656	±7.6%	µg Al/L
19-Feb-25	2348672	TST001	St Appollinaris Raw	Coliforms*	>2420	±22%	MPN/100mL
19-Feb-25	2348671	TST001	St Appollinaris Raw	Coll Time OS*	09:30	-	-
19-Feb-25	2348674	TST001	St Appollinaris Raw	Conductivity	4.89	±1.5%	mS/m
19-Feb-25	2348672	TST001	St Appollinaris Raw	E.coli*	770	±21%	MPN/100mL
19-Feb-25	2348671	TST001	St Appollinaris Raw	pH OS*	7.80	-	-
19-Feb-25	2348671	TST001	St Appollinaris Raw	Temperature OS*	18.9	-	°C
19-Feb-25	2348673	TST001	St Appollinaris Raw	Turbidity	36.2	±6.1%	NTU
19-Feb-25	2348686	TUN001	Underberg Raw	Al (AE)	490	±7.6%	µg Al/L
19-Feb-25	2348683	TUN001	Underberg Raw	Coliforms*	>2420	±22%	MPN/100mL
19-Feb-25	2348683	TUN001	Underberg Raw	Coliphages*	12	±8%	PFU/10ml

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

19-Feb-25	2348682	TUN001	Underberg Raw	Coll Time OS*	07:50	-	-
19-Feb-25	2348685	TUN001	Underberg Raw	Conductivity	4.51	±1.5%	mS/m
19-Feb-25	2348683	TUN001	Underberg Raw	E.coli*	148	±21%	MPN/100mL
19-Feb-25	2348682	TUN001	Underberg Raw	pH OS*	7.30	-	-
19-Feb-25	2348682	TUN001	Underberg Raw	Temperature OS*	17.6	-	°C
19-Feb-25	2348684	TUN001	Underberg Raw	Turbidity	19.8	±6.1%	NTU
20-Feb-25	2349247	TMZ001	Umzimkhulu Raw	AI (AE)	1313	±7.6%	µg AI/L
20-Feb-25	2349244	TMZ001	Umzimkhulu Raw	Coliforms*	>2420	±22%	MPN/100mL
20-Feb-25	2349244	TMZ001	Umzimkhulu Raw	Coliphages*	228	±8%	PFU/10ml
20-Feb-25	2349243	TMZ001	Umzimkhulu Raw	Coll Time OS*	7:33	-	-
20-Feb-25	2349246	TMZ001	Umzimkhulu Raw	Conductivity	6.61	±1.5%	mS/m
20-Feb-25	2349244	TMZ001	Umzimkhulu Raw	E.coli*	1733	±21%	MPN/100mL
20-Feb-25	2349243	TMZ001	Umzimkhulu Raw	pH OS*	7.30	-	-
20-Feb-25	2349243	TMZ001	Umzimkhulu Raw	Temperature OS*	20.6	-	°C
20-Feb-25	2349245	TMZ001	Umzimkhulu Raw	Turbidity	87.4	±6.1%	NTU
20-Feb-25	2349258	TNO001	Nokweja Raw	AI (AE)	902	±7.6%	µg AI/L
20-Feb-25	2349255	TNO001	Nokweja Raw	Coliforms*	>2420	±22%	MPN/100mL
20-Feb-25	2349255	TNO001	Nokweja Raw	Coliphages*	254	±8%	PFU/10ml
20-Feb-25	2349254	TNO001	Nokweja Raw	Coll Time OS*	7:20	-	-
20-Feb-25	2349257	TNO001	Nokweja Raw	Conductivity	7.04	±1.5%	mS/m
20-Feb-25	2349255	TNO001	Nokweja Raw	E.coli*	2420	±21%	MPN/100mL
20-Feb-25	2349254	TNO001	Nokweja Raw	pH OS*	7.40	-	-
20-Feb-25	2349254	TNO001	Nokweja Raw	Temperature OS*	19.3	-	°C
20-Feb-25	2349256	TNO001	Nokweja Raw	Turbidity	103.0	±6.1%	NTU
21-Feb-25	2349510	TIB001	Ibisi Raw	AI (AE)	5447	±7.6%	µg AI/L
21-Feb-25	2349507	TIB001	Ibisi Raw	Coliforms*	>2420	±22%	MPN/100mL
21-Feb-25	2349507	TIB001	Ibisi Raw	Coliphages*	>500	±8%	PFU/10ml
21-Feb-25	2349506	TIB001	Ibisi Raw	Coll Time OS*	06:40	-	-
21-Feb-25	2349509	TIB001	Ibisi Raw	Conductivity	7.68	±1.5%	mS/m
21-Feb-25	2349507	TIB001	Ibisi Raw	E.coli*	866	±21%	MPN/100mL
21-Feb-25	2349506	TIB001	Ibisi Raw	pH OS*	7.60	-	-
21-Feb-25	2349506	TIB001	Ibisi Raw	Temperature OS*	21.6	-	°C
21-Feb-25	2349508	TIB001	Ibisi Raw	Turbidity	107.0	±6.1%	NTU
24-Feb-25	2350189	TFR001	Franklin Raw	AI (AE)	483	±7.6%	µg AI/L
24-Feb-25	2350186	TFR001	Franklin Raw	Coliforms*	>2420	±22%	MPN/100mL
24-Feb-25	2350186	TFR001	Franklin Raw	Coliphages*	403	±8%	PFU/10ml
24-Feb-25	2350185	TFR001	Franklin Raw	Coll Time OS*	07:53	-	-
24-Feb-25	2350188	TFR001	Franklin Raw	Conductivity	6.76	±1.5%	mS/m
24-Feb-25	2350186	TFR001	Franklin Raw	E.coli*	2420	±21%	MPN/100mL
24-Feb-25	2350185	TFR001	Franklin Raw	pH OS*	7.00	-	-
24-Feb-25	2350185	TFR001	Franklin Raw	Temperature OS*	24.3	-	°C
24-Feb-25	2350187	TFR001	Franklin Raw	Turbidity	63.9	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

24-Feb-25	2350213	TKK001	Kokstad River Raw	Al (AE)	405	±7.6%	µg Al/L
24-Feb-25	2350210	TKK001	Kokstad River Raw	Coliforms*	>2420	±22%	MPN/100mL
24-Feb-25	2350210	TKK001	Kokstad River Raw	Coliphages*	144	±8%	PFU/10ml
24-Feb-25	2350209	TKK001	Kokstad River Raw	Coll Time OS*	09:30	-	-
24-Feb-25	2350212	TKK001	Kokstad River Raw	Conductivity	10.8	±1.5%	mS/m
24-Feb-25	2350210	TKK001	Kokstad River Raw	E.coli*	210	±21%	MPN/100mL
24-Feb-25	2350209	TKK001	Kokstad River Raw	pH OS*	7.50	-	-
24-Feb-25	2350209	TKK001	Kokstad River Raw	Temperature OS*	22.3	-	°C
24-Feb-25	2350211	TKK001	Kokstad River Raw	Turbidity	39.3	±6.1%	NTU
24-Feb-25	2350224	TKK003	Kokstad Crystal Spring Raw	Al (AE)	235	±7.6%	µg Al/L
24-Feb-25	2350221	TKK003	Kokstad Crystal Spring Raw	Coliforms*	>2420	±22%	MPN/100mL
24-Feb-25	2350221	TKK003	Kokstad Crystal Spring Raw	Coliphages*	95	±8%	PFU/10ml
24-Feb-25	2350220	TKK003	Kokstad Crystal Spring Raw	Coll Time OS*	09:20	-	-
24-Feb-25	2350223	TKK003	Kokstad Crystal Spring Raw	Conductivity	10.9	±1.5%	mS/m
24-Feb-25	2350221	TKK003	Kokstad Crystal Spring Raw	E.coli*	146	±21%	MPN/100mL
24-Feb-25	2350220	TKK003	Kokstad Crystal Spring Raw	pH OS*	7.40	-	-
24-Feb-25	2350220	TKK003	Kokstad Crystal Spring Raw	Temperature OS*	22.1	-	°C
24-Feb-25	2350222	TKK003	Kokstad Crystal Spring Raw	Turbidity	27.7	±6.1%	NTU
25-Feb-25	2350902	TQU001	Mnqumeni Raw	Coliforms*	816	±22%	MPN/100mL
25-Feb-25	2350901	TQU001	Mnqumeni Raw	Coll Time OS*	06:55	-	-
25-Feb-25	2350904	TQU001	Mnqumeni Raw	Conductivity	10.5	±1.5%	mS/m
25-Feb-25	2350902	TQU001	Mnqumeni Raw	E.coli*	26	±21%	MPN/100mL
25-Feb-25	2350901	TQU001	Mnqumeni Raw	pH OS*	7.10	-	-
25-Feb-25	2350901	TQU001	Mnqumeni Raw	Temperature OS*	25.0	-	°C
25-Feb-25	2350903	TQU001	Mnqumeni Raw	Turbidity	35.4	±6.1%	NTU
25-Feb-25	2350914	TSQ001	Esiqanduleni Raw	Al (AE)	833	±7.6%	µg Al/L
25-Feb-25	2350911	TSQ001	Esiqanduleni Raw	Coliforms*	>2420	±22%	MPN/100mL
25-Feb-25	2350911	TSQ001	Esiqanduleni Raw	Coliphages*	172	±8%	PFU/10ml
25-Feb-25	2350910	TSQ001	Esiqanduleni Raw	Coll Time OS*	08:12	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolu | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

25-Feb-25	2350912	TSQ001	Esiqanduleni Raw	Colour	8.00	±6.5%	mg Pt-Co/L
25-Feb-25	2350913	TSQ001	Esiqanduleni Raw	Conductivity	5.81	±1.5%	mS/m
25-Feb-25	2350911	TSQ001	Esiqanduleni Raw	E.coli*	1414	±21%	MPN/100mL
25-Feb-25	2350914	TSQ001	Esiqanduleni Raw	Fe (AE)	1.06	±5.4%	mg Fe/L
25-Feb-25	2350914	TSQ001	Esiqanduleni Raw	Mn (AE)	0.23	±6.2%	mg Mn/L
25-Feb-25	2350912	TSQ001	Esiqanduleni Raw	Odour*	Nil	-	-
25-Feb-25	2350910	TSQ001	Esiqanduleni Raw	pH OS*	7.30	-	-
25-Feb-25	2350910	TSQ001	Esiqanduleni Raw	Temperature OS*	20.2	-	°C
25-Feb-25	2350912	TSQ001	Esiqanduleni Raw	Turbidity	282.0	±6.1%	NTU
26-Feb-25	2351547	TBU001	Bulwer Raw	Al (AE)	598	±7.6%	µg Al/L
26-Feb-25	2351544	TBU001	Bulwer Raw	Coliforms*	>2420	±22%	MPN/100mL
26-Feb-25	2351543	TBU001	Bulwer Raw	Coll Time OS*	10:20	-	-
26-Feb-25	2351545	TBU001	Bulwer Raw	Colour	17.8	±6.5%	mg Pt-Co/L
26-Feb-25	2351546	TBU001	Bulwer Raw	Conductivity	4.18	±1.5%	mS/m
26-Feb-25	2351544	TBU001	Bulwer Raw	E.coli*	687	±21%	MPN/100mL
26-Feb-25	2351545	TBU001	Bulwer Raw	Odour*	Mild Vegetation	-	-
26-Feb-25	2351543	TBU001	Bulwer Raw	pH OS*	7.40	-	-
26-Feb-25	2351543	TBU001	Bulwer Raw	Temperature OS*	21.2	-	°C
26-Feb-25	2351545	TBU001	Bulwer Raw	Turbidity	29.9	±6.1%	NTU
26-Feb-25	2351561	TCR001	Creighton Raw	Al (AE)	1026	±7.6%	µg Al/L
26-Feb-25	2351558	TCR001	Creighton Raw	Coliforms*	>2420	±22%	MPN/100mL
26-Feb-25	2351557	TCR001	Creighton Raw	Coll Time OS*	07:20	-	-
26-Feb-25	2351559	TCR001	Creighton Raw	Colour	15.2	±6.5%	mg Pt-Co/L
26-Feb-25	2351560	TCR001	Creighton Raw	Conductivity	6.31	±1.5%	mS/m
26-Feb-25	2351558	TCR001	Creighton Raw	E.coli*	291	±21%	MPN/100mL
26-Feb-25	2351557	TCR001	Creighton Raw	pH OS*	7.40	-	-
26-Feb-25	2351557	TCR001	Creighton Raw	Temperature OS*	21.2	-	°C
26-Feb-25	2351559	TCR001	Creighton Raw	Turbidity	69.0	±6.1%	NTU
26-Feb-25	2351578	THL001	Hlanganani Raw	Coliforms*	>2420	±22%	MPN/100mL
26-Feb-25	2351577	THL001	Hlanganani Raw	Coll Time OS*	11:15	-	-
26-Feb-25	2351580	THL001	Hlanganani Raw	Conductivity	6.10	±1.5%	mS/m
26-Feb-25	2351578	THL001	Hlanganani Raw	E.coli*	1986	±21%	MPN/100mL
26-Feb-25	2351577	THL001	Hlanganani Raw	pH OS*	7.50	-	-
26-Feb-25	2351577	THL001	Hlanganani Raw	Temperature OS*	23.1	-	°C
26-Feb-25	2351579	THL001	Hlanganani Raw	Turbidity	307.0	±6.1%	NTU
26-Feb-25	2351600	TMAN001	Mangwaneni Raw	Coliforms*	>2420	±22%	MPN/100mL
26-Feb-25	2351599	TMAN001	Mangwaneni Raw	Coll Time OS*	10:42	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

26-Feb-25	2351601	TMAN001	Mangwaneni Raw	Colour	10.9	±6.5%	mg Pt-Co/L
26-Feb-25	2351602	TMAN001	Mangwaneni Raw	Conductivity	7.22	±1.5%	mS/m
26-Feb-25	2351600	TMAN001	Mangwaneni Raw	E.coli*	119	±21%	MPN/100mL
26-Feb-25	2351599	TMAN001	Mangwaneni Raw	pH OS*	7.00	-	-
26-Feb-25	2351599	TMAN001	Mangwaneni Raw	Temperature OS*	23.0	-	°C
26-Feb-25	2351601	TMAN001	Mangwaneni Raw	Turbidity	25.0	±6.1%	NTU
26-Feb-25	2351609	TMQA001	Mqatsheni Raw	Coliforms*	0	±22%	MPN/100mL
26-Feb-25	2351608	TMQA001	Mqatsheni Raw	Coll Time OS*	08:19	-	-
26-Feb-25	2351610	TMQA001	Mqatsheni Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
26-Feb-25	2351611	TMQA001	Mqatsheni Raw	Conductivity	27.8	±1.5%	mS/m
26-Feb-25	2351609	TMQA001	Mqatsheni Raw	E.coli*	0	±21%	MPN/100mL
26-Feb-25	2351610	TMQA001	Mqatsheni Raw	Odour*	Nil	-	-
26-Feb-25	2351608	TMQA001	Mqatsheni Raw	pH OS*	9.20	-	-
26-Feb-25	2351608	TMQA001	Mqatsheni Raw	Temperature OS*	20.1	-	°C
26-Feb-25	2351610	TMQA001	Mqatsheni Raw	Turbidity	2.6	±6.1%	NTU
26-Feb-25	2351625	TRV001	Riversside Raw	AI (AE)	3480	±7.6%	µg AI/L
26-Feb-25	2351622	TRV001	Riversside Raw	Coliforms*	>2420	±22%	MPN/100mL
26-Feb-25	2351621	TRV001	Riversside Raw	Coll Time OS*	08:18	-	-
26-Feb-25	2351623	TRV001	Riversside Raw	Colour	10.5	±6.5%	mg Pt-Co/L
26-Feb-25	2351624	TRV001	Riversside Raw	Conductivity	4.69	±1.5%	mS/m
26-Feb-25	2351622	TRV001	Riversside Raw	E.coli*	178	±21%	MPN/100mL
26-Feb-25	2351621	TRV001	Riversside Raw	pH OS*	7.50	-	-
26-Feb-25	2351621	TRV001	Riversside Raw	Temperature OS*	23.2	-	°C
26-Feb-25	2351623	TRV001	Riversside Raw	Turbidity	41.0	±6.1%	NTU
26-Feb-25	2351640	TST001	St Appollinaris Raw	AI (AE)	445	±7.6%	µg AI/L
26-Feb-25	2351637	TST001	St Appollinaris Raw	Coliforms*	>2420	±22%	MPN/100mL
26-Feb-25	2351636	TST001	St Appollinaris Raw	Coll Time OS*	9:07	-	-
26-Feb-25	2351639	TST001	St Appollinaris Raw	Conductivity	4.27	±1.5%	mS/m
26-Feb-25	2351637	TST001	St Appollinaris Raw	E.coli*	517	±21%	MPN/100mL
26-Feb-25	2351636	TST001	St Appollinaris Raw	pH OS*	7.50	-	-
26-Feb-25	2351636	TST001	St Appollinaris Raw	Temperature OS*	20.4	-	°C
26-Feb-25	2351638	TST001	St Appollinaris Raw	Turbidity	39.0	±6.1%	NTU
26-Feb-25	2351651	TUN001	Underberg Raw	AI (AE)	550	±7.6%	µg AI/L
26-Feb-25	2351648	TUN001	Underberg Raw	Coliforms*	>2420	±22%	MPN/100mL
26-Feb-25	2351648	TUN001	Underberg Raw	Coliphages*	118	±8%	PFU/10ml
26-Feb-25	2351647	TUN001	Underberg Raw	Coll Time OS*	09:31	-	-
26-Feb-25	2351650	TUN001	Underberg Raw	Conductivity	3.59	±1.5%	mS/m
26-Feb-25	2351648	TUN001	Underberg Raw	E.coli*	517	±21%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

26-Feb-25	2351647	TUN001	Underberg Raw	pH OS*	7.10	-	-
26-Feb-25	2351647	TUN001	Underberg Raw	Temperature OS*	19.4	-	°C
26-Feb-25	2351649	TUN001	Underberg Raw	Turbidity	16.6	±6.1%	NTU
27-Feb-25	2352164	TMZ001	Umzimkhulu Raw	Al (AE)	413	±7.6%	µg Al/L
27-Feb-25	2352161	TMZ001	Umzimkhulu Raw	Coliforms*	>2420	±22%	MPN/100mL
27-Feb-25	2352161	TMZ001	Umzimkhulu Raw	Coliphages*	73	±8%	PFU/10ml
27-Feb-25	2352160	TMZ001	Umzimkhulu Raw	Coll Time OS*	07:25	-	-
27-Feb-25	2352163	TMZ001	Umzimkhulu Raw	Conductivity	5.04	±1.5%	mS/m
27-Feb-25	2352161	TMZ001	Umzimkhulu Raw	E.coli*	411	±21%	MPN/100mL
27-Feb-25	2352160	TMZ001	Umzimkhulu Raw	pH OS*	7.10	-	-
27-Feb-25	2352160	TMZ001	Umzimkhulu Raw	Temperature OS*	21.5	-	°C
27-Feb-25	2352162	TMZ001	Umzimkhulu Raw	Turbidity	68.2	±6.1%	NTU
27-Feb-25	2352195	TNO001	Nokweja Raw	Al (AE)	764	±7.6%	µg Al/L
27-Feb-25	2352192	TNO001	Nokweja Raw	Coliforms*	>2420	±22%	MPN/100mL
27-Feb-25	2352192	TNO001	Nokweja Raw	Coliphages*	68	±8%	PFU/10ml
27-Feb-25	2352191	TNO001	Nokweja Raw	Coll Time OS*	07:25	-	-
27-Feb-25	2352194	TNO001	Nokweja Raw	Conductivity	5.05	±1.5%	mS/m
27-Feb-25	2352192	TNO001	Nokweja Raw	E.coli*	1300	±21%	MPN/100mL
27-Feb-25	2352191	TNO001	Nokweja Raw	pH OS*	7.60	-	-
27-Feb-25	2352191	TNO001	Nokweja Raw	Temperature OS*	20.4	-	°C
27-Feb-25	2352193	TNO001	Nokweja Raw	Turbidity	97.6	±6.1%	NTU
27-Feb-25	2352216	TWA001	Washbank Raw	Al (AE)	15311	±7.6%	µg Al/L
27-Feb-25	2352213	TWA001	Washbank Raw	Coliforms*	>2420	±22%	MPN/100mL
27-Feb-25	2352212	TWA001	Washbank Raw	Coll Time OS*	06:34	-	-
27-Feb-25	2352214	TWA001	Washbank Raw	Colour	85.2	±6.5%	mg Pt-Co/L
27-Feb-25	2352215	TWA001	Washbank Raw	Conductivity	9.87	±1.5%	mS/m
27-Feb-25	2352213	TWA001	Washbank Raw	E.coli*	52	±21%	MPN/100mL
27-Feb-25	2352212	TWA001	Washbank Raw	pH OS*	7.60	-	-
27-Feb-25	2352212	TWA001	Washbank Raw	Temperature OS*	20.1	-	°C
27-Feb-25	2352214	TWA001	Washbank Raw	Turbidity	59.2	±6.1%	NTU
28-Feb-25	2352437	TIB001	Ibisi Raw	Al (AE)	1193	±7.6%	µg Al/L
28-Feb-25	2352434	TIB001	Ibisi Raw	Coliforms*	>2420	±22%	MPN/100mL
28-Feb-25	2352434	TIB001	Ibisi Raw	Coliphages*	14	±8%	PFU/10ml
28-Feb-25	2352433	TIB001	Ibisi Raw	Coll Time OS*	07:20	-	-
28-Feb-25	2352436	TIB001	Ibisi Raw	Conductivity	7.92	±1.5%	mS/m
28-Feb-25	2352434	TIB001	Ibisi Raw	E.coli*	365	±21%	MPN/100mL
28-Feb-25	2352433	TIB001	Ibisi Raw	pH OS*	7.60	-	-
28-Feb-25	2352433	TIB001	Ibisi Raw	Temperature OS*	20.4	-	°C
28-Feb-25	2352435	TIB001	Ibisi Raw	Turbidity	75.0	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)