

Date: 10 July 2025

The Executive Director: Water Services Department

Harry Gwala District Municipality

40 Main Street

Ixopo

3276

**Attention: Basetsana Khathalib and Bheki Nene**

### **JUNE 2025 TREATED WATER (FINAL) RESULTS**

Please find June 2025 Treated Water (Final) results tabulated below for samples received during June 2025. Determinands marked with an asterix are unaccredited and are not included in uMngeni-uThukela Water's schedule of accreditation.

Please contact us immediately should you have any queries.

Yours' Sincerely

Mr M Sewcharan

Client Services Manager

## **uMngeni-uThukela Water**

### **HEAD OFFICE**

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

| Sample Date | Sample Number | Sampling Point | Description                   | Determinand     | Result   | UOM   | Unit       |
|-------------|---------------|----------------|-------------------------------|-----------------|----------|-------|------------|
| 02-Jun-25   | 2406989       | TFR002         | Franklin Final                | Al (AE)         | 198      | ±7.6% | µg Al/L    |
| 02-Jun-25   | 2406984       | TFR002         | Franklin Final                | Batch No.*      | 20250201 | -     | -          |
| 02-Jun-25   | 2406984       | TFR002         | Franklin Final                | Cl2 (F) OS*     | 0.96     | -     | mg Cl2/L   |
| 02-Jun-25   | 2406984       | TFR002         | Franklin Final                | Cl2 (T) OS*     | 1.35     | -     | mg Cl2/L   |
| 02-Jun-25   | 2406985       | TFR002         | Franklin Final                | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 02-Jun-25   | 2406985       | TFR002         | Franklin Final                | Coliphages*     | 0        | ±8%   | PFU/10ml   |
| 02-Jun-25   | 2406984       | TFR002         | Franklin Final                | Coll Time OS*   | 8:31     | -     | -          |
| 02-Jun-25   | 2406987       | TFR002         | Franklin Final                | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 02-Jun-25   | 2406988       | TFR002         | Franklin Final                | Conductivity    | 13.6     | ±1.5% | mS/m       |
| 02-Jun-25   | 2406985       | TFR002         | Franklin Final                | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 02-Jun-25   | 2406989       | TFR002         | Franklin Final                | Fe (AE)         | 0.96     | ±5.4% | mg Fe/L    |
| 02-Jun-25   | 2406985       | TFR002         | Franklin Final                | HPC 37*         | 0        | ±21%  | cfu/mL     |
| 02-Jun-25   | 2406989       | TFR002         | Franklin Final                | Mn (AE)         | <0.01    | ±6.2% | mg Mn/L    |
| 02-Jun-25   | 2406984       | TFR002         | Franklin Final                | pH OS*          | 7.50     | -     | -          |
| 02-Jun-25   | 2406984       | TFR002         | Franklin Final                | Temperature OS* | 8.8      | -     | °C         |
| 02-Jun-25   | 2406987       | TFR002         | Franklin Final                | Turbidity       | 0.9      | ±6.1% | NTU        |
| 02-Jun-25   | 2406990       | TFR003         | Franklin Police Station Retic | Batch No.*      | 20250201 | -     | -          |
| 02-Jun-25   | 2406990       | TFR003         | Franklin Police Station Retic | Cl2 (F) OS*     | 0.90     | -     | mg Cl2/L   |
| 02-Jun-25   | 2406990       | TFR003         | Franklin Police Station Retic | Cl2 (T) OS*     | 1.20     | -     | mg Cl2/L   |
| 02-Jun-25   | 2406991       | TFR003         | Franklin Police Station Retic | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 02-Jun-25   | 2406990       | TFR003         | Franklin Police Station Retic | Coll Time OS*   | 8;21     | -     | -          |
| 02-Jun-25   | 2406991       | TFR003         | Franklin Police Station Retic | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 02-Jun-25   | 2406991       | TFR003         | Franklin Police Station Retic | HPC 37*         | 0        | ±21%  | cfu/mL     |
| 02-Jun-25   | 2406990       | TFR003         | Franklin Police Station Retic | pH OS*          | 7.80     | -     | -          |
| 02-Jun-25   | 2406990       | TFR003         | Franklin Police Station Retic | Temperature OS* | 11.6     | -     | °C         |
| 02-Jun-25   | 2406993       | TFR003         | Franklin Police Station Retic | Turbidity       | 0.7      | ±6.1% | NTU        |
| 02-Jun-25   | 2407021       | TKK002         | Kokstad Final                 | Al (AE)         | <25.0    | ±7.6% | µg Al/L    |
| 02-Jun-25   | 2407016       | TKK002         | Kokstad Final                 | Batch No.*      | 20250201 | -     | -          |
| 02-Jun-25   | 2407016       | TKK002         | Kokstad Final                 | Cl2 (F) OS*     | 1.36     | -     | mg Cl2/L   |
| 02-Jun-25   | 2407016       | TKK002         | Kokstad Final                 | Cl2 (T) OS*     | 1.49     | -     | mg Cl2/L   |
| 02-Jun-25   | 2407017       | TKK002         | Kokstad Final                 | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 02-Jun-25   | 2407017       | TKK002         | Kokstad Final                 | Coliphages*     | 0        | ±8%   | PFU/10ml   |
| 02-Jun-25   | 2407016       | TKK002         | Kokstad Final                 | Coll Time OS*   | 9:20     | -     | -          |
| 02-Jun-25   | 2407019       | TKK002         | Kokstad Final                 | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 02-Jun-25   | 2407020       | TKK002         | Kokstad Final                 | Conductivity    | 12.2     | ±1.5% | mS/m       |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

|           |         |        |                                          |                 |          |       |            |
|-----------|---------|--------|------------------------------------------|-----------------|----------|-------|------------|
| 02-Jun-25 | 2407017 | TKK002 | Kokstad Final                            | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 02-Jun-25 | 2407021 | TKK002 | Kokstad Final                            | Fe (AE)         | 0.05     | ±5.4% | mg Fe/L    |
| 02-Jun-25 | 2407017 | TKK002 | Kokstad Final                            | HPC 37*         | 0        | ±21%  | cfu/mL     |
| 02-Jun-25 | 2407019 | TKK002 | Kokstad Final                            | Odour*          | Nil      | -     | -          |
| 02-Jun-25 | 2407016 | TKK002 | Kokstad Final                            | pH OS*          | 7.40     | -     | -          |
| 02-Jun-25 | 2407019 | TKK002 | Kokstad Final                            | Taste*          | Nil      | -     | -          |
| 02-Jun-25 | 2407016 | TKK002 | Kokstad Final                            | Temperature OS* | 13.2     | -     | °C         |
| 02-Jun-25 | 2407019 | TKK002 | Kokstad Final                            | Turbidity       | 0.2      | ±6.1% | NTU        |
| 02-Jun-25 | 2407031 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Batch No.*      | 20250201 | -     | -          |
| 02-Jun-25 | 2407031 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Cl2 (F) OS*     | 0.45     | -     | mg Cl2/L   |
| 02-Jun-25 | 2407031 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Cl2 (T) OS*     | 0.62     | -     | mg Cl2/L   |
| 02-Jun-25 | 2407032 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 02-Jun-25 | 2407031 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Coll Time OS*   | 8:55     | -     | -          |
| 02-Jun-25 | 2407034 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 02-Jun-25 | 2407032 | TKK006 | Kokstad Bongweni Correctional Serv Retic | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 02-Jun-25 | 2407032 | TKK006 | Kokstad Bongweni Correctional Serv Retic | HPC 37*         | 0        | ±21%  | cfu/mL     |
| 02-Jun-25 | 2407034 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Odour*          | Nil      | -     | -          |
| 02-Jun-25 | 2407031 | TKK006 | Kokstad Bongweni Correctional Serv Retic | pH OS*          | 7.20     | -     | -          |
| 02-Jun-25 | 2407034 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Taste*          | Nil      | -     | -          |
| 02-Jun-25 | 2407031 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Temperature OS* | 15.2     | -     | °C         |
| 02-Jun-25 | 2407034 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Turbidity       | <0.2     | ±6.1% | NTU        |
| 02-Jun-25 | 2407035 | TKK007 | Kokstad Shayamoya Reticulation           | Batch No.*      | 20250201 | -     | -          |
| 02-Jun-25 | 2407035 | TKK007 | Kokstad Shayamoya Reticulation           | Cl2 (F) OS*     | 0.88     | -     | mg Cl2/L   |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

|           |         |        |                                   |                         |          |       |                       |
|-----------|---------|--------|-----------------------------------|-------------------------|----------|-------|-----------------------|
| 02-Jun-25 | 2407035 | TKK007 | Kokstad Shayamoya Reticulation    | Cl <sub>2</sub> (T) OS* | 1.04     | -     | mg Cl <sub>2</sub> /L |
| 02-Jun-25 | 2407036 | TKK007 | Kokstad Shayamoya Reticulation    | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 02-Jun-25 | 2407035 | TKK007 | Kokstad Shayamoya Reticulation    | Coll Time OS*           | 10:10    | -     | -                     |
| 02-Jun-25 | 2407038 | TKK007 | Kokstad Shayamoya Reticulation    | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 02-Jun-25 | 2407036 | TKK007 | Kokstad Shayamoya Reticulation    | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 02-Jun-25 | 2407036 | TKK007 | Kokstad Shayamoya Reticulation    | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 02-Jun-25 | 2407038 | TKK007 | Kokstad Shayamoya Reticulation    | Odour*                  | Nil      | -     | -                     |
| 02-Jun-25 | 2407035 | TKK007 | Kokstad Shayamoya Reticulation    | pH OS*                  | 7.30     | -     | -                     |
| 02-Jun-25 | 2407038 | TKK007 | Kokstad Shayamoya Reticulation    | Taste*                  | Nil      | -     | -                     |
| 02-Jun-25 | 2407035 | TKK007 | Kokstad Shayamoya Reticulation    | Temperature OS*         | 16.0     | -     | °C                    |
| 02-Jun-25 | 2407038 | TKK007 | Kokstad Shayamoya Reticulation    | Turbidity               | 0.3      | ±6.1% | NTU                   |
| 02-Jun-25 | 2407039 | TKK009 | Kokstad Farm Fresh Produce Market | Batch No.*              | 20250201 | -     | -                     |
| 02-Jun-25 | 2407039 | TKK009 | Kokstad Farm Fresh Produce Market | Cl <sub>2</sub> (F) OS* | 1.35     | -     | mg Cl <sub>2</sub> /L |
| 02-Jun-25 | 2407039 | TKK009 | Kokstad Farm Fresh Produce Market | Cl <sub>2</sub> (T) OS* | 1.40     | -     | mg Cl <sub>2</sub> /L |
| 02-Jun-25 | 2407040 | TKK009 | Kokstad Farm Fresh Produce Market | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 02-Jun-25 | 2407039 | TKK009 | Kokstad Farm Fresh Produce Market | Coll Time OS*           | 9:50     | -     | -                     |
| 02-Jun-25 | 2407042 | TKK009 | Kokstad Farm Fresh Produce Market | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 02-Jun-25 | 2407040 | TKK009 | Kokstad Farm Fresh Produce Market | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 02-Jun-25 | 2407040 | TKK009 | Kokstad Farm Fresh Produce Market | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 02-Jun-25 | 2407042 | TKK009 | Kokstad Farm Fresh Produce Market | Odour*                  | Nil      | -     | -                     |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

|           |         |         |                                   |                         |          |       |                       |
|-----------|---------|---------|-----------------------------------|-------------------------|----------|-------|-----------------------|
| 02-Jun-25 | 2407039 | TKK009  | Kokstad Farm Fresh Produce Market | pH OS*                  | 7.50     | -     | -                     |
| 02-Jun-25 | 2407042 | TKK009  | Kokstad Farm Fresh Produce Market | Taste*                  | Nil      | -     | -                     |
| 02-Jun-25 | 2407039 | TKK009  | Kokstad Farm Fresh Produce Market | Temperature OS*         | 15.4     | -     | °C                    |
| 02-Jun-25 | 2407042 | TKK009  | Kokstad Farm Fresh Produce Market | Turbidity               | <0.2     | ±6.1% | NTU                   |
| 02-Jun-25 | 2407043 | TKK012  | Kokstad FET College Reticulation  | Batch No.*              | 20250201 | -     | -                     |
| 02-Jun-25 | 2407043 | TKK012  | Kokstad FET College Reticulation  | Cl <sub>2</sub> (F) OS* | 0.84     | -     | mg Cl <sub>2</sub> /L |
| 02-Jun-25 | 2407043 | TKK012  | Kokstad FET College Reticulation  | Cl <sub>2</sub> (T) OS* | 1.09     | -     | mg Cl <sub>2</sub> /L |
| 02-Jun-25 | 2407044 | TKK012  | Kokstad FET College Reticulation  | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 02-Jun-25 | 2407043 | TKK012  | Kokstad FET College Reticulation  | Coll Time OS*           | 8:40     | -     | -                     |
| 02-Jun-25 | 2407046 | TKK012  | Kokstad FET College Reticulation  | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 02-Jun-25 | 2407047 | TKK012  | Kokstad FET College Reticulation  | Conductivity            | 12.7     | ±1.5% | mS/m                  |
| 02-Jun-25 | 2407044 | TKK012  | Kokstad FET College Reticulation  | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 02-Jun-25 | 2407044 | TKK012  | Kokstad FET College Reticulation  | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 02-Jun-25 | 2407043 | TKK012  | Kokstad FET College Reticulation  | pH OS*                  | 7.30     | -     | -                     |
| 02-Jun-25 | 2407043 | TKK012  | Kokstad FET College Reticulation  | Temperature OS*         | 14.2     | -     | °C                    |
| 02-Jun-25 | 2407046 | TKK012  | Kokstad FET College Reticulation  | Turbidity               | 0.2      | ±6.1% | NTU                   |
| 02-Jun-25 | 2407075 | TNJU002 | KwaNjunga Final                   | Al (AE)                 | 30.8     | ±7.6% | µg Al/L               |
| 02-Jun-25 | 2407070 | TNJU002 | KwaNjunga Final                   | Batch No.*              | 20250201 | -     | -                     |
| 02-Jun-25 | 2407070 | TNJU002 | KwaNjunga Final                   | Cl <sub>2</sub> (F) OS* | 0.80     | -     | mg Cl <sub>2</sub> /L |
| 02-Jun-25 | 2407070 | TNJU002 | KwaNjunga Final                   | Cl <sub>2</sub> (T) OS* | 0.96     | -     | mg Cl <sub>2</sub> /L |
| 02-Jun-25 | 2407071 | TNJU002 | KwaNjunga Final                   | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 02-Jun-25 | 2407070 | TNJU002 | KwaNjunga Final                   | Coll Time OS*           | 7:38     | -     | -                     |
| 02-Jun-25 | 2407074 | TNJU002 | KwaNjunga Final                   | Conductivity            | 17.3     | ±1.5% | mS/m                  |
| 02-Jun-25 | 2407071 | TNJU002 | KwaNjunga Final                   | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 02-Jun-25 | 2407075 | TNJU002 | KwaNjunga Final                   | Fe (AE)                 | <0.02    | ±5.4% | mg Fe/L               |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

|           |         |         |                           |                         |          |       |                       |
|-----------|---------|---------|---------------------------|-------------------------|----------|-------|-----------------------|
| 02-Jun-25 | 2407071 | TNJU002 | KwaNjunga Final           | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 02-Jun-25 | 2407075 | TNJU002 | KwaNjunga Final           | Mn (AE)                 | <0.01    | ±6.2% | mg Mn/L               |
| 02-Jun-25 | 2407073 | TNJU002 | KwaNjunga Final           | Odour*                  | Nil      | -     | -                     |
| 02-Jun-25 | 2407070 | TNJU002 | KwaNjunga Final           | pH OS*                  | 7.70     | -     | -                     |
| 02-Jun-25 | 2407070 | TNJU002 | KwaNjunga Final           | Temperature OS*         | 15.4     | -     | °C                    |
| 02-Jun-25 | 2407073 | TNJU002 | KwaNjunga Final           | Turbidity               | 0.8      | ±6.1% | NTU                   |
| 02-Jun-25 | 2407076 | TNJU003 | KwaNjunga Reticulation    | Batch No.*              | 20250201 | -     | -                     |
| 02-Jun-25 | 2407076 | TNJU003 | KwaNjunga Reticulation    | Cl <sub>2</sub> (F) OS* | 0.10     | -     | mg Cl <sub>2</sub> /L |
| 02-Jun-25 | 2407076 | TNJU003 | KwaNjunga Reticulation    | Cl <sub>2</sub> (T) OS* | 0.15     | -     | mg Cl <sub>2</sub> /L |
| 02-Jun-25 | 2407077 | TNJU003 | KwaNjunga Reticulation    | Coliforms*              | 1        | ±15%  | MPN/100mL             |
| 02-Jun-25 | 2407076 | TNJU003 | KwaNjunga Reticulation    | Coll Time OS*           | 7:20     | -     | -                     |
| 02-Jun-25 | 2407079 | TNJU003 | KwaNjunga Reticulation    | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 02-Jun-25 | 2407080 | TNJU003 | KwaNjunga Reticulation    | Conductivity            | 17.0     | ±1.5% | mS/m                  |
| 02-Jun-25 | 2407077 | TNJU003 | KwaNjunga Reticulation    | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 02-Jun-25 | 2407077 | TNJU003 | KwaNjunga Reticulation    | HPC 37*                 | 1        | ±21%  | cfu/mL                |
| 02-Jun-25 | 2407079 | TNJU003 | KwaNjunga Reticulation    | Odour*                  | Nil      | -     | -                     |
| 02-Jun-25 | 2407076 | TNJU003 | KwaNjunga Reticulation    | pH OS*                  | 8.80     | -     | -                     |
| 02-Jun-25 | 2407076 | TNJU003 | KwaNjunga Reticulation    | Temperature OS*         | 12.6     | -     | °C                    |
| 02-Jun-25 | 2407079 | TNJU003 | KwaNjunga Reticulation    | Turbidity               | 0.5      | ±6.1% | NTU                   |
| 03-Jun-25 | 2407631 | TJO001  | Jolivet RRT frn Vulamehlo | Batch No.*              | 26250201 | -     | -                     |
| 03-Jun-25 | 2407631 | TJO001  | Jolivet RRT frn Vulamehlo | Cl <sub>2</sub> (F) OS* | 0.60     | -     | mg Cl <sub>2</sub> /L |
| 03-Jun-25 | 2407631 | TJO001  | Jolivet RRT frn Vulamehlo | Cl <sub>2</sub> (T) OS* | 0.80     | -     | mg Cl <sub>2</sub> /L |
| 03-Jun-25 | 2407632 | TJO001  | Jolivet RRT frn Vulamehlo | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 03-Jun-25 | 2407631 | TJO001  | Jolivet RRT frn Vulamehlo | Coll Time OS*           | 10h55    | -     | -                     |
| 03-Jun-25 | 2407632 | TJO001  | Jolivet RRT frn Vulamehlo | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 03-Jun-25 | 2407632 | TJO001  | Jolivet RRT frn Vulamehlo | HPC 37*                 | 6        | ±21%  | cfu/mL                |
| 03-Jun-25 | 2407631 | TJO001  | Jolivet RRT frn Vulamehlo | pH OS*                  | 7.90     | -     | -                     |
| 03-Jun-25 | 2407631 | TJO001  | Jolivet RRT frn Vulamehlo | Temperature OS*         | 21.1     | -     | °C                    |
| 03-Jun-25 | 2407634 | TJO001  | Jolivet RRT frn Vulamehlo | Turbidity               | 4.9      | ±6.1% | NTU                   |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,

Telephone (033) 341 1111

E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

|           |         |        |                           |                 |          |       |            |
|-----------|---------|--------|---------------------------|-----------------|----------|-------|------------|
| 03-Jun-25 | 2407707 | TQU002 | Mnqumeni Final            | Al (AE)         | 67.9     | ±7.6% | µg Al/L    |
| 03-Jun-25 | 2407702 | TQU002 | Mnqumeni Final            | Batch No.*      | 20250201 | -     | -          |
| 03-Jun-25 | 2407702 | TQU002 | Mnqumeni Final            | Cl2 (F) OS*     | 0.60     | -     | mg Cl2/L   |
| 03-Jun-25 | 2407702 | TQU002 | Mnqumeni Final            | Cl2 (T) OS*     | 0.78     | -     | mg Cl2/L   |
| 03-Jun-25 | 2407703 | TQU002 | Mnqumeni Final            | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 03-Jun-25 | 2407702 | TQU002 | Mnqumeni Final            | Coll Time OS*   | 08:29    | -     | -          |
| 03-Jun-25 | 2407706 | TQU002 | Mnqumeni Final            | Conductivity    | 12.9     | ±1.5% | mS/m       |
| 03-Jun-25 | 2407703 | TQU002 | Mnqumeni Final            | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 03-Jun-25 | 2407707 | TQU002 | Mnqumeni Final            | Fe (AE)         | <0.02    | ±5.4% | mg Fe/L    |
| 03-Jun-25 | 2407703 | TQU002 | Mnqumeni Final            | HPC 37*         | 0        | ±21%  | cfu/mL     |
| 03-Jun-25 | 2407707 | TQU002 | Mnqumeni Final            | Mn (AE)         | <0.01    | ±6.2% | mg Mn/L    |
| 03-Jun-25 | 2407705 | TQU002 | Mnqumeni Final            | Odour*          | Nil      | -     | -          |
| 03-Jun-25 | 2407702 | TQU002 | Mnqumeni Final            | pH OS*          | 8.70     | -     | -          |
| 03-Jun-25 | 2407705 | TQU002 | Mnqumeni Final            | Taste*          | Nil      | -     | -          |
| 03-Jun-25 | 2407702 | TQU002 | Mnqumeni Final            | Temperature OS* | 14.3     | -     | °C         |
| 03-Jun-25 | 2407705 | TQU002 | Mnqumeni Final            | Turbidity       | 0.3      | ±6.1% | NTU        |
| 03-Jun-25 | 2407718 | TSQ002 | Esiqanduleni Final        | Al (AE)         | 47.1     | ±7.6% | µg Al/L    |
| 03-Jun-25 | 2407713 | TSQ002 | Esiqanduleni Final        | Batch No.*      | 20250201 | -     | -          |
| 03-Jun-25 | 2407713 | TSQ002 | Esiqanduleni Final        | Cl2 (F) OS*     | 1.02     | -     | mg Cl2/L   |
| 03-Jun-25 | 2407713 | TSQ002 | Esiqanduleni Final        | Cl2 (T) OS*     | 1.09     | -     | mg Cl2/L   |
| 03-Jun-25 | 2407714 | TSQ002 | Esiqanduleni Final        | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 03-Jun-25 | 2407713 | TSQ002 | Esiqanduleni Final        | Coll Time OS*   | 07:30    | -     | -          |
| 03-Jun-25 | 2407716 | TSQ002 | Esiqanduleni Final        | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 03-Jun-25 | 2407717 | TSQ002 | Esiqanduleni Final        | Conductivity    | 17.5     | ±1.5% | mS/m       |
| 03-Jun-25 | 2407714 | TSQ002 | Esiqanduleni Final        | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 03-Jun-25 | 2407718 | TSQ002 | Esiqanduleni Final        | Fe (AE)         | <0.02    | ±5.4% | mg Fe/L    |
| 03-Jun-25 | 2407714 | TSQ002 | Esiqanduleni Final        | HPC 37*         | 2        | ±21%  | cfu/mL     |
| 03-Jun-25 | 2407718 | TSQ002 | Esiqanduleni Final        | Mn (AE)         | <0.01    | ±6.2% | mg Mn/L    |
| 03-Jun-25 | 2407716 | TSQ002 | Esiqanduleni Final        | Odour*          | Nil      | -     | -          |
| 03-Jun-25 | 2407713 | TSQ002 | Esiqanduleni Final        | pH OS*          | 7.60     | -     | -          |
| 03-Jun-25 | 2407713 | TSQ002 | Esiqanduleni Final        | Temperature OS* | 14.3     | -     | °C         |
| 03-Jun-25 | 2407716 | TSQ002 | Esiqanduleni Final        | Turbidity       | 0.5      | ±6.1% | NTU        |
| 03-Jun-25 | 2407719 | TSQ003 | Esiqanduleni Reticulation | Batch No.*      | 20250201 | -     | -          |
| 03-Jun-25 | 2407719 | TSQ003 | Esiqanduleni Reticulation | Cl2 (F) OS*     | 0.74     | -     | mg Cl2/L   |
| 03-Jun-25 | 2407719 | TSQ003 | Esiqanduleni Reticulation | Cl2 (T) OS*     | 0.80     | -     | mg Cl2/L   |
| 03-Jun-25 | 2407720 | TSQ003 | Esiqanduleni Reticulation | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 03-Jun-25 | 2407719 | TSQ003 | Esiqanduleni Reticulation | Coll Time OS*   | 07:41    | -     | -          |
| 03-Jun-25 | 2407722 | TSQ003 | Esiqanduleni Reticulation | Colour          | 1.90     | ±6.5% | mg Pt-Co/L |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

|           |         |        |                                  |                         |          |       |                       |
|-----------|---------|--------|----------------------------------|-------------------------|----------|-------|-----------------------|
| 03-Jun-25 | 2407723 | TSQ003 | Esiqanduleni Reticulation        | Conductivity            | 17.4     | ±1.5% | mS/m                  |
| 03-Jun-25 | 2407720 | TSQ003 | Esiqanduleni Reticulation        | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 03-Jun-25 | 2407720 | TSQ003 | Esiqanduleni Reticulation        | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 03-Jun-25 | 2407722 | TSQ003 | Esiqanduleni Reticulation        | Odour*                  | Nil      | -     | -                     |
| 03-Jun-25 | 2407719 | TSQ003 | Esiqanduleni Reticulation        | pH OS*                  | 7.50     | -     | -                     |
| 03-Jun-25 | 2407719 | TSQ003 | Esiqanduleni Reticulation        | Temperature OS*         | 13.2     | -     | °C                    |
| 03-Jun-25 | 2407722 | TSQ003 | Esiqanduleni Reticulation        | Turbidity               | 1.4      | ±6.1% | NTU                   |
| 04-Jun-25 | 2408281 | TBU002 | Bulwer Final                     | Batch No.*              | 20250201 | -     | -                     |
| 04-Jun-25 | 2408281 | TBU002 | Bulwer Final                     | Cl <sub>2</sub> (F) OS* | 1.51     | -     | mg Cl <sub>2</sub> /L |
| 04-Jun-25 | 2408281 | TBU002 | Bulwer Final                     | Cl <sub>2</sub> (T) OS* | 1.70     | -     | mg Cl <sub>2</sub> /L |
| 04-Jun-25 | 2408282 | TBU002 | Bulwer Final                     | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 04-Jun-25 | 2408281 | TBU002 | Bulwer Final                     | Coll Time OS*           | 10:40    | -     | -                     |
| 04-Jun-25 | 2408284 | TBU002 | Bulwer Final                     | Colour                  | 2.00     | ±6.5% | mg Pt-Co/L            |
| 04-Jun-25 | 2408285 | TBU002 | Bulwer Final                     | Conductivity            | 5.44     | ±1.5% | mS/m                  |
| 04-Jun-25 | 2408282 | TBU002 | Bulwer Final                     | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 04-Jun-25 | 2408286 | TBU002 | Bulwer Final                     | Fe (AE)                 | 0.11     | ±5.4% | mg Fe/L               |
| 04-Jun-25 | 2408282 | TBU002 | Bulwer Final                     | HPC 37*                 | 5        | ±21%  | cfu/mL                |
| 04-Jun-25 | 2408284 | TBU002 | Bulwer Final                     | Odour*                  | Nil      | -     | -                     |
| 04-Jun-25 | 2408281 | TBU002 | Bulwer Final                     | pH OS*                  | 7.40     | -     | -                     |
| 04-Jun-25 | 2408281 | TBU002 | Bulwer Final                     | Temperature OS*         | 14.4     | -     | °C                    |
| 04-Jun-25 | 2408284 | TBU002 | Bulwer Final                     | Turbidity               | 2.4      | ±6.1% | NTU                   |
| 04-Jun-25 | 2408287 | TBU005 | Bulwer Mountain Park Hotel Retic | Batch No.*              | 20250201 | -     | -                     |
| 04-Jun-25 | 2408287 | TBU005 | Bulwer Mountain Park Hotel Retic | Cl <sub>2</sub> (F) OS* | 0.30     | -     | mg Cl <sub>2</sub> /L |
| 04-Jun-25 | 2408287 | TBU005 | Bulwer Mountain Park Hotel Retic | Cl <sub>2</sub> (T) OS* | 0.40     | -     | mg Cl <sub>2</sub> /L |
| 04-Jun-25 | 2408288 | TBU005 | Bulwer Mountain Park Hotel Retic | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 04-Jun-25 | 2408287 | TBU005 | Bulwer Mountain Park Hotel Retic | Coll Time OS*           | 11:05    | -     | -                     |
| 04-Jun-25 | 2408290 | TBU005 | Bulwer Mountain Park Hotel Retic | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 04-Jun-25 | 2408291 | TBU005 | Bulwer Mountain Park Hotel Retic | Conductivity            | 5.49     | ±1.5% | mS/m                  |
| 04-Jun-25 | 2408288 | TBU005 | Bulwer Mountain Park Hotel Retic | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 04-Jun-25 | 2408288 | TBU005 | Bulwer Mountain Park Hotel Retic | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 04-Jun-25 | 2408287 | TBU005 | Bulwer Mountain Park Hotel Retic | pH OS*                  | 7.40     | -     | -                     |
| 04-Jun-25 | 2408287 | TBU005 | Bulwer Mountain Park Hotel Retic | Temperature OS*         | 12.3     | -     | °C                    |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

|           |         |        |                                  |                 |          |       |            |
|-----------|---------|--------|----------------------------------|-----------------|----------|-------|------------|
| 04-Jun-25 | 2408290 | TBU005 | Bulwer Mountain Park Hotel Retic | Turbidity       | 1.0      | ±6.1% | NTU        |
| 04-Jun-25 | 2408302 | TCR002 | Creighton Final                  | Al (AE)         | 123      | ±7.6% | µg Al/L    |
| 04-Jun-25 | 2408297 | TCR002 | Creighton Final                  | Batch No.*      | 20250201 | -     | -          |
| 04-Jun-25 | 2408297 | TCR002 | Creighton Final                  | Cl2 (F) OS*     | 0.68     | -     | mg Cl2/L   |
| 04-Jun-25 | 2408297 | TCR002 | Creighton Final                  | Cl2 (T) OS*     | 0.81     | -     | mg Cl2/L   |
| 04-Jun-25 | 2408298 | TCR002 | Creighton Final                  | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 04-Jun-25 | 2408297 | TCR002 | Creighton Final                  | Coll Time OS*   | 08:34    | -     | -          |
| 04-Jun-25 | 2408300 | TCR002 | Creighton Final                  | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 04-Jun-25 | 2408301 | TCR002 | Creighton Final                  | Conductivity    | 8.46     | ±1.5% | mS/m       |
| 04-Jun-25 | 2408298 | TCR002 | Creighton Final                  | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 04-Jun-25 | 2408302 | TCR002 | Creighton Final                  | Fe (AE)         | <0.02    | ±5.4% | mg Fe/L    |
| 04-Jun-25 | 2408298 | TCR002 | Creighton Final                  | HPC 37*         | 0        | ±21%  | cfu/mL     |
| 04-Jun-25 | 2408302 | TCR002 | Creighton Final                  | Mn (AE)         | <0.01    | ±6.2% | mg Mn/L    |
| 04-Jun-25 | 2408300 | TCR002 | Creighton Final                  | Odour*          | Nil      | -     | -          |
| 04-Jun-25 | 2408297 | TCR002 | Creighton Final                  | pH OS*          | 7.30     | -     | -          |
| 04-Jun-25 | 2408297 | TCR002 | Creighton Final                  | Temperature OS* | 11.6     | -     | °C         |
| 04-Jun-25 | 2408300 | TCR002 | Creighton Final                  | Turbidity       | 0.7      | ±6.1% | NTU        |
| 04-Jun-25 | 2408303 | TCR004 | Creighton Madondo Cottages       | Batch No.*      | 20250201 | -     | -          |
| 04-Jun-25 | 2408303 | TCR004 | Creighton Madondo Cottages       | Cl2 (F) OS*     | 0.73     | -     | mg Cl2/L   |
| 04-Jun-25 | 2408303 | TCR004 | Creighton Madondo Cottages       | Cl2 (T) OS*     | 0.80     | -     | mg Cl2/L   |
| 04-Jun-25 | 2408304 | TCR004 | Creighton Madondo Cottages       | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 04-Jun-25 | 2408303 | TCR004 | Creighton Madondo Cottages       | Coll Time OS*   | 08:20    | -     | -          |
| 04-Jun-25 | 2408306 | TCR004 | Creighton Madondo Cottages       | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 04-Jun-25 | 2408307 | TCR004 | Creighton Madondo Cottages       | Conductivity    | 8.15     | ±1.5% | mS/m       |
| 04-Jun-25 | 2408304 | TCR004 | Creighton Madondo Cottages       | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 04-Jun-25 | 2408304 | TCR004 | Creighton Madondo Cottages       | HPC 37*         | 0        | ±21%  | cfu/mL     |
| 04-Jun-25 | 2408303 | TCR004 | Creighton Madondo Cottages       | pH OS*          | 7.30     | -     | -          |
| 04-Jun-25 | 2408303 | TCR004 | Creighton Madondo Cottages       | Temperature OS* | 10.7     | -     | °C         |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

|           |         |         |                                |                 |          |       |            |
|-----------|---------|---------|--------------------------------|-----------------|----------|-------|------------|
| 04-Jun-25 | 2408306 | TCR004  | Creighton Madondo Cottages     | Turbidity       | 1.4      | ±6.1% | NTU        |
| 04-Jun-25 | 2408322 | THL003  | Hlanganani Clinic Reticulation | Batch No.*      | 20250201 | -     | -          |
| 04-Jun-25 | 2408322 | THL003  | Hlanganani Clinic Reticulation | Cl2 (F) OS*     | 0.15     | -     | mg Cl2/L   |
| 04-Jun-25 | 2408322 | THL003  | Hlanganani Clinic Reticulation | Cl2 (T) OS*     | 0.22     | -     | mg Cl2/L   |
| 04-Jun-25 | 2408323 | THL003  | Hlanganani Clinic Reticulation | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 04-Jun-25 | 2408322 | THL003  | Hlanganani Clinic Reticulation | Coll Time OS*   | 11:48    | -     | -          |
| 04-Jun-25 | 2408325 | THL003  | Hlanganani Clinic Reticulation | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 04-Jun-25 | 2408326 | THL003  | Hlanganani Clinic Reticulation | Conductivity    | 9.17     | ±1.5% | mS/m       |
| 04-Jun-25 | 2408323 | THL003  | Hlanganani Clinic Reticulation | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 04-Jun-25 | 2408323 | THL003  | Hlanganani Clinic Reticulation | HPC 37*         | 1        | ±21%  | cfu/mL     |
| 04-Jun-25 | 2408322 | THL003  | Hlanganani Clinic Reticulation | pH OS*          | 7.20     | -     | -          |
| 04-Jun-25 | 2408322 | THL003  | Hlanganani Clinic Reticulation | Temperature OS* | 12.8     | -     | °C         |
| 04-Jun-25 | 2408325 | THL003  | Hlanganani Clinic Reticulation | Turbidity       | <0.2     | ±6.1% | NTU        |
| 04-Jun-25 | 2408353 | TMQA002 | Mqatsheni Final                | Batch No.*      | 20250201 | -     | -          |
| 04-Jun-25 | 2408353 | TMQA002 | Mqatsheni Final                | Cl2 (F) OS*     | 1.55     | -     | mg Cl2/L   |
| 04-Jun-25 | 2408353 | TMQA002 | Mqatsheni Final                | Cl2 (T) OS*     | 1.70     | -     | mg Cl2/L   |
| 04-Jun-25 | 2408354 | TMQA002 | Mqatsheni Final                | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 04-Jun-25 | 2408353 | TMQA002 | Mqatsheni Final                | Coll Time OS*   | 09:18    | -     | -          |
| 04-Jun-25 | 2408356 | TMQA002 | Mqatsheni Final                | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 04-Jun-25 | 2408357 | TMQA002 | Mqatsheni Final                | Conductivity    | 27.0     | ±1.5% | mS/m       |
| 04-Jun-25 | 2408354 | TMQA002 | Mqatsheni Final                | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 04-Jun-25 | 2408358 | TMQA002 | Mqatsheni Final                | Fe (AE)         | <0.02    | ±5.4% | mg Fe/L    |
| 04-Jun-25 | 2408354 | TMQA002 | Mqatsheni Final                | HPC 37*         | 2        | ±21%  | cfu/mL     |
| 04-Jun-25 | 2408356 | TMQA002 | Mqatsheni Final                | Odour*          | Nil      | -     | -          |
| 04-Jun-25 | 2408353 | TMQA002 | Mqatsheni Final                | pH OS*          | 9.00     | -     | -          |
| 04-Jun-25 | 2408356 | TMQA002 | Mqatsheni Final                | Taste*          | Nil      | -     | -          |
| 04-Jun-25 | 2408353 | TMQA002 | Mqatsheni Final                | Temperature OS* | 10.7     | -     | °C         |
| 04-Jun-25 | 2408356 | TMQA002 | Mqatsheni Final                | Turbidity       | 0.3      | ±6.1% | NTU        |
| 04-Jun-25 | 2408359 | TMQA003 | Mqatsheni Reticulation         | Batch No.*      | 20250201 | -     | -          |
| 04-Jun-25 | 2408359 | TMQA003 | Mqatsheni Reticulation         | Cl2 (F) OS*     | 1.39     | -     | mg Cl2/L   |
| 04-Jun-25 | 2408359 | TMQA003 | Mqatsheni Reticulation         | Cl2 (T) OS*     | 1.52     | -     | mg Cl2/L   |
| 04-Jun-25 | 2408360 | TMQA003 | Mqatsheni Reticulation         | Coliforms*      | 0        | ±15%  | MPN/100mL  |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

|           |         |         |                        |                         |          |       |                       |
|-----------|---------|---------|------------------------|-------------------------|----------|-------|-----------------------|
| 04-Jun-25 | 2408359 | TMQA003 | Mqatsheni Reticulation | Coll Time OS*           | 09:20    | -     | -                     |
| 04-Jun-25 | 2408362 | TMQA003 | Mqatsheni Reticulation | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 04-Jun-25 | 2408363 | TMQA003 | Mqatsheni Reticulation | Conductivity            | 27.2     | ±1.5% | mS/m                  |
| 04-Jun-25 | 2408360 | TMQA003 | Mqatsheni Reticulation | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 04-Jun-25 | 2408360 | TMQA003 | Mqatsheni Reticulation | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 04-Jun-25 | 2408359 | TMQA003 | Mqatsheni Reticulation | pH OS*                  | 9.00     | -     | -                     |
| 04-Jun-25 | 2408359 | TMQA003 | Mqatsheni Reticulation | Temperature OS*         | 10.4     | -     | °C                    |
| 04-Jun-25 | 2408362 | TMQA003 | Mqatsheni Reticulation | Turbidity               | 0.3      | ±6.1% | NTU                   |
| 04-Jun-25 | 2408374 | TRV002  | Riverside Final        | Al (AE)                 | 230      | ±7.6% | µg Al/L               |
| 04-Jun-25 | 2408369 | TRV002  | Riverside Final        | Batch No.*              | 20250201 | -     | -                     |
| 04-Jun-25 | 2408369 | TRV002  | Riverside Final        | Cl <sub>2</sub> (F) OS* | 1.02     | -     | mg Cl <sub>2</sub> /L |
| 04-Jun-25 | 2408369 | TRV002  | Riverside Final        | Cl <sub>2</sub> (T) OS* | 1.10     | -     | mg Cl <sub>2</sub> /L |
| 04-Jun-25 | 2408370 | TRV002  | Riverside Final        | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 04-Jun-25 | 2408370 | TRV002  | Riverside Final        | Coliphages*             | 0        | ±8%   | PFU/10ml              |
| 04-Jun-25 | 2408369 | TRV002  | Riverside Final        | Coll Time OS*           | 09:04    | -     | -                     |
| 04-Jun-25 | 2408372 | TRV002  | Riverside Final        | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 04-Jun-25 | 2408373 | TRV002  | Riverside Final        | Conductivity            | 13.1     | ±1.5% | mS/m                  |
| 04-Jun-25 | 2408370 | TRV002  | Riverside Final        | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 04-Jun-25 | 2408374 | TRV002  | Riverside Final        | Fe (AE)                 | <0.02    | ±5.4% | mg Fe/L               |
| 04-Jun-25 | 2408370 | TRV002  | Riverside Final        | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 04-Jun-25 | 2408372 | TRV002  | Riverside Final        | Odour*                  | Nil      | -     | -                     |
| 04-Jun-25 | 2408369 | TRV002  | Riverside Final        | pH OS*                  | 7.20     | -     | -                     |
| 04-Jun-25 | 2408372 | TRV002  | Riverside Final        | Taste*                  | Nil      | -     | -                     |
| 04-Jun-25 | 2408369 | TRV002  | Riverside Final        | Temperature OS*         | 12.2     | -     | °C                    |
| 04-Jun-25 | 2408372 | TRV002  | Riverside Final        | Turbidity               | 0.4      | ±6.1% | NTU                   |
| 04-Jun-25 | 2408375 | TRV003  | Riverside Reticulation | Batch No.*              | 20250201 | -     | -                     |
| 04-Jun-25 | 2408375 | TRV003  | Riverside Reticulation | Cl <sub>2</sub> (F) OS* | 1.21     | -     | mg Cl <sub>2</sub> /L |
| 04-Jun-25 | 2408375 | TRV003  | Riverside Reticulation | Cl <sub>2</sub> (T) OS* | 1.38     | -     | mg Cl <sub>2</sub> /L |
| 04-Jun-25 | 2408376 | TRV003  | Riverside Reticulation | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 04-Jun-25 | 2408375 | TRV003  | Riverside Reticulation | Coll Time OS*           | 09:15    | -     | -                     |
| 04-Jun-25 | 2408378 | TRV003  | Riverside Reticulation | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 04-Jun-25 | 2408376 | TRV003  | Riverside Reticulation | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 04-Jun-25 | 2408376 | TRV003  | Riverside Reticulation | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 04-Jun-25 | 2408378 | TRV003  | Riverside Reticulation | Odour*                  | Nil      | -     | -                     |
| 04-Jun-25 | 2408375 | TRV003  | Riverside Reticulation | pH OS*                  | 7.40     | -     | -                     |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

|           |         |        |                        |                         |          |       |                       |
|-----------|---------|--------|------------------------|-------------------------|----------|-------|-----------------------|
| 04-Jun-25 | 2408375 | TRV003 | Riverside Reticulation | Temperature OS*         | 11.3     | -     | °C                    |
| 04-Jun-25 | 2408378 | TRV003 | Riverside Reticulation | Turbidity               | 1.2      | ±6.1% | NTU                   |
| 04-Jun-25 | 2408389 | TST002 | St Appollinaris Final  | Al (AE)                 | 93.8     | ±7.6% | µg Al/L               |
| 04-Jun-25 | 2408384 | TST002 | St Appollinaris Final  | Batch No.*              | 20250201 | -     | -                     |
| 04-Jun-25 | 2408384 | TST002 | St Appollinaris Final  | Cl <sub>2</sub> (F) OS* | 1.16     | -     | mg Cl <sub>2</sub> /L |
| 04-Jun-25 | 2408384 | TST002 | St Appollinaris Final  | Cl <sub>2</sub> (T) OS* | 1.28     | -     | mg Cl <sub>2</sub> /L |
| 04-Jun-25 | 2408385 | TST002 | St Appollinaris Final  | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 04-Jun-25 | 2408384 | TST002 | St Appollinaris Final  | Coll Time OS*           | 10:20    | -     | -                     |
| 04-Jun-25 | 2408387 | TST002 | St Appollinaris Final  | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 04-Jun-25 | 2408388 | TST002 | St Appollinaris Final  | Conductivity            | 9.46     | ±1.5% | mS/m                  |
| 04-Jun-25 | 2408385 | TST002 | St Appollinaris Final  | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 04-Jun-25 | 2408385 | TST002 | St Appollinaris Final  | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 04-Jun-25 | 2408387 | TST002 | St Appollinaris Final  | Odour*                  | Nil      | -     | -                     |
| 04-Jun-25 | 2408384 | TST002 | St Appollinaris Final  | pH OS*                  | 7.30     | -     | -                     |
| 04-Jun-25 | 2408384 | TST002 | St Appollinaris Final  | Temperature OS*         | 14.1     | -     | °C                    |
| 04-Jun-25 | 2408387 | TST002 | St Appollinaris Final  | Turbidity               | 0.9      | ±6.1% | NTU                   |
| 04-Jun-25 | 2408400 | TUN002 | Underberg Final        | Al (AE)                 | <25.0    | ±7.6% | µg Al/L               |
| 04-Jun-25 | 2408395 | TUN002 | Underberg Final        | Batch No.*              | 20250201 | -     | -                     |
| 04-Jun-25 | 2408395 | TUN002 | Underberg Final        | Cl <sub>2</sub> (F) OS* | 1.32     | -     | mg Cl <sub>2</sub> /L |
| 04-Jun-25 | 2408395 | TUN002 | Underberg Final        | Cl <sub>2</sub> (T) OS* | 1.45     | -     | mg Cl <sub>2</sub> /L |
| 04-Jun-25 | 2408396 | TUN002 | Underberg Final        | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 04-Jun-25 | 2408395 | TUN002 | Underberg Final        | Coll Time OS*           | 07:37    | -     | -                     |
| 04-Jun-25 | 2408398 | TUN002 | Underberg Final        | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 04-Jun-25 | 2408399 | TUN002 | Underberg Final        | Conductivity            | 7.21     | ±1.5% | mS/m                  |
| 04-Jun-25 | 2408396 | TUN002 | Underberg Final        | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 04-Jun-25 | 2408396 | TUN002 | Underberg Final        | HPC 37*                 | 2        | ±21%  | cfu/mL                |
| 04-Jun-25 | 2408398 | TUN002 | Underberg Final        | Odour*                  | Nil      | -     | -                     |
| 04-Jun-25 | 2408395 | TUN002 | Underberg Final        | pH OS*                  | 7.60     | -     | -                     |
| 04-Jun-25 | 2408395 | TUN002 | Underberg Final        | Temperature OS*         | 10.1     | -     | °C                    |
| 04-Jun-25 | 2408398 | TUN002 | Underberg Final        | Turbidity               | 0.7      | ±6.1% | NTU                   |
| 05-Jun-25 | 2409059 | TMZ002 | Umzimkhulu Final       | Al (AE)                 | 176      | ±7.6% | µg Al/L               |
| 05-Jun-25 | 2409054 | TMZ002 | Umzimkhulu Final       | Batch No.*              | 20250201 | -     | -                     |
| 05-Jun-25 | 2409054 | TMZ002 | Umzimkhulu Final       | Cl <sub>2</sub> (F) OS* | 1.20     | -     | mg Cl <sub>2</sub> /L |
| 05-Jun-25 | 2409054 | TMZ002 | Umzimkhulu Final       | Cl <sub>2</sub> (T) OS* | 1.35     | -     | mg Cl <sub>2</sub> /L |
| 05-Jun-25 | 2409055 | TMZ002 | Umzimkhulu Final       | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 05-Jun-25 | 2409055 | TMZ002 | Umzimkhulu Final       | Coliphages*             | 0        | ±8%   | PFU/10ml              |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

|           |         |        |                                       |                         |          |       |                       |
|-----------|---------|--------|---------------------------------------|-------------------------|----------|-------|-----------------------|
| 05-Jun-25 | 2409054 | TMZ002 | Umzimkhulu Final                      | Coll Time OS*           | 08:47    | -     | -                     |
| 05-Jun-25 | 2409057 | TMZ002 | Umzimkhulu Final                      | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 05-Jun-25 | 2409058 | TMZ002 | Umzimkhulu Final                      | Conductivity            | 10.4     | ±1.5% | mS/m                  |
| 05-Jun-25 | 2409055 | TMZ002 | Umzimkhulu Final                      | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 05-Jun-25 | 2409055 | TMZ002 | Umzimkhulu Final                      | HPC 37*                 | 1        | ±21%  | cfu/mL                |
| 05-Jun-25 | 2409057 | TMZ002 | Umzimkhulu Final                      | Odour*                  | Nil      | -     | -                     |
| 05-Jun-25 | 2409054 | TMZ002 | Umzimkhulu Final                      | pH OS*                  | 7.70     | -     | -                     |
| 05-Jun-25 | 2409054 | TMZ002 | Umzimkhulu Final                      | Temperature OS*         | 13.9     | -     | °C                    |
| 05-Jun-25 | 2409057 | TMZ002 | Umzimkhulu Final                      | Turbidity               | 1.1      | ±6.1% | NTU                   |
| 05-Jun-25 | 2409060 | TMZ004 | Umzikhulu Informal Settlement Retic   | Batch No.*              | 20250201 | -     | -                     |
| 05-Jun-25 | 2409060 | TMZ004 | Umzikhulu Informal Settlement Retic   | Cl <sub>2</sub> (F) OS* | 1.04     | -     | mg Cl <sub>2</sub> /L |
| 05-Jun-25 | 2409060 | TMZ004 | Umzikhulu Informal Settlement Retic   | Cl <sub>2</sub> (T) OS* | 1.14     | -     | mg Cl <sub>2</sub> /L |
| 05-Jun-25 | 2409061 | TMZ004 | Umzikhulu Informal Settlement Retic   | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 05-Jun-25 | 2409060 | TMZ004 | Umzikhulu Informal Settlement Retic   | Coll Time OS*           | 09:06    | -     | -                     |
| 05-Jun-25 | 2409061 | TMZ004 | Umzikhulu Informal Settlement Retic   | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 05-Jun-25 | 2409061 | TMZ004 | Umzikhulu Informal Settlement Retic   | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 05-Jun-25 | 2409060 | TMZ004 | Umzikhulu Informal Settlement Retic   | pH OS*                  | 7.60     | -     | -                     |
| 05-Jun-25 | 2409060 | TMZ004 | Umzikhulu Informal Settlement Retic   | Temperature OS*         | 14.4     | -     | °C                    |
| 05-Jun-25 | 2409063 | TMZ004 | Umzikhulu Informal Settlement Retic   | Turbidity               | 1.6      | ±6.1% | NTU                   |
| 05-Jun-25 | 2409064 | TMZ005 | Umzimkhulu Local Municipality Offices | Batch No.*              | 20250201 | -     | -                     |
| 05-Jun-25 | 2409064 | TMZ005 | Umzimkhulu Local Municipality Offices | Cl <sub>2</sub> (F) OS* | 1.33     | -     | mg Cl <sub>2</sub> /L |
| 05-Jun-25 | 2409064 | TMZ005 | Umzimkhulu Local Municipality Offices | Cl <sub>2</sub> (T) OS* | 1.46     | -     | mg Cl <sub>2</sub> /L |
| 05-Jun-25 | 2409065 | TMZ005 | Umzimkhulu Local Municipality Offices | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 05-Jun-25 | 2409064 | TMZ005 | Umzimkhulu Local Municipality Offices | Coll Time OS*           | 9.17     | -     | -                     |
| 05-Jun-25 | 2409065 | TMZ005 | Umzimkhulu Local Municipality Offices | E.coli*                 | 0        | ±14%  | MPN/100mL             |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

|           |         |        |                                           |                         |          |       |                       |
|-----------|---------|--------|-------------------------------------------|-------------------------|----------|-------|-----------------------|
| 05-Jun-25 | 2409065 | TMZ005 | Umzimkhulu Local Municipality Offices     | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 05-Jun-25 | 2409064 | TMZ005 | Umzimkhulu Local Municipality Offices     | pH OS*                  | 7.50     | -     | -                     |
| 05-Jun-25 | 2409064 | TMZ005 | Umzimkhulu Local Municipality Offices     | Temperature OS*         | 15.0     | -     | °C                    |
| 05-Jun-25 | 2409067 | TMZ005 | Umzimkhulu Local Municipality Offices     | Turbidity               | 2.0      | ±6.1% | NTU                   |
| 05-Jun-25 | 2409068 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | Batch No.*              | 20250201 | -     | -                     |
| 05-Jun-25 | 2409068 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | Cl <sub>2</sub> (F) OS* | 0.43     | -     | mg Cl <sub>2</sub> /L |
| 05-Jun-25 | 2409068 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | Cl <sub>2</sub> (T) OS* | 0.60     | -     | mg Cl <sub>2</sub> /L |
| 05-Jun-25 | 2409069 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 05-Jun-25 | 2409068 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | Coll Time OS*           | 09:36    | -     | -                     |
| 05-Jun-25 | 2409069 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 05-Jun-25 | 2409069 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 05-Jun-25 | 2409068 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | pH OS*                  | 7.60     | -     | -                     |
| 05-Jun-25 | 2409068 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | Temperature OS*         | 15.0     | -     | °C                    |
| 05-Jun-25 | 2409071 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | Turbidity               | 0.7      | ±6.1% | NTU                   |
| 05-Jun-25 | 2409072 | TMZ007 | Umzimkhulu Local FET College              | Batch No.*              | 20250201 | -     | -                     |
| 05-Jun-25 | 2409072 | TMZ007 | Umzimkhulu Local FET College              | Cl <sub>2</sub> (F) OS* | 0.09     | -     | mg Cl <sub>2</sub> /L |
| 05-Jun-25 | 2409072 | TMZ007 | Umzimkhulu Local FET College              | Cl <sub>2</sub> (T) OS* | 0.15     | -     | mg Cl <sub>2</sub> /L |
| 05-Jun-25 | 2409073 | TMZ007 | Umzimkhulu Local FET College              | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 05-Jun-25 | 2409072 | TMZ007 | Umzimkhulu Local FET College              | Coll Time OS*           | 09:28    | -     | -                     |
| 05-Jun-25 | 2409073 | TMZ007 | Umzimkhulu Local FET College              | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 05-Jun-25 | 2409073 | TMZ007 | Umzimkhulu Local FET College              | HPC 37*                 | 37       | ±21%  | cfu/mL                |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

|           |         |        |                                   |                 |          |       |            |
|-----------|---------|--------|-----------------------------------|-----------------|----------|-------|------------|
| 05-Jun-25 | 2409072 | TMZ007 | Umzimkhulu Local FET College      | pH OS*          | 7.30     | -     | -          |
| 05-Jun-25 | 2409072 | TMZ007 | Umzimkhulu Local FET College      | Temperature OS* | 17.4     | -     | °C         |
| 05-Jun-25 | 2409075 | TMZ007 | Umzimkhulu Local FET College      | Turbidity       | 43.0     | ±6.1% | NTU        |
| 05-Jun-25 | 2409086 | TNO002 | Nokweja Final                     | Al (AE)         | 496      | ±7.6% | µg Al/L    |
| 05-Jun-25 | 2409081 | TNO002 | Nokweja Final                     | Batch No.*      | 20250201 | -     | -          |
| 05-Jun-25 | 2409081 | TNO002 | Nokweja Final                     | Cl2 (F) OS*     | 1.02     | -     | mg Cl2/L   |
| 05-Jun-25 | 2409081 | TNO002 | Nokweja Final                     | Cl2 (T) OS*     | 1.09     | -     | mg Cl2/L   |
| 05-Jun-25 | 2409082 | TNO002 | Nokweja Final                     | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 05-Jun-25 | 2409082 | TNO002 | Nokweja Final                     | Coliphages*     | 0        | ±8%   | PFU/10ml   |
| 05-Jun-25 | 2409081 | TNO002 | Nokweja Final                     | Coll Time OS*   | 09:18    | -     | -          |
| 05-Jun-25 | 2409084 | TNO002 | Nokweja Final                     | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 05-Jun-25 | 2409085 | TNO002 | Nokweja Final                     | Conductivity    | 11.6     | ±1.5% | mS/m       |
| 05-Jun-25 | 2409082 | TNO002 | Nokweja Final                     | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 05-Jun-25 | 2409082 | TNO002 | Nokweja Final                     | HPC 37*         | 11       | ±21%  | cfu/mL     |
| 05-Jun-25 | 2409084 | TNO002 | Nokweja Final                     | Odour*          | Nil      | -     | -          |
| 05-Jun-25 | 2409081 | TNO002 | Nokweja Final                     | pH OS*          | 7.40     | -     | -          |
| 05-Jun-25 | 2409081 | TNO002 | Nokweja Final                     | Temperature OS* | 16.5     | -     | °C         |
| 05-Jun-25 | 2409084 | TNO002 | Nokweja Final                     | Turbidity       | 2.8      | ±6.1% | NTU        |
| 05-Jun-25 | 2409105 | TWA002 | Washbank Final                    | Al (AE)         | 311      | ±7.6% | µg Al/L    |
| 05-Jun-25 | 2409100 | TWA002 | Washbank Final                    | Batch No.*      | 20250201 | -     | -          |
| 05-Jun-25 | 2409100 | TWA002 | Washbank Final                    | Cl2 (F) OS*     | 0.78     | -     | mg Cl2/L   |
| 05-Jun-25 | 2409100 | TWA002 | Washbank Final                    | Cl2 (T) OS*     | 0.89     | -     | mg Cl2/L   |
| 05-Jun-25 | 2409101 | TWA002 | Washbank Final                    | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 05-Jun-25 | 2409100 | TWA002 | Washbank Final                    | Coll Time OS*   | 08:06    | -     | -          |
| 05-Jun-25 | 2409103 | TWA002 | Washbank Final                    | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 05-Jun-25 | 2409104 | TWA002 | Washbank Final                    | Conductivity    | 7.31     | ±1.5% | mS/m       |
| 05-Jun-25 | 2409101 | TWA002 | Washbank Final                    | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 05-Jun-25 | 2409101 | TWA002 | Washbank Final                    | HPC 37*         | 1        | ±21%  | cfu/mL     |
| 05-Jun-25 | 2409103 | TWA002 | Washbank Final                    | Odour*          | Nil      | -     | -          |
| 05-Jun-25 | 2409100 | TWA002 | Washbank Final                    | pH OS*          | 7.20     | -     | -          |
| 05-Jun-25 | 2409100 | TWA002 | Washbank Final                    | Temperature OS* | 12.7     | -     | °C         |
| 05-Jun-25 | 2409103 | TWA002 | Washbank Final                    | Turbidity       | 2.0      | ±6.1% | NTU        |
| 06-Jun-25 | 2409372 | TIB003 | Ibisi Police Station Reticulation | Batch No.*      | 20250201 | -     | -          |
| 06-Jun-25 | 2409372 | TIB003 | Ibisi Police Station Reticulation | Cl2 (F) OS*     | 0.09     | -     | mg Cl2/L   |
| 06-Jun-25 | 2409372 | TIB003 | Ibisi Police Station Reticulation | Cl2 (T) OS*     | 0.15     | -     | mg Cl2/L   |
| 06-Jun-25 | 2409373 | TIB003 | Ibisi Police Station Reticulation | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 06-Jun-25 | 2409372 | TIB003 | Ibisi Police Station Reticulation | Coll Time OS*   | 07:35    | -     | -          |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

|           |         |        |                                   |                 |          |       |           |
|-----------|---------|--------|-----------------------------------|-----------------|----------|-------|-----------|
| 06-Jun-25 | 2409373 | TIB003 | Ibisi Police Station Reticulation | E.coli*         | 0        | ±14%  | MPN/100mL |
| 06-Jun-25 | 2409373 | TIB003 | Ibisi Police Station Reticulation | HPC 37*         | 1        | ±21%  | cfu/mL    |
| 06-Jun-25 | 2409372 | TIB003 | Ibisi Police Station Reticulation | pH OS*          | 7.40     | -     | -         |
| 06-Jun-25 | 2409372 | TIB003 | Ibisi Police Station Reticulation | Temperature OS* | 16.3     | -     | °C        |
| 06-Jun-25 | 2409375 | TIB003 | Ibisi Police Station Reticulation | Turbidity       | 0.8      | ±6.1% | NTU       |
| 06-Jun-25 | 2409385 | TRT004 | Rietvlei Hospital Reticulation    | Batch No.*      | 20250201 | -     | -         |
| 06-Jun-25 | 2409385 | TRT004 | Rietvlei Hospital Reticulation    | Cl2 (F) OS*     | 1.09     | -     | mg Cl2/L  |
| 06-Jun-25 | 2409385 | TRT004 | Rietvlei Hospital Reticulation    | Cl2 (T) OS*     | 1.18     | -     | mg Cl2/L  |
| 06-Jun-25 | 2409386 | TRT004 | Rietvlei Hospital Reticulation    | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 06-Jun-25 | 2409385 | TRT004 | Rietvlei Hospital Reticulation    | Coll Time OS*   | 07:00    | -     | -         |
| 06-Jun-25 | 2409386 | TRT004 | Rietvlei Hospital Reticulation    | E.coli*         | 0        | ±14%  | MPN/100mL |
| 06-Jun-25 | 2409386 | TRT004 | Rietvlei Hospital Reticulation    | HPC 37*         | 0        | ±21%  | cfu/mL    |
| 06-Jun-25 | 2409385 | TRT004 | Rietvlei Hospital Reticulation    | pH OS*          | 7.40     | -     | -         |
| 06-Jun-25 | 2409385 | TRT004 | Rietvlei Hospital Reticulation    | Temperature OS* | 16.4     | -     | °C        |
| 06-Jun-25 | 2409388 | TRT004 | Rietvlei Hospital Reticulation    | Turbidity       | 3.2      | ±6.1% | NTU       |
| 09-Jun-25 | 2411556 | TFR002 | Franklin Final                    | Al (AE)         | 289      | ±7.6% | µg Al/L   |
| 09-Jun-25 | 2411551 | TFR002 | Franklin Final                    | Batch No.*      | 20250201 | -     | -         |
| 09-Jun-25 | 2411551 | TFR002 | Franklin Final                    | Cl2 (F) OS*     | 0.63     | -     | mg Cl2/L  |
| 09-Jun-25 | 2411551 | TFR002 | Franklin Final                    | Cl2 (T) OS*     | 0.77     | -     | mg Cl2/L  |
| 09-Jun-25 | 2411552 | TFR002 | Franklin Final                    | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 09-Jun-25 | 2411552 | TFR002 | Franklin Final                    | Coliphages*     | 0        | ±8%   | PFU/10ml  |
| 09-Jun-25 | 2411551 | TFR002 | Franklin Final                    | Coll Time OS*   | 08:49    | -     | -         |
| 09-Jun-25 | 2411555 | TFR002 | Franklin Final                    | Conductivity    | 11.7     | ±1.5% | mS/m      |
| 09-Jun-25 | 2411552 | TFR002 | Franklin Final                    | E.coli*         | 0        | ±14%  | MPN/100mL |
| 09-Jun-25 | 2411552 | TFR002 | Franklin Final                    | HPC 37*         | 0        | ±21%  | cfu/mL    |
| 09-Jun-25 | 2411551 | TFR002 | Franklin Final                    | pH OS*          | 7.40     | -     | -         |
| 09-Jun-25 | 2411551 | TFR002 | Franklin Final                    | Temperature OS* | 11.9     | -     | °C        |
| 09-Jun-25 | 2411554 | TFR002 | Franklin Final                    | Turbidity       | 0.9      | ±6.1% | NTU       |
| 09-Jun-25 | 2411576 | TKK002 | Kokstad Final                     | Al (AE)         | <25.0    | ±7.6% | µg Al/L   |
| 09-Jun-25 | 2411571 | TKK002 | Kokstad Final                     | Batch No.*      | 20250201 | -     | -         |
| 09-Jun-25 | 2411571 | TKK002 | Kokstad Final                     | Cl2 (F) OS*     | 0.65     | -     | mg Cl2/L  |
| 09-Jun-25 | 2411571 | TKK002 | Kokstad Final                     | Cl2 (T) OS*     | 0.79     | -     | mg Cl2/L  |
| 09-Jun-25 | 2411572 | TKK002 | Kokstad Final                     | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 09-Jun-25 | 2411572 | TKK002 | Kokstad Final                     | Coliphages*     | 0        | ±8%   | PFU/10ml  |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

|           |         |         |                 |                 |          |       |           |
|-----------|---------|---------|-----------------|-----------------|----------|-------|-----------|
| 09-Jun-25 | 2411571 | TKK002  | Kokstad Final   | Coll Time OS*   | 07:40    | -     | -         |
| 09-Jun-25 | 2411575 | TKK002  | Kokstad Final   | Conductivity    | 12.5     | ±1.5% | mS/m      |
| 09-Jun-25 | 2411572 | TKK002  | Kokstad Final   | E.coli*         | 0        | ±14%  | MPN/100mL |
| 09-Jun-25 | 2411572 | TKK002  | Kokstad Final   | HPC 37*         | 0        | ±21%  | cfu/mL    |
| 09-Jun-25 | 2411571 | TKK002  | Kokstad Final   | pH OS*          | 7.50     | -     | -         |
| 09-Jun-25 | 2411571 | TKK002  | Kokstad Final   | Temperature OS* | 11.3     | -     | °C        |
| 09-Jun-25 | 2411574 | TKK002  | Kokstad Final   | Turbidity       | <0.2     | ±6.1% | NTU       |
| 11-Jun-25 | 2412734 | TBU002  | Bulwer Final    | Batch No.*      | 20250201 | -     | -         |
| 11-Jun-25 | 2412734 | TBU002  | Bulwer Final    | Cl2 (F) OS*     | 0.84     | -     | mg Cl2/L  |
| 11-Jun-25 | 2412734 | TBU002  | Bulwer Final    | Cl2 (T) OS*     | 0.99     | -     | mg Cl2/L  |
| 11-Jun-25 | 2412735 | TBU002  | Bulwer Final    | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 11-Jun-25 | 2412734 | TBU002  | Bulwer Final    | Coll Time OS*   | 10:27    | -     | -         |
| 11-Jun-25 | 2412738 | TBU002  | Bulwer Final    | Conductivity    | 5.42     | ±1.5% | mS/m      |
| 11-Jun-25 | 2412735 | TBU002  | Bulwer Final    | E.coli*         | 0        | ±14%  | MPN/100mL |
| 11-Jun-25 | 2412735 | TBU002  | Bulwer Final    | HPC 37*         | 28       | ±21%  | cfu/mL    |
| 11-Jun-25 | 2412734 | TBU002  | Bulwer Final    | pH OS*          | 7.60     | -     | -         |
| 11-Jun-25 | 2412734 | TBU002  | Bulwer Final    | Temperature OS* | 11.2     | -     | °C        |
| 11-Jun-25 | 2412737 | TBU002  | Bulwer Final    | Turbidity       | 10.2     | ±6.1% | NTU       |
| 11-Jun-25 | 2412778 | TMQA002 | Mqatsheni Final | Batch No.*      | 20250201 | -     | -         |
| 11-Jun-25 | 2412778 | TMQA002 | Mqatsheni Final | Cl2 (F) OS*     | 0.80     | -     | mg Cl2/L  |
| 11-Jun-25 | 2412778 | TMQA002 | Mqatsheni Final | Cl2 (T) OS*     | 0.95     | -     | mg Cl2/L  |
| 11-Jun-25 | 2412779 | TMQA002 | Mqatsheni Final | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 11-Jun-25 | 2412778 | TMQA002 | Mqatsheni Final | Coll Time OS*   | 10:05    | -     | -         |
| 11-Jun-25 | 2412782 | TMQA002 | Mqatsheni Final | Conductivity    | 26.8     | ±1.5% | mS/m      |
| 11-Jun-25 | 2412779 | TMQA002 | Mqatsheni Final | E.coli*         | 0        | ±14%  | MPN/100mL |
| 11-Jun-25 | 2412779 | TMQA002 | Mqatsheni Final | HPC 37*         | 0        | ±21%  | cfu/mL    |
| 11-Jun-25 | 2412778 | TMQA002 | Mqatsheni Final | pH OS*          | 9.00     | -     | -         |
| 11-Jun-25 | 2412778 | TMQA002 | Mqatsheni Final | Temperature OS* | 9.3      | -     | °C        |
| 11-Jun-25 | 2412781 | TMQA002 | Mqatsheni Final | Turbidity       | 0.6      | ±6.1% | NTU       |
| 11-Jun-25 | 2412793 | TRV002  | Riverside Final | Al (AE)         | 44.0     | ±7.6% | µg Al/L   |
| 11-Jun-25 | 2412788 | TRV002  | Riverside Final | Batch No.*      | 20250201 | -     | -         |
| 11-Jun-25 | 2412788 | TRV002  | Riverside Final | Cl2 (F) OS*     | 1.26     | -     | mg Cl2/L  |
| 11-Jun-25 | 2412788 | TRV002  | Riverside Final | Cl2 (T) OS*     | 1.32     | -     | mg Cl2/L  |
| 11-Jun-25 | 2412789 | TRV002  | Riverside Final | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 11-Jun-25 | 2412789 | TRV002  | Riverside Final | Coliphages*     | 0        | ±8%   | PFU/10ml  |
| 11-Jun-25 | 2412788 | TRV002  | Riverside Final | Coll Time OS*   | 08:59    | -     | -         |
| 11-Jun-25 | 2412792 | TRV002  | Riverside Final | Conductivity    | 17.6     | ±1.5% | mS/m      |
| 11-Jun-25 | 2412789 | TRV002  | Riverside Final | E.coli*         | 0        | ±14%  | MPN/100mL |
| 11-Jun-25 | 2412789 | TRV002  | Riverside Final | HPC 37*         | 0        | ±21%  | cfu/mL    |
| 11-Jun-25 | 2412788 | TRV002  | Riverside Final | pH OS*          | 7.60     | -     | -         |
| 11-Jun-25 | 2412788 | TRV002  | Riverside Final | Temperature OS* | 10.2     | -     | °C        |
| 11-Jun-25 | 2412791 | TRV002  | Riverside Final | Turbidity       | 1.4      | ±6.1% | NTU       |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

|           |         |        |                       |                 |          |       |           |
|-----------|---------|--------|-----------------------|-----------------|----------|-------|-----------|
| 11-Jun-25 | 2412804 | TST002 | St Appollinaris Final | Al (AE)         | 421      | ±7.6% | µg Al/L   |
| 11-Jun-25 | 2412799 | TST002 | St Appollinaris Final | Batch No.*      | 20250201 | -     | -         |
| 11-Jun-25 | 2412799 | TST002 | St Appollinaris Final | Cl2 (F) OS*     | 0.67     | -     | mg Cl2/L  |
| 11-Jun-25 | 2412799 | TST002 | St Appollinaris Final | Cl2 (T) OS*     | 0.89     | -     | mg Cl2/L  |
| 11-Jun-25 | 2412800 | TST002 | St Appollinaris Final | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 11-Jun-25 | 2412799 | TST002 | St Appollinaris Final | Coll Time OS*   | 09:36    | -     | -         |
| 11-Jun-25 | 2412803 | TST002 | St Appollinaris Final | Conductivity    | 9.15     | ±1.5% | mS/m      |
| 11-Jun-25 | 2412800 | TST002 | St Appollinaris Final | E.coli*         | 0        | ±14%  | MPN/100mL |
| 11-Jun-25 | 2412800 | TST002 | St Appollinaris Final | HPC 37*         | 0        | ±21%  | cfu/mL    |
| 11-Jun-25 | 2412799 | TST002 | St Appollinaris Final | pH OS*          | 7.40     | -     | -         |
| 11-Jun-25 | 2412799 | TST002 | St Appollinaris Final | Temperature OS* | 12.4     | -     | °C        |
| 11-Jun-25 | 2412802 | TST002 | St Appollinaris Final | Turbidity       | 6.4      | ±6.1% | NTU       |
| 11-Jun-25 | 2412815 | TUN002 | Underberg Final       | Al (AE)         | 41.2     | ±7.6% | µg Al/L   |
| 11-Jun-25 | 2412810 | TUN002 | Underberg Final       | Batch No.*      | 20250201 | -     | -         |
| 11-Jun-25 | 2412810 | TUN002 | Underberg Final       | Cl2 (F) OS*     | 0.17     | -     | mg Cl2/L  |
| 11-Jun-25 | 2412810 | TUN002 | Underberg Final       | Cl2 (T) OS*     | 0.30     | -     | mg Cl2/L  |
| 11-Jun-25 | 2412811 | TUN002 | Underberg Final       | Coliforms*      | 130      | ±15%  | MPN/100mL |
| 11-Jun-25 | 2412810 | TUN002 | Underberg Final       | Coll Time OS*   | 11:11    | -     | -         |
| 11-Jun-25 | 2412814 | TUN002 | Underberg Final       | Conductivity    | 7.02     | ±1.5% | mS/m      |
| 11-Jun-25 | 2412811 | TUN002 | Underberg Final       | E.coli*         | 43       | ±14%  | MPN/100mL |
| 11-Jun-25 | 2412811 | TUN002 | Underberg Final       | HPC 37*         | 54       | ±21%  | cfu/mL    |
| 11-Jun-25 | 2412810 | TUN002 | Underberg Final       | pH OS*          | 7.20     | -     | -         |
| 11-Jun-25 | 2412810 | TUN002 | Underberg Final       | Temperature OS* | 12.1     | -     | °C        |
| 11-Jun-25 | 2412813 | TUN002 | Underberg Final       | Turbidity       | 0.8      | ±6.1% | NTU       |
| 12-Jun-25 | 2413478 | TMZ002 | Umzimkhulu Final      | Al (AE)         | 722      | ±7.6% | µg Al/L   |
| 12-Jun-25 | 2413471 | TMZ002 | Umzimkhulu Final      | Batch No.*      | 20250201 | -     | -         |
| 12-Jun-25 | 2413471 | TMZ002 | Umzimkhulu Final      | Cl2 (F) OS*     | 2.50     | -     | mg Cl2/L  |
| 12-Jun-25 | 2413471 | TMZ002 | Umzimkhulu Final      | Cl2 (T) OS*     | 3.50     | -     | mg Cl2/L  |
| 12-Jun-25 | 2413472 | TMZ002 | Umzimkhulu Final      | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 12-Jun-25 | 2413472 | TMZ002 | Umzimkhulu Final      | Coliphages*     | 0        | ±8%   | PFU/10ml  |
| 12-Jun-25 | 2413471 | TMZ002 | Umzimkhulu Final      | Coll Time OS*   | 10:22    | -     | -         |
| 12-Jun-25 | 2413477 | TMZ002 | Umzimkhulu Final      | Conductivity    | 9.71     | ±1.5% | mS/m      |
| 12-Jun-25 | 2413472 | TMZ002 | Umzimkhulu Final      | E.coli*         | 0        | ±14%  | MPN/100mL |
| 12-Jun-25 | 2413478 | TMZ002 | Umzimkhulu Final      | Fe (AE)         | 0.28     | ±5.4% | mg Fe/L   |
| 12-Jun-25 | 2413472 | TMZ002 | Umzimkhulu Final      | HPC 37*         | 0        | ±21%  | cfu/mL    |
| 12-Jun-25 | 2413471 | TMZ002 | Umzimkhulu Final      | pH OS*          | 7.30     | -     | -         |
| 12-Jun-25 | 2413471 | TMZ002 | Umzimkhulu Final      | Temperature OS* | 14.5     | -     | °C        |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

|           |         |        |                           |                 |          |       |            |
|-----------|---------|--------|---------------------------|-----------------|----------|-------|------------|
| 12-Jun-25 | 2413475 | TMZ002 | Umzimkhulu Final          | Turbidity       | 11.8     | ±6.1% | NTU        |
| 12-Jun-25 | 2413489 | TNO002 | Nokweja Final             | Al (AE)         | 438      | ±7.6% | µg Al/L    |
| 12-Jun-25 | 2413484 | TNO002 | Nokweja Final             | Batch No.*      | 20250201 | -     | -          |
| 12-Jun-25 | 2413484 | TNO002 | Nokweja Final             | Cl2 (F) OS*     | 1.06     | -     | mg Cl2/L   |
| 12-Jun-25 | 2413484 | TNO002 | Nokweja Final             | Cl2 (T) OS*     | 1.10     | -     | mg Cl2/L   |
| 12-Jun-25 | 2413485 | TNO002 | Nokweja Final             | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 12-Jun-25 | 2413485 | TNO002 | Nokweja Final             | Coliphages*     | 0        | ±8%   | PFU/10ml   |
| 12-Jun-25 | 2413484 | TNO002 | Nokweja Final             | Coll Time OS*   | 08:50    | -     | -          |
| 12-Jun-25 | 2413488 | TNO002 | Nokweja Final             | Conductivity    | 11.9     | ±1.5% | mS/m       |
| 12-Jun-25 | 2413485 | TNO002 | Nokweja Final             | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 12-Jun-25 | 2413485 | TNO002 | Nokweja Final             | HPC 37*         | 91       | ±21%  | cfu/mL     |
| 12-Jun-25 | 2413484 | TNO002 | Nokweja Final             | pH OS*          | 7.60     | -     | -          |
| 12-Jun-25 | 2413484 | TNO002 | Nokweja Final             | Temperature OS* | 12.4     | -     | °C         |
| 12-Jun-25 | 2413487 | TNO002 | Nokweja Final             | Turbidity       | 23.1     | ±6.1% | NTU        |
| 12-Jun-25 | 2412209 | TQU002 | Mnqumeni Final            | Batch No.*      | 20250201 | -     | -          |
| 12-Jun-25 | 2412209 | TQU002 | Mnqumeni Final            | Cl2 (F) OS*     | 0.73     | -     | mg Cl2/L   |
| 12-Jun-25 | 2412209 | TQU002 | Mnqumeni Final            | Cl2 (T) OS*     | 0.84     | -     | mg Cl2/L   |
| 12-Jun-25 | 2412210 | TQU002 | Mnqumeni Final            | Coliforms*      | 1        | ±15%  | MPN/100mL  |
| 12-Jun-25 | 2412209 | TQU002 | Mnqumeni Final            | Coll Time OS*   | 07:49    | -     | -          |
| 12-Jun-25 | 2412210 | TQU002 | Mnqumeni Final            | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 12-Jun-25 | 2412210 | TQU002 | Mnqumeni Final            | HPC 37*         | 0        | ±21%  | cfu/mL     |
| 12-Jun-25 | 2412209 | TQU002 | Mnqumeni Final            | pH OS*          | 7.20     | -     | -          |
| 12-Jun-25 | 2412209 | TQU002 | Mnqumeni Final            | Temperature OS* | 12.6     | -     | °C         |
| 12-Jun-25 | 2412212 | TQU002 | Mnqumeni Final            | Turbidity       | 0.6      | ±6.1% | NTU        |
| 17-Jun-25 | 2416499 | TSQ002 | Esiqanduleni Final        | Al (AE)         | 102      | ±7.6% | µg Al/L    |
| 17-Jun-25 | 2416494 | TSQ002 | Esiqanduleni Final        | Batch No.*      | 20250201 | -     | -          |
| 17-Jun-25 | 2416494 | TSQ002 | Esiqanduleni Final        | Cl2 (F) OS*     | 1.35     | -     | mg Cl2/L   |
| 17-Jun-25 | 2416494 | TSQ002 | Esiqanduleni Final        | Cl2 (T) OS*     | 1.47     | -     | mg Cl2/L   |
| 17-Jun-25 | 2416495 | TSQ002 | Esiqanduleni Final        | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 17-Jun-25 | 2416494 | TSQ002 | Esiqanduleni Final        | Coll Time OS*   | 07:11    | -     | -          |
| 17-Jun-25 | 2416497 | TSQ002 | Esiqanduleni Final        | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 17-Jun-25 | 2416498 | TSQ002 | Esiqanduleni Final        | Conductivity    | 17.6     | ±1.5% | mS/m       |
| 17-Jun-25 | 2416495 | TSQ002 | Esiqanduleni Final        | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 17-Jun-25 | 2416495 | TSQ002 | Esiqanduleni Final        | HPC 37*         | 1        | ±21%  | cfu/mL     |
| 17-Jun-25 | 2416497 | TSQ002 | Esiqanduleni Final        | Odour*          | Nil      | -     | -          |
| 17-Jun-25 | 2416494 | TSQ002 | Esiqanduleni Final        | pH OS*          | 7.50     | -     | -          |
| 17-Jun-25 | 2416494 | TSQ002 | Esiqanduleni Final        | Temperature OS* | 17.6     | -     | °C         |
| 17-Jun-25 | 2416497 | TSQ002 | Esiqanduleni Final        | Turbidity       | 1.1      | ±6.1% | NTU        |
| 17-Jun-25 | 2416500 | TSQ003 | Esiqanduleni Reticulation | Batch No.*      | 20250201 | -     | -          |
| 17-Jun-25 | 2416500 | TSQ003 | Esiqanduleni Reticulation | Cl2 (F) OS*     | 1.74     | -     | mg Cl2/L   |
| 17-Jun-25 | 2416500 | TSQ003 | Esiqanduleni Reticulation | Cl2 (T) OS*     | 1.86     | -     | mg Cl2/L   |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

|           |         |        |                                  |                 |          |       |            |
|-----------|---------|--------|----------------------------------|-----------------|----------|-------|------------|
| 17-Jun-25 | 2416501 | TSQ003 | Esiganduleni Reticulation        | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 17-Jun-25 | 2416500 | TSQ003 | Esiganduleni Reticulation        | Coll Time OS*   | 07:30    | -     | -          |
| 17-Jun-25 | 2416501 | TSQ003 | Esiganduleni Reticulation        | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 17-Jun-25 | 2416501 | TSQ003 | Esiganduleni Reticulation        | HPC 37*         | 1        | ±21%  | cfu/mL     |
| 17-Jun-25 | 2416500 | TSQ003 | Esiganduleni Reticulation        | pH OS*          | 7.30     | -     | -          |
| 17-Jun-25 | 2416500 | TSQ003 | Esiganduleni Reticulation        | Temperature OS* | 16.1     | -     | °C         |
| 17-Jun-25 | 2416503 | TSQ003 | Esiganduleni Reticulation        | Turbidity       | 12.9     | ±6.1% | NTU        |
| 18-Jun-25 | 2417100 | TBU002 | Bulwer Final                     | Batch No.*      | 20250201 | -     | -          |
| 18-Jun-25 | 2417100 | TBU002 | Bulwer Final                     | Cl2 (F) OS*     | 0.46     | -     | mg Cl2/L   |
| 18-Jun-25 | 2417100 | TBU002 | Bulwer Final                     | Cl2 (T) OS*     | 0.61     | -     | mg Cl2/L   |
| 18-Jun-25 | 2417101 | TBU002 | Bulwer Final                     | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 18-Jun-25 | 2417100 | TBU002 | Bulwer Final                     | Coll Time OS*   | 09:20    | -     | -          |
| 18-Jun-25 | 2417103 | TBU002 | Bulwer Final                     | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 18-Jun-25 | 2417104 | TBU002 | Bulwer Final                     | Conductivity    | 5.53     | ±1.5% | mS/m       |
| 18-Jun-25 | 2417101 | TBU002 | Bulwer Final                     | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 18-Jun-25 | 2417101 | TBU002 | Bulwer Final                     | HPC 37*         | 3        | ±21%  | cfu/mL     |
| 18-Jun-25 | 2417103 | TBU002 | Bulwer Final                     | Odour*          | Nil      | -     | -          |
| 18-Jun-25 | 2417100 | TBU002 | Bulwer Final                     | pH OS*          | 7.20     | -     | -          |
| 18-Jun-25 | 2417100 | TBU002 | Bulwer Final                     | Temperature OS* | 13.2     | -     | °C         |
| 18-Jun-25 | 2417103 | TBU002 | Bulwer Final                     | Turbidity       | 4.0      | ±6.1% | NTU        |
| 18-Jun-25 | 2417105 | TBU005 | Bulwer Mountain Park Hotel Retic | Batch No.*      | 20250201 | -     | -          |
| 18-Jun-25 | 2417105 | TBU005 | Bulwer Mountain Park Hotel Retic | Cl2 (F) OS*     | 1.26     | -     | mg Cl2/L   |
| 18-Jun-25 | 2417105 | TBU005 | Bulwer Mountain Park Hotel Retic | Cl2 (T) OS*     | 1.33     | -     | mg Cl2/L   |
| 18-Jun-25 | 2417106 | TBU005 | Bulwer Mountain Park Hotel Retic | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 18-Jun-25 | 2417105 | TBU005 | Bulwer Mountain Park Hotel Retic | Coll Time OS*   | 09:30    | -     | -          |
| 18-Jun-25 | 2417106 | TBU005 | Bulwer Mountain Park Hotel Retic | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 18-Jun-25 | 2417106 | TBU005 | Bulwer Mountain Park Hotel Retic | HPC 37*         | 0        | ±21%  | cfu/mL     |
| 18-Jun-25 | 2417105 | TBU005 | Bulwer Mountain Park Hotel Retic | pH OS*          | 7.20     | -     | -          |
| 18-Jun-25 | 2417105 | TBU005 | Bulwer Mountain Park Hotel Retic | Temperature OS* | 13.4     | -     | °C         |
| 18-Jun-25 | 2417108 | TBU005 | Bulwer Mountain Park Hotel Retic | Turbidity       | 3.7      | ±6.1% | NTU        |
| 18-Jun-25 | 2417119 | TCR002 | Creighton Final                  | Al (AE)         | 191      | ±7.6% | µg Al/L    |
| 18-Jun-25 | 2417114 | TCR002 | Creighton Final                  | Batch No.*      | 20250201 | -     | -          |
| 18-Jun-25 | 2417114 | TCR002 | Creighton Final                  | Cl2 (F) OS*     | 1.19     | -     | mg Cl2/L   |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

|           |         |        |                                |                         |          |       |                       |
|-----------|---------|--------|--------------------------------|-------------------------|----------|-------|-----------------------|
| 18-Jun-25 | 2417114 | TCR002 | Creighton Final                | Cl <sub>2</sub> (T) OS* | 1.31     | -     | mg Cl <sub>2</sub> /L |
| 18-Jun-25 | 2417115 | TCR002 | Creighton Final                | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 18-Jun-25 | 2417114 | TCR002 | Creighton Final                | Coll Time OS*           | 07:40    | -     | -                     |
| 18-Jun-25 | 2417118 | TCR002 | Creighton Final                | Conductivity            | 9.34     | ±1.5% | mS/m                  |
| 18-Jun-25 | 2417115 | TCR002 | Creighton Final                | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 18-Jun-25 | 2417115 | TCR002 | Creighton Final                | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 18-Jun-25 | 2417114 | TCR002 | Creighton Final                | pH OS*                  | 7.30     | -     | -                     |
| 18-Jun-25 | 2417114 | TCR002 | Creighton Final                | Temperature OS*         | 11.8     | -     | °C                    |
| 18-Jun-25 | 2417117 | TCR002 | Creighton Final                | Turbidity               | 0.5      | ±6.1% | NTU                   |
| 18-Jun-25 | 2417120 | TCR004 | Creighton Madondo Cottages     | Batch No.*              | 20250201 | -     | -                     |
| 18-Jun-25 | 2417120 | TCR004 | Creighton Madondo Cottages     | Cl <sub>2</sub> (F) OS* | 0.72     | -     | mg Cl <sub>2</sub> /L |
| 18-Jun-25 | 2417120 | TCR004 | Creighton Madondo Cottages     | Cl <sub>2</sub> (T) OS* | 0.90     | -     | mg Cl <sub>2</sub> /L |
| 18-Jun-25 | 2417121 | TCR004 | Creighton Madondo Cottages     | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 18-Jun-25 | 2417120 | TCR004 | Creighton Madondo Cottages     | Coll Time OS*           | 07:28    | -     | -                     |
| 18-Jun-25 | 2417121 | TCR004 | Creighton Madondo Cottages     | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 18-Jun-25 | 2417121 | TCR004 | Creighton Madondo Cottages     | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 18-Jun-25 | 2417120 | TCR004 | Creighton Madondo Cottages     | pH OS*                  | 7.20     | -     | -                     |
| 18-Jun-25 | 2417120 | TCR004 | Creighton Madondo Cottages     | Temperature OS*         | 11.1     | -     | °C                    |
| 18-Jun-25 | 2417123 | TCR004 | Creighton Madondo Cottages     | Turbidity               | 0.4      | ±6.1% | NTU                   |
| 18-Jun-25 | 2417138 | THL003 | Hlanganani Clinic Reticulation | Batch No.*              | 20250201 | -     | -                     |
| 18-Jun-25 | 2417138 | THL003 | Hlanganani Clinic Reticulation | Cl <sub>2</sub> (F) OS* | 1.04     | -     | mg Cl <sub>2</sub> /L |
| 18-Jun-25 | 2417138 | THL003 | Hlanganani Clinic Reticulation | Cl <sub>2</sub> (T) OS* | 1.13     | -     | mg Cl <sub>2</sub> /L |
| 18-Jun-25 | 2417139 | THL003 | Hlanganani Clinic Reticulation | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 18-Jun-25 | 2417138 | THL003 | Hlanganani Clinic Reticulation | Coll Time OS*           | 10:00    | -     | -                     |
| 18-Jun-25 | 2417139 | THL003 | Hlanganani Clinic Reticulation | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 18-Jun-25 | 2417139 | THL003 | Hlanganani Clinic Reticulation | HPC 37*                 | 1        | ±21%  | cfu/mL                |
| 18-Jun-25 | 2417138 | THL003 | Hlanganani Clinic Reticulation | pH OS*                  | 7.40     | -     | -                     |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

|           |         |         |                                |                 |          |       |            |
|-----------|---------|---------|--------------------------------|-----------------|----------|-------|------------|
| 18-Jun-25 | 2417138 | THL003  | Hlanganani Clinic Reticulation | Temperature OS* | 15.2     | -     | °C         |
| 18-Jun-25 | 2417141 | THL003  | Hlanganani Clinic Reticulation | Turbidity       | <0.2     | ±6.1% | NTU        |
| 18-Jun-25 | 2417164 | TMQA002 | Mqatsheni Final                | Batch No.*      | 20250201 | -     | -          |
| 18-Jun-25 | 2417164 | TMQA002 | Mqatsheni Final                | Cl2 (F) OS*     | 1.80     | -     | mg Cl2/L   |
| 18-Jun-25 | 2417164 | TMQA002 | Mqatsheni Final                | Cl2 (T) OS*     | 1.92     | -     | mg Cl2/L   |
| 18-Jun-25 | 2417165 | TMQA002 | Mqatsheni Final                | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 18-Jun-25 | 2417164 | TMQA002 | Mqatsheni Final                | Coll Time OS*   | 10:09    | -     | -          |
| 18-Jun-25 | 2417167 | TMQA002 | Mqatsheni Final                | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 18-Jun-25 | 2417168 | TMQA002 | Mqatsheni Final                | Conductivity    | 26.8     | ±1.5% | mS/m       |
| 18-Jun-25 | 2417165 | TMQA002 | Mqatsheni Final                | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 18-Jun-25 | 2417165 | TMQA002 | Mqatsheni Final                | HPC 37*         | 2        | ±21%  | cfu/mL     |
| 18-Jun-25 | 2417167 | TMQA002 | Mqatsheni Final                | Odour*          | Nil      | -     | -          |
| 18-Jun-25 | 2417164 | TMQA002 | Mqatsheni Final                | pH OS*          | 8.80     | -     | -          |
| 18-Jun-25 | 2417167 | TMQA002 | Mqatsheni Final                | Taste*          | Nil      | -     | -          |
| 18-Jun-25 | 2417164 | TMQA002 | Mqatsheni Final                | Temperature OS* | 12.2     | -     | °C         |
| 18-Jun-25 | 2417167 | TMQA002 | Mqatsheni Final                | Turbidity       | 0.3      | ±6.1% | NTU        |
| 18-Jun-25 | 2417169 | TMQA003 | Mqatsheni Reticulation         | Batch No.*      | 20250201 | -     | -          |
| 18-Jun-25 | 2417169 | TMQA003 | Mqatsheni Reticulation         | Cl2 (F) OS*     | 0.73     | -     | mg Cl2/L   |
| 18-Jun-25 | 2417169 | TMQA003 | Mqatsheni Reticulation         | Cl2 (T) OS*     | 0.88     | -     | mg Cl2/L   |
| 18-Jun-25 | 2417170 | TMQA003 | Mqatsheni Reticulation         | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 18-Jun-25 | 2417169 | TMQA003 | Mqatsheni Reticulation         | Coll Time OS*   | 10:07    | -     | -          |
| 18-Jun-25 | 2417170 | TMQA003 | Mqatsheni Reticulation         | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 18-Jun-25 | 2417170 | TMQA003 | Mqatsheni Reticulation         | HPC 37*         | 0        | ±21%  | cfu/mL     |
| 18-Jun-25 | 2417169 | TMQA003 | Mqatsheni Reticulation         | pH OS*          | 8.20     | -     | -          |
| 18-Jun-25 | 2417169 | TMQA003 | Mqatsheni Reticulation         | Temperature OS* | 16.0     | -     | °C         |
| 18-Jun-25 | 2417172 | TMQA003 | Mqatsheni Reticulation         | Turbidity       | 0.5      | ±6.1% | NTU        |
| 18-Jun-25 | 2417198 | TST002  | St Appollinaris Final          | Al (AE)         | 162      | ±7.6% | µg Al/L    |
| 18-Jun-25 | 2417193 | TST002  | St Appollinaris Final          | Batch No.*      | 20250201 | -     | -          |
| 18-Jun-25 | 2417193 | TST002  | St Appollinaris Final          | Cl2 (F) OS*     | 0.70     | -     | mg Cl2/L   |
| 18-Jun-25 | 2417193 | TST002  | St Appollinaris Final          | Cl2 (T) OS*     | 0.80     | -     | mg Cl2/L   |
| 18-Jun-25 | 2417194 | TST002  | St Appollinaris Final          | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 18-Jun-25 | 2417193 | TST002  | St Appollinaris Final          | Coll Time OS*   | 08:48    | -     | -          |
| 18-Jun-25 | 2417196 | TST002  | St Appollinaris Final          | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 18-Jun-25 | 2417197 | TST002  | St Appollinaris Final          | Conductivity    | 10.0     | ±1.5% | mS/m       |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

|           |         |        |                                     |                         |          |       |                       |
|-----------|---------|--------|-------------------------------------|-------------------------|----------|-------|-----------------------|
| 18-Jun-25 | 2417194 | TST002 | St Appollinaris Final               | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 18-Jun-25 | 2417194 | TST002 | St Appollinaris Final               | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 18-Jun-25 | 2417196 | TST002 | St Appollinaris Final               | Odour*                  | Nil      | -     | -                     |
| 18-Jun-25 | 2417193 | TST002 | St Appollinaris Final               | pH OS*                  | 7.30     | -     | -                     |
| 18-Jun-25 | 2417193 | TST002 | St Appollinaris Final               | Temperature OS*         | 12.3     | -     | °C                    |
| 18-Jun-25 | 2417196 | TST002 | St Appollinaris Final               | Turbidity               | 2.4      | ±6.1% | NTU                   |
| 18-Jun-25 | 2417209 | TUN002 | Underberg Final                     | Al (AE)                 | 53.6     | ±7.6% | µg Al/L               |
| 18-Jun-25 | 2417204 | TUN002 | Underberg Final                     | Batch No.*              | 20250201 | -     | -                     |
| 18-Jun-25 | 2417204 | TUN002 | Underberg Final                     | Cl <sub>2</sub> (F) OS* | <0.05    | -     | mg Cl <sub>2</sub> /L |
| 18-Jun-25 | 2417204 | TUN002 | Underberg Final                     | Cl <sub>2</sub> (T) OS* | 0.05     | -     | mg Cl <sub>2</sub> /L |
| 18-Jun-25 | 2417205 | TUN002 | Underberg Final                     | Coliforms*              | 59       | ±15%  | MPN/100mL             |
| 18-Jun-25 | 2417204 | TUN002 | Underberg Final                     | Coll Time OS*           | 08:23    | -     | -                     |
| 18-Jun-25 | 2417207 | TUN002 | Underberg Final                     | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 18-Jun-25 | 2417208 | TUN002 | Underberg Final                     | Conductivity            | 6.79     | ±1.5% | mS/m                  |
| 18-Jun-25 | 2417205 | TUN002 | Underberg Final                     | E.coli*                 | 18       | ±14%  | MPN/100mL             |
| 18-Jun-25 | 2417205 | TUN002 | Underberg Final                     | HPC 37*                 | 48       | ±21%  | cfu/mL                |
| 18-Jun-25 | 2417207 | TUN002 | Underberg Final                     | Odour*                  | Nil      | -     | -                     |
| 18-Jun-25 | 2417204 | TUN002 | Underberg Final                     | pH OS*                  | 7.40     | -     | -                     |
| 18-Jun-25 | 2417204 | TUN002 | Underberg Final                     | Temperature OS*         | 11.0     | -     | °C                    |
| 18-Jun-25 | 2417207 | TUN002 | Underberg Final                     | Turbidity               | 0.9      | ±6.1% | NTU                   |
| 19-Jun-25 | 2417828 | TMZ002 | Umzimkhulu Final                    | Al (AE)                 | 464      | ±7.6% | µg Al/L               |
| 19-Jun-25 | 2417823 | TMZ002 | Umzimkhulu Final                    | Batch No.*              | 20250201 | -     | -                     |
| 19-Jun-25 | 2417823 | TMZ002 | Umzimkhulu Final                    | Cl <sub>2</sub> (F) OS* | 0.62     | -     | mg Cl <sub>2</sub> /L |
| 19-Jun-25 | 2417823 | TMZ002 | Umzimkhulu Final                    | Cl <sub>2</sub> (T) OS* | 0.72     | -     | mg Cl <sub>2</sub> /L |
| 19-Jun-25 | 2417824 | TMZ002 | Umzimkhulu Final                    | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 19-Jun-25 | 2417824 | TMZ002 | Umzimkhulu Final                    | Coliphages*             | 0        | ±8%   | PFU/10ml              |
| 19-Jun-25 | 2417823 | TMZ002 | Umzimkhulu Final                    | Coll Time OS*           | 08:32    | -     | -                     |
| 19-Jun-25 | 2417826 | TMZ002 | Umzimkhulu Final                    | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 19-Jun-25 | 2417827 | TMZ002 | Umzimkhulu Final                    | Conductivity            | 10.2     | ±1.5% | mS/m                  |
| 19-Jun-25 | 2417824 | TMZ002 | Umzimkhulu Final                    | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 19-Jun-25 | 2417824 | TMZ002 | Umzimkhulu Final                    | HPC 37*                 | 1        | ±21%  | cfu/mL                |
| 19-Jun-25 | 2417826 | TMZ002 | Umzimkhulu Final                    | Odour*                  | Nil      | -     | -                     |
| 19-Jun-25 | 2417823 | TMZ002 | Umzimkhulu Final                    | pH OS*                  | 7.30     | -     | -                     |
| 19-Jun-25 | 2417823 | TMZ002 | Umzimkhulu Final                    | Temperature OS*         | 13.3     | -     | °C                    |
| 19-Jun-25 | 2417826 | TMZ002 | Umzimkhulu Final                    | Turbidity               | 3.3      | ±6.1% | NTU                   |
| 19-Jun-25 | 2417829 | TMZ004 | Umzikhulu Informal Settlement Retic | Batch No.*              | 20250201 | -     | -                     |
| 19-Jun-25 | 2417829 | TMZ004 | Umzikhulu Informal Settlement Retic | Cl <sub>2</sub> (F) OS* | 0.42     | -     | mg Cl <sub>2</sub> /L |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

|           |         |        |                                       |                         |          |       |                       |
|-----------|---------|--------|---------------------------------------|-------------------------|----------|-------|-----------------------|
| 19-Jun-25 | 2417829 | TMZ004 | Umzikhulu Informal Settlement Retic   | Cl <sub>2</sub> (T) OS* | 0.70     | -     | mg Cl <sub>2</sub> /L |
| 19-Jun-25 | 2417830 | TMZ004 | Umzikhulu Informal Settlement Retic   | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 19-Jun-25 | 2417829 | TMZ004 | Umzikhulu Informal Settlement Retic   | Coll Time OS*           | 08:45    | -     | -                     |
| 19-Jun-25 | 2417832 | TMZ004 | Umzikhulu Informal Settlement Retic   | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 19-Jun-25 | 2417833 | TMZ004 | Umzikhulu Informal Settlement Retic   | Conductivity            | 10.2     | ±1.5% | mS/m                  |
| 19-Jun-25 | 2417830 | TMZ004 | Umzikhulu Informal Settlement Retic   | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 19-Jun-25 | 2417830 | TMZ004 | Umzikhulu Informal Settlement Retic   | HPC 37*                 | 3        | ±21%  | cfu/mL                |
| 19-Jun-25 | 2417832 | TMZ004 | Umzikhulu Informal Settlement Retic   | Odour*                  | Nil      | -     | -                     |
| 19-Jun-25 | 2417829 | TMZ004 | Umzikhulu Informal Settlement Retic   | pH OS*                  | 7.30     | -     | -                     |
| 19-Jun-25 | 2417829 | TMZ004 | Umzikhulu Informal Settlement Retic   | Temperature OS*         | 13.5     | -     | °C                    |
| 19-Jun-25 | 2417832 | TMZ004 | Umzikhulu Informal Settlement Retic   | Turbidity               | 3.5      | ±6.1% | NTU                   |
| 19-Jun-25 | 2417834 | TMZ005 | Umzimkhulu Local Municipality Offices | Batch No.*              | 20250201 | -     | -                     |
| 19-Jun-25 | 2417834 | TMZ005 | Umzimkhulu Local Municipality Offices | Cl <sub>2</sub> (F) OS* | 0.80     | -     | mg Cl <sub>2</sub> /L |
| 19-Jun-25 | 2417834 | TMZ005 | Umzimkhulu Local Municipality Offices | Cl <sub>2</sub> (T) OS* | 0.92     | -     | mg Cl <sub>2</sub> /L |
| 19-Jun-25 | 2417835 | TMZ005 | Umzimkhulu Local Municipality Offices | Coliforms*              | 6        | ±15%  | MPN/100mL             |
| 19-Jun-25 | 2417834 | TMZ005 | Umzimkhulu Local Municipality Offices | Coll Time OS*           | 09:15    | -     | -                     |
| 19-Jun-25 | 2417837 | TMZ005 | Umzimkhulu Local Municipality Offices | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 19-Jun-25 | 2417838 | TMZ005 | Umzimkhulu Local Municipality Offices | Conductivity            | 10.2     | ±1.5% | mS/m                  |
| 19-Jun-25 | 2417835 | TMZ005 | Umzimkhulu Local Municipality Offices | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 19-Jun-25 | 2417835 | TMZ005 | Umzimkhulu Local Municipality Offices | HPC 37*                 | 2        | ±21%  | cfu/mL                |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

|           |         |        |                                           |                         |          |       |                       |
|-----------|---------|--------|-------------------------------------------|-------------------------|----------|-------|-----------------------|
| 19-Jun-25 | 2417834 | TMZ005 | Umzimkhulu Local Municipality Offices     | pH OS*                  | 7.20     | -     | -                     |
| 19-Jun-25 | 2417834 | TMZ005 | Umzimkhulu Local Municipality Offices     | Temperature OS*         | 14.2     | -     | °C                    |
| 19-Jun-25 | 2417837 | TMZ005 | Umzimkhulu Local Municipality Offices     | Turbidity               | 4.0      | ±6.1% | NTU                   |
| 19-Jun-25 | 2417839 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | Batch No.*              | 20250201 | -     | -                     |
| 19-Jun-25 | 2417839 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | Cl <sub>2</sub> (F) OS* | 0.52     | -     | mg Cl <sub>2</sub> /L |
| 19-Jun-25 | 2417839 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | Cl <sub>2</sub> (T) OS* | 0.60     | -     | mg Cl <sub>2</sub> /L |
| 19-Jun-25 | 2417840 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 19-Jun-25 | 2417839 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | Coll Time OS*           | 08:15    | -     | -                     |
| 19-Jun-25 | 2417842 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 19-Jun-25 | 2417843 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | Conductivity            | 10.2     | ±1.5% | mS/m                  |
| 19-Jun-25 | 2417840 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 19-Jun-25 | 2417840 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 19-Jun-25 | 2417839 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | pH OS*                  | 7.20     | -     | -                     |
| 19-Jun-25 | 2417839 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | Temperature OS*         | 13.1     | -     | °C                    |
| 19-Jun-25 | 2417842 | TMZ006 | Umzimkhulu Mbizweni Hospital Reticulation | Turbidity               | 3.4      | ±6.1% | NTU                   |
| 19-Jun-25 | 2417844 | TMZ007 | Umzimkhulu Local FET College              | Batch No.*              | 20250201 | -     | -                     |
| 19-Jun-25 | 2417844 | TMZ007 | Umzimkhulu Local FET College              | Cl <sub>2</sub> (F) OS* | 0.38     | -     | mg Cl <sub>2</sub> /L |
| 19-Jun-25 | 2417844 | TMZ007 | Umzimkhulu Local FET College              | Cl <sub>2</sub> (T) OS* | 0.46     | -     | mg Cl <sub>2</sub> /L |
| 19-Jun-25 | 2417845 | TMZ007 | Umzimkhulu Local FET College              | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 19-Jun-25 | 2417844 | TMZ007 | Umzimkhulu Local FET College              | Coll Time OS*           | 07:59    | -     | -                     |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

|           |         |        |                              |                         |          |       |                       |
|-----------|---------|--------|------------------------------|-------------------------|----------|-------|-----------------------|
| 19-Jun-25 | 2417847 | TMZ007 | Umzimkhulu Local FET College | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 19-Jun-25 | 2417848 | TMZ007 | Umzimkhulu Local FET College | Conductivity            | 11.1     | ±1.5% | mS/m                  |
| 19-Jun-25 | 2417845 | TMZ007 | Umzimkhulu Local FET College | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 19-Jun-25 | 2417845 | TMZ007 | Umzimkhulu Local FET College | HPC 37*                 | 9        | ±21%  | cfu/mL                |
| 19-Jun-25 | 2417844 | TMZ007 | Umzimkhulu Local FET College | pH OS*                  | 7.30     | -     | -                     |
| 19-Jun-25 | 2417844 | TMZ007 | Umzimkhulu Local FET College | Temperature OS*         | 16.1     | -     | °C                    |
| 19-Jun-25 | 2417847 | TMZ007 | Umzimkhulu Local FET College | Turbidity               | 5.7      | ±6.1% | NTU                   |
| 19-Jun-25 | 2417859 | TNO002 | Nokweja Final                | Al (AE)                 | <25.0    | ±7.6% | µg Al/L               |
| 19-Jun-25 | 2417854 | TNO002 | Nokweja Final                | Batch No.*              | 20250201 | -     | -                     |
| 19-Jun-25 | 2417854 | TNO002 | Nokweja Final                | Cl <sub>2</sub> (F) OS* | 1.53     | -     | mg Cl <sub>2</sub> /L |
| 19-Jun-25 | 2417854 | TNO002 | Nokweja Final                | Cl <sub>2</sub> (T) OS* | 1.70     | -     | mg Cl <sub>2</sub> /L |
| 19-Jun-25 | 2417855 | TNO002 | Nokweja Final                | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 19-Jun-25 | 2417855 | TNO002 | Nokweja Final                | Coliphages*             | 0        | ±8%   | PFU/10ml              |
| 19-Jun-25 | 2417854 | TNO002 | Nokweja Final                | Coll Time OS*           | 09:00    | -     | -                     |
| 19-Jun-25 | 2417857 | TNO002 | Nokweja Final                | Colour                  | <1.00    | ±6.5% | mg Pt-Co/L            |
| 19-Jun-25 | 2417858 | TNO002 | Nokweja Final                | Conductivity            | 11.4     | ±1.5% | mS/m                  |
| 19-Jun-25 | 2417855 | TNO002 | Nokweja Final                | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 19-Jun-25 | 2417855 | TNO002 | Nokweja Final                | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 19-Jun-25 | 2417857 | TNO002 | Nokweja Final                | Odour*                  | Nil      | -     | -                     |
| 19-Jun-25 | 2417854 | TNO002 | Nokweja Final                | pH OS*                  | 7.30     | -     | -                     |
| 19-Jun-25 | 2417857 | TNO002 | Nokweja Final                | Taste*                  | Nil      | -     | -                     |
| 19-Jun-25 | 2417854 | TNO002 | Nokweja Final                | Temperature OS*         | 16.4     | -     | °C                    |
| 19-Jun-25 | 2417857 | TNO002 | Nokweja Final                | Turbidity               | 0.3      | ±6.1% | NTU                   |
| 19-Jun-25 | 2417880 | TWA002 | Washbank Final               | Al (AE)                 | 515      | ±7.6% | µg Al/L               |
| 19-Jun-25 | 2417875 | TWA002 | Washbank Final               | Batch No.*              | 20250201 | -     | -                     |
| 19-Jun-25 | 2417875 | TWA002 | Washbank Final               | Cl <sub>2</sub> (F) OS* | 1.02     | -     | mg Cl <sub>2</sub> /L |
| 19-Jun-25 | 2417875 | TWA002 | Washbank Final               | Cl <sub>2</sub> (T) OS* | 1.09     | -     | mg Cl <sub>2</sub> /L |
| 19-Jun-25 | 2417876 | TWA002 | Washbank Final               | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 19-Jun-25 | 2417875 | TWA002 | Washbank Final               | Coll Time OS*           | 09:15    | -     | -                     |
| 19-Jun-25 | 2417878 | TWA002 | Washbank Final               | Colour                  | 5.50     | ±6.5% | mg Pt-Co/L            |
| 19-Jun-25 | 2417879 | TWA002 | Washbank Final               | Conductivity            | 8.62     | ±1.5% | mS/m                  |
| 19-Jun-25 | 2417876 | TWA002 | Washbank Final               | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 19-Jun-25 | 2417876 | TWA002 | Washbank Final               | HPC 37*                 | 2        | ±21%  | cfu/mL                |
| 19-Jun-25 | 2417878 | TWA002 | Washbank Final               | Odour*                  | Nil      | -     | -                     |
| 19-Jun-25 | 2417875 | TWA002 | Washbank Final               | pH OS*                  | 7.20     | -     | -                     |
| 19-Jun-25 | 2417875 | TWA002 | Washbank Final               | Temperature OS*         | 14.2     | -     | °C                    |
| 19-Jun-25 | 2417878 | TWA002 | Washbank Final               | Turbidity               | 6.1      | ±6.1% | NTU                   |
| 20-Jun-25 | 2416393 | TFR002 | Franklin Final               | Al (AE)                 | 207      | ±7.6% | µg Al/L               |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

|           |         |        |                               |                 |          |       |            |
|-----------|---------|--------|-------------------------------|-----------------|----------|-------|------------|
| 20-Jun-25 | 2416388 | TFR002 | Franklin Final                | Batch No.*      | 20250201 | -     | -          |
| 20-Jun-25 | 2416388 | TFR002 | Franklin Final                | Cl2 (F) OS*     | 0.45     | -     | mg Cl2/L   |
| 20-Jun-25 | 2416388 | TFR002 | Franklin Final                | Cl2 (T) OS*     | 0.58     | -     | mg Cl2/L   |
| 20-Jun-25 | 2416389 | TFR002 | Franklin Final                | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 20-Jun-25 | 2416389 | TFR002 | Franklin Final                | Coliphages*     | 0        | ±8%   | PFU/10ml   |
| 20-Jun-25 | 2416388 | TFR002 | Franklin Final                | Coll Time OS*   | 08:11    | -     | -          |
| 20-Jun-25 | 2416391 | TFR002 | Franklin Final                | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 20-Jun-25 | 2416392 | TFR002 | Franklin Final                | Conductivity    | 15.0     | ±1.5% | mS/m       |
| 20-Jun-25 | 2416389 | TFR002 | Franklin Final                | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 20-Jun-25 | 2416393 | TFR002 | Franklin Final                | Fe (AE)         | 0.08     | ±5.4% | mg Fe/L    |
| 20-Jun-25 | 2416389 | TFR002 | Franklin Final                | HPC 37*         | 0        | ±21%  | cfu/mL     |
| 20-Jun-25 | 2416393 | TFR002 | Franklin Final                | Mn (AE)         | <0.01    | ±6.2% | mg Mn/L    |
| 20-Jun-25 | 2416388 | TFR002 | Franklin Final                | pH OS*          | 7.10     | -     | -          |
| 20-Jun-25 | 2416388 | TFR002 | Franklin Final                | Temperature OS* | 9.2      | -     | °C         |
| 20-Jun-25 | 2416391 | TFR002 | Franklin Final                | Turbidity       | 1.3      | ±6.1% | NTU        |
| 20-Jun-25 | 2416394 | TFR003 | Franklin Police Station Retic | Batch No.*      | 20250201 | -     | -          |
| 20-Jun-25 | 2416394 | TFR003 | Franklin Police Station Retic | Cl2 (F) OS*     | 0.65     | -     | mg Cl2/L   |
| 20-Jun-25 | 2416394 | TFR003 | Franklin Police Station Retic | Cl2 (T) OS*     | 0.81     | -     | mg Cl2/L   |
| 20-Jun-25 | 2416395 | TFR003 | Franklin Police Station Retic | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 20-Jun-25 | 2416394 | TFR003 | Franklin Police Station Retic | Coll Time OS*   | 08:25    | -     | -          |
| 20-Jun-25 | 2416397 | TFR003 | Franklin Police Station Retic | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 20-Jun-25 | 2416398 | TFR003 | Franklin Police Station Retic | Conductivity    | 14.8     | ±1.5% | mS/m       |
| 20-Jun-25 | 2416395 | TFR003 | Franklin Police Station Retic | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 20-Jun-25 | 2416395 | TFR003 | Franklin Police Station Retic | HPC 37*         | 0        | ±21%  | cfu/mL     |
| 20-Jun-25 | 2416397 | TFR003 | Franklin Police Station Retic | Odour*          | Nil      | -     | -          |
| 20-Jun-25 | 2416394 | TFR003 | Franklin Police Station Retic | pH OS*          | 7.00     | -     | -          |
| 20-Jun-25 | 2416394 | TFR003 | Franklin Police Station Retic | Temperature OS* | 10.2     | -     | °C         |
| 20-Jun-25 | 2416397 | TFR003 | Franklin Police Station Retic | Turbidity       | 1.4      | ±6.1% | NTU        |
| 20-Jun-25 | 2418179 | TIB002 | Ibisi Final                   | Al (AE)         | 161      | ±7.6% | µg Al/L    |
| 20-Jun-25 | 2418174 | TIB002 | Ibisi Final                   | Batch No.*      | 20250201 | -     | -          |
| 20-Jun-25 | 2418174 | TIB002 | Ibisi Final                   | Cl2 (F) OS*     | 0.29     | -     | mg Cl2/L   |
| 20-Jun-25 | 2418174 | TIB002 | Ibisi Final                   | Cl2 (T) OS*     | 0.34     | -     | mg Cl2/L   |
| 20-Jun-25 | 2418175 | TIB002 | Ibisi Final                   | Coliforms*      | 5        | ±15%  | MPN/100mL  |
| 20-Jun-25 | 2418175 | TIB002 | Ibisi Final                   | Coliphages*     | 0        | ±8%   | PFU/10ml   |
| 20-Jun-25 | 2418174 | TIB002 | Ibisi Final                   | Coll Time OS*   | 07:00    | -     | -          |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

|           |         |        |                           |                 |          |       |            |
|-----------|---------|--------|---------------------------|-----------------|----------|-------|------------|
| 20-Jun-25 | 2418177 | TIB002 | Ibisi Final               | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 20-Jun-25 | 2418178 | TIB002 | Ibisi Final               | Conductivity    | 8.94     | ±1.5% | mS/m       |
| 20-Jun-25 | 2418175 | TIB002 | Ibisi Final               | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 20-Jun-25 | 2418175 | TIB002 | Ibisi Final               | HPC 37*         | 3        | ±21%  | cfu/mL     |
| 20-Jun-25 | 2418177 | TIB002 | Ibisi Final               | Odour*          | Nil      | -     | -          |
| 20-Jun-25 | 2418174 | TIB002 | Ibisi Final               | pH OS*          | 7.20     | -     | -          |
| 20-Jun-25 | 2418174 | TIB002 | Ibisi Final               | Temperature OS* | 10.1     | -     | °C         |
| 20-Jun-25 | 2418177 | TIB002 | Ibisi Final               | Turbidity       | 1.8      | ±6.1% | NTU        |
| 20-Jun-25 | 2416410 | TJO001 | Jolivet RRT frn Vulamehlo | Batch No.*      | 20250201 | -     | -          |
| 20-Jun-25 | 2416410 | TJO001 | Jolivet RRT frn Vulamehlo | Cl2 (F) OS*     | 0.50     | -     | mg Cl2/L   |
| 20-Jun-25 | 2416410 | TJO001 | Jolivet RRT frn Vulamehlo | Cl2 (T) OS*     | 0.80     | -     | mg Cl2/L   |
| 20-Jun-25 | 2416411 | TJO001 | Jolivet RRT frn Vulamehlo | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 20-Jun-25 | 2416410 | TJO001 | Jolivet RRT frn Vulamehlo | Coll Time OS*   | 11:15    | -     | -          |
| 20-Jun-25 | 2416413 | TJO001 | Jolivet RRT frn Vulamehlo | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 20-Jun-25 | 2416414 | TJO001 | Jolivet RRT frn Vulamehlo | Conductivity    | 15.9     | ±1.5% | mS/m       |
| 20-Jun-25 | 2416411 | TJO001 | Jolivet RRT frn Vulamehlo | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 20-Jun-25 | 2416411 | TJO001 | Jolivet RRT frn Vulamehlo | HPC 37*         | 5        | ±21%  | cfu/mL     |
| 20-Jun-25 | 2416413 | TJO001 | Jolivet RRT frn Vulamehlo | Odour*          | Nil      | -     | -          |
| 20-Jun-25 | 2416410 | TJO001 | Jolivet RRT frn Vulamehlo | pH OS*          | 7.50     | -     | -          |
| 20-Jun-25 | 2416410 | TJO001 | Jolivet RRT frn Vulamehlo | Temperature OS* | 14.8     | -     | °C         |
| 20-Jun-25 | 2416413 | TJO001 | Jolivet RRT frn Vulamehlo | Turbidity       | 3.9      | ±6.1% | NTU        |
| 20-Jun-25 | 2415835 | TKK002 | Kokstad Final             | Al (AE)         | 67.5     | ±7.6% | µg Al/L    |
| 20-Jun-25 | 2415830 | TKK002 | Kokstad Final             | Batch No.*      | 20250201 | -     | -          |
| 20-Jun-25 | 2415830 | TKK002 | Kokstad Final             | Cl2 (F) OS*     | 1.58     | -     | mg Cl2/L   |
| 20-Jun-25 | 2415830 | TKK002 | Kokstad Final             | Cl2 (T) OS*     | 1.72     | -     | mg Cl2/L   |
| 20-Jun-25 | 2415831 | TKK002 | Kokstad Final             | Coliforms*      | 0        | ±15%  | MPN/100mL  |
| 20-Jun-25 | 2415831 | TKK002 | Kokstad Final             | Coliphages*     | 0        | ±8%   | PFU/10ml   |
| 20-Jun-25 | 2415830 | TKK002 | Kokstad Final             | Coll Time OS*   | 08:50    | -     | -          |
| 20-Jun-25 | 2415833 | TKK002 | Kokstad Final             | Colour          | <1.00    | ±6.5% | mg Pt-Co/L |
| 20-Jun-25 | 2415834 | TKK002 | Kokstad Final             | Conductivity    | 8.13     | ±1.5% | mS/m       |
| 20-Jun-25 | 2415831 | TKK002 | Kokstad Final             | E.coli*         | 0        | ±14%  | MPN/100mL  |
| 20-Jun-25 | 2415831 | TKK002 | Kokstad Final             | HPC 37*         | 0        | ±21%  | cfu/mL     |
| 20-Jun-25 | 2415833 | TKK002 | Kokstad Final             | Odour*          | Nil      | -     | -          |
| 20-Jun-25 | 2415830 | TKK002 | Kokstad Final             | pH OS*          | 7.40     | -     | -          |
| 20-Jun-25 | 2415830 | TKK002 | Kokstad Final             | Temperature OS* | 14.6     | -     | °C         |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

|           |         |        |                                          |                 |          |       |           |
|-----------|---------|--------|------------------------------------------|-----------------|----------|-------|-----------|
| 20-Jun-25 | 2415833 | TKK002 | Kokstad Final                            | Turbidity       | 0.7      | ±6.1% | NTU       |
| 20-Jun-25 | 2415841 | TKK005 | Kokstad Khanyiselani Rectification       | Batch No.*      | 20250201 | -     | -         |
| 20-Jun-25 | 2415841 | TKK005 | Kokstad Khanyiselani Rectification       | Cl2 (F) OS*     | 1.04     | -     | mg Cl2/L  |
| 20-Jun-25 | 2415841 | TKK005 | Kokstad Khanyiselani Rectification       | Cl2 (T) OS*     | 1.11     | -     | mg Cl2/L  |
| 20-Jun-25 | 2415842 | TKK005 | Kokstad Khanyiselani Rectification       | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 20-Jun-25 | 2415841 | TKK005 | Kokstad Khanyiselani Rectification       | Coll Time OS*   | 09:25    | -     | -         |
| 20-Jun-25 | 2415842 | TKK005 | Kokstad Khanyiselani Rectification       | E.coli*         | 0        | ±14%  | MPN/100mL |
| 20-Jun-25 | 2415842 | TKK005 | Kokstad Khanyiselani Rectification       | HPC 37*         | 0        | ±21%  | cfu/mL    |
| 20-Jun-25 | 2415841 | TKK005 | Kokstad Khanyiselani Rectification       | pH OS*          | 7.40     | -     | -         |
| 20-Jun-25 | 2415841 | TKK005 | Kokstad Khanyiselani Rectification       | Temperature OS* | 16.3     | -     | °C        |
| 20-Jun-25 | 2415844 | TKK005 | Kokstad Khanyiselani Rectification       | Turbidity       | 0.4      | ±6.1% | NTU       |
| 20-Jun-25 | 2415845 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Batch No.*      | 20250201 | -     | -         |
| 20-Jun-25 | 2415845 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Cl2 (F) OS*     | 0.80     | -     | mg Cl2/L  |
| 20-Jun-25 | 2415845 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Cl2 (T) OS*     | 0.92     | -     | mg Cl2/L  |
| 20-Jun-25 | 2415846 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 20-Jun-25 | 2415845 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Coll Time OS*   | 08:35    | -     | -         |
| 20-Jun-25 | 2415846 | TKK006 | Kokstad Bongweni Correctional Serv Retic | E.coli*         | 0        | ±14%  | MPN/100mL |
| 20-Jun-25 | 2415846 | TKK006 | Kokstad Bongweni Correctional Serv Retic | HPC 37*         | 0        | ±21%  | cfu/mL    |
| 20-Jun-25 | 2415845 | TKK006 | Kokstad Bongweni Correctional Serv Retic | pH OS*          | 7.20     | -     | -         |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

|           |         |        |                                          |                         |          |       |                       |
|-----------|---------|--------|------------------------------------------|-------------------------|----------|-------|-----------------------|
| 20-Jun-25 | 2415845 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Temperature OS*         | 13.2     | -     | °C                    |
| 20-Jun-25 | 2415848 | TKK006 | Kokstad Bongweni Correctional Serv Retic | Turbidity               | 0.3      | ±6.1% | NTU                   |
| 20-Jun-25 | 2415849 | TKK007 | Kokstad Shayamoya Reticulation           | Batch No.*              | 20250201 | -     | -                     |
| 20-Jun-25 | 2415849 | TKK007 | Kokstad Shayamoya Reticulation           | Cl <sub>2</sub> (F) OS* | 0.70     | -     | mg Cl <sub>2</sub> /L |
| 20-Jun-25 | 2415849 | TKK007 | Kokstad Shayamoya Reticulation           | Cl <sub>2</sub> (T) OS* | 0.81     | -     | mg Cl <sub>2</sub> /L |
| 20-Jun-25 | 2415850 | TKK007 | Kokstad Shayamoya Reticulation           | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 20-Jun-25 | 2415849 | TKK007 | Kokstad Shayamoya Reticulation           | Coll Time OS*           | 09:15    | -     | -                     |
| 20-Jun-25 | 2415850 | TKK007 | Kokstad Shayamoya Reticulation           | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 20-Jun-25 | 2415850 | TKK007 | Kokstad Shayamoya Reticulation           | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 20-Jun-25 | 2415849 | TKK007 | Kokstad Shayamoya Reticulation           | pH OS*                  | 7.30     | -     | -                     |
| 20-Jun-25 | 2415849 | TKK007 | Kokstad Shayamoya Reticulation           | Temperature OS*         | 16.0     | -     | °C                    |
| 20-Jun-25 | 2415852 | TKK007 | Kokstad Shayamoya Reticulation           | Turbidity               | 0.4      | ±6.1% | NTU                   |
| 20-Jun-25 | 2415853 | TKK009 | Kokstad Farm Fresh Produce Market        | Batch No.*              | 20250201 | -     | -                     |
| 20-Jun-25 | 2415853 | TKK009 | Kokstad Farm Fresh Produce Market        | Cl <sub>2</sub> (F) OS* | 1.32     | -     | mg Cl <sub>2</sub> /L |
| 20-Jun-25 | 2415853 | TKK009 | Kokstad Farm Fresh Produce Market        | Cl <sub>2</sub> (T) OS* | 1.44     | -     | mg Cl <sub>2</sub> /L |
| 20-Jun-25 | 2415854 | TKK009 | Kokstad Farm Fresh Produce Market        | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 20-Jun-25 | 2415853 | TKK009 | Kokstad Farm Fresh Produce Market        | Coll Time OS*           | 09:40    | -     | -                     |
| 20-Jun-25 | 2415854 | TKK009 | Kokstad Farm Fresh Produce Market        | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 20-Jun-25 | 2415854 | TKK009 | Kokstad Farm Fresh Produce Market        | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 20-Jun-25 | 2415853 | TKK009 | Kokstad Farm Fresh Produce Market        | pH OS*                  | 7.30     | -     | -                     |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

|           |         |         |                                   |                 |          |       |           |
|-----------|---------|---------|-----------------------------------|-----------------|----------|-------|-----------|
| 20-Jun-25 | 2415853 | TKK009  | Kokstad Farm Fresh Produce Market | Temperature OS* | 16.8     | -     | °C        |
| 20-Jun-25 | 2415856 | TKK009  | Kokstad Farm Fresh Produce Market | Turbidity       | 0.3      | ±6.1% | NTU       |
| 20-Jun-25 | 2415857 | TKK012  | Kokstad FET College Reticulation  | Batch No.*      | 20250201 | -     | -         |
| 20-Jun-25 | 2415857 | TKK012  | Kokstad FET College Reticulation  | Cl2 (F) OS*     | 0.61     | -     | mg Cl2/L  |
| 20-Jun-25 | 2415857 | TKK012  | Kokstad FET College Reticulation  | Cl2 (T) OS*     | 0.72     | -     | mg Cl2/L  |
| 20-Jun-25 | 2415858 | TKK012  | Kokstad FET College Reticulation  | Coliforms*      | 2        | ±15%  | MPN/100mL |
| 20-Jun-25 | 2415857 | TKK012  | Kokstad FET College Reticulation  | Coll Time OS*   | 08:02    | -     | -         |
| 20-Jun-25 | 2415858 | TKK012  | Kokstad FET College Reticulation  | E.coli*         | 0        | ±14%  | MPN/100mL |
| 20-Jun-25 | 2415858 | TKK012  | Kokstad FET College Reticulation  | HPC 37*         | 0        | ±21%  | cfu/mL    |
| 20-Jun-25 | 2415857 | TKK012  | Kokstad FET College Reticulation  | pH OS*          | 7.30     | -     | -         |
| 20-Jun-25 | 2415857 | TKK012  | Kokstad FET College Reticulation  | Temperature OS* | 11.2     | -     | °C        |
| 20-Jun-25 | 2415860 | TKK012  | Kokstad FET College Reticulation  | Turbidity       | 0.3      | ±6.1% | NTU       |
| 20-Jun-25 | 2415888 | TNJU002 | KwaNjunga Final                   | Al (AE)         | 43.2     | ±7.6% | µg Al/L   |
| 20-Jun-25 | 2415883 | TNJU002 | KwaNjunga Final                   | Batch No.*      | 20250201 | -     | -         |
| 20-Jun-25 | 2415883 | TNJU002 | KwaNjunga Final                   | Cl2 (F) OS*     | 0.59     | -     | mg Cl2/L  |
| 20-Jun-25 | 2415883 | TNJU002 | KwaNjunga Final                   | Cl2 (T) OS*     | 1.08     | -     | mg Cl2/L  |
| 20-Jun-25 | 2415884 | TNJU002 | KwaNjunga Final                   | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 20-Jun-25 | 2415883 | TNJU002 | KwaNjunga Final                   | Coll Time OS*   | 07:12    | -     | -         |
| 20-Jun-25 | 2415887 | TNJU002 | KwaNjunga Final                   | Conductivity    | 15.9     | ±1.5% | mS/m      |
| 20-Jun-25 | 2415884 | TNJU002 | KwaNjunga Final                   | E.coli*         | 0        | ±14%  | MPN/100mL |
| 20-Jun-25 | 2415884 | TNJU002 | KwaNjunga Final                   | HPC 37*         | 0        | ±21%  | cfu/mL    |
| 20-Jun-25 | 2415883 | TNJU002 | KwaNjunga Final                   | pH OS*          | 7.20     | -     | -         |
| 20-Jun-25 | 2415883 | TNJU002 | KwaNjunga Final                   | Temperature OS* | 16.1     | -     | °C        |
| 20-Jun-25 | 2415886 | TNJU002 | KwaNjunga Final                   | Turbidity       | 0.7      | ±6.1% | NTU       |
| 23-Jun-25 | 2419854 | TFR002  | Franklin Final                    | Al (AE)         | 281      | ±7.6% | µg Al/L   |
| 23-Jun-25 | 2419849 | TFR002  | Franklin Final                    | Batch No.*      | 20250201 | -     | -         |
| 23-Jun-25 | 2419849 | TFR002  | Franklin Final                    | Cl2 (F) OS*     | 1.00     | -     | mg Cl2/L  |
| 23-Jun-25 | 2419849 | TFR002  | Franklin Final                    | Cl2 (T) OS*     | 1.12     | -     | mg Cl2/L  |
| 23-Jun-25 | 2419850 | TFR002  | Franklin Final                    | Coliforms*      | 0        | ±15%  | MPN/100mL |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

|           |         |         |                 |                 |          |       |           |
|-----------|---------|---------|-----------------|-----------------|----------|-------|-----------|
| 23-Jun-25 | 2419850 | TFR002  | Franklin Final  | Coliphages*     | 0        | ±8%   | PFU/10ml  |
| 23-Jun-25 | 2419849 | TFR002  | Franklin Final  | Coll Time OS*   | 08:28    | -     | -         |
| 23-Jun-25 | 2419853 | TFR002  | Franklin Final  | Conductivity    | 15.0     | ±1.5% | mS/m      |
| 23-Jun-25 | 2419850 | TFR002  | Franklin Final  | E.coli*         | 0        | ±14%  | MPN/100mL |
| 23-Jun-25 | 2419850 | TFR002  | Franklin Final  | HPC 37*         | 1        | ±21%  | cfu/mL    |
| 23-Jun-25 | 2419852 | TFR002  | Franklin Final  | Odour*          | Nil      | -     | -         |
| 23-Jun-25 | 2419849 | TFR002  | Franklin Final  | pH OS*          | 7.40     | -     | -         |
| 23-Jun-25 | 2419849 | TFR002  | Franklin Final  | Temperature OS* | 10.4     | -     | °C        |
| 23-Jun-25 | 2419852 | TFR002  | Franklin Final  | Turbidity       | 1.2      | ±6.1% | NTU       |
| 23-Jun-25 | 2419874 | TKK002  | Kokstad Final   | Al (AE)         | <25.0    | ±7.6% | µg Al/L   |
| 23-Jun-25 | 2419869 | TKK002  | Kokstad Final   | Batch No.*      | 20250201 | -     | -         |
| 23-Jun-25 | 2419869 | TKK002  | Kokstad Final   | Cl2 (F) OS*     | 1.74     | -     | mg Cl2/L  |
| 23-Jun-25 | 2419869 | TKK002  | Kokstad Final   | Cl2 (T) OS*     | 1.99     | -     | mg Cl2/L  |
| 23-Jun-25 | 2419870 | TKK002  | Kokstad Final   | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 23-Jun-25 | 2419870 | TKK002  | Kokstad Final   | Coliphages*     | 0        | ±8%   | PFU/10ml  |
| 23-Jun-25 | 2419869 | TKK002  | Kokstad Final   | Coll Time OS*   | 09:00    | -     | -         |
| 23-Jun-25 | 2419873 | TKK002  | Kokstad Final   | Conductivity    | 8.01     | ±1.5% | mS/m      |
| 23-Jun-25 | 2419870 | TKK002  | Kokstad Final   | E.coli*         | 0        | ±14%  | MPN/100mL |
| 23-Jun-25 | 2419870 | TKK002  | Kokstad Final   | HPC 37*         | 1        | ±21%  | cfu/mL    |
| 23-Jun-25 | 2419869 | TKK002  | Kokstad Final   | pH OS*          | 7.30     | -     | -         |
| 23-Jun-25 | 2419869 | TKK002  | Kokstad Final   | Temperature OS* | 16.7     | -     | °C        |
| 23-Jun-25 | 2419872 | TKK002  | Kokstad Final   | Turbidity       | 0.3      | ±6.1% | NTU       |
| 23-Jun-25 | 2419912 | TNJU002 | KwaNjunga Final | Al (AE)         | 46.1     | ±7.6% | µg Al/L   |
| 23-Jun-25 | 2419907 | TNJU002 | KwaNjunga Final | Batch No.*      | 20250201 | -     | -         |
| 23-Jun-25 | 2419907 | TNJU002 | KwaNjunga Final | Cl2 (F) OS*     | 1.05     | -     | mg Cl2/L  |
| 23-Jun-25 | 2419907 | TNJU002 | KwaNjunga Final | Cl2 (T) OS*     | 1.15     | -     | mg Cl2/L  |
| 23-Jun-25 | 2419908 | TNJU002 | KwaNjunga Final | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 23-Jun-25 | 2419907 | TNJU002 | KwaNjunga Final | Coll Time OS*   | 09:29    | -     | -         |
| 23-Jun-25 | 2419911 | TNJU002 | KwaNjunga Final | Conductivity    | 18.2     | ±1.5% | mS/m      |
| 23-Jun-25 | 2419908 | TNJU002 | KwaNjunga Final | E.coli*         | 0        | ±14%  | MPN/100mL |
| 23-Jun-25 | 2419908 | TNJU002 | KwaNjunga Final | HPC 37*         | 0        | ±21%  | cfu/mL    |
| 23-Jun-25 | 2419907 | TNJU002 | KwaNjunga Final | pH OS*          | 7.60     | -     | -         |
| 23-Jun-25 | 2419907 | TNJU002 | KwaNjunga Final | Temperature OS* | 17.3     | -     | °C        |
| 23-Jun-25 | 2419910 | TNJU002 | KwaNjunga Final | Turbidity       | 0.5      | ±6.1% | NTU       |
| 24-Jun-25 | 2420419 | TQU002  | Mnqumeni Final  | Batch No.*      | 20250201 | -     | -         |
| 24-Jun-25 | 2420419 | TQU002  | Mnqumeni Final  | Cl2 (F) OS*     | 1.04     | -     | mg Cl2/L  |
| 24-Jun-25 | 2420419 | TQU002  | Mnqumeni Final  | Cl2 (T) OS*     | 1.15     | -     | mg Cl2/L  |
| 24-Jun-25 | 2420420 | TQU002  | Mnqumeni Final  | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 24-Jun-25 | 2420419 | TQU002  | Mnqumeni Final  | Coll Time OS*   | 08:27    | -     | -         |
| 24-Jun-25 | 2420423 | TQU002  | Mnqumeni Final  | Conductivity    | 12.5     | ±1.5% | mS/m      |
| 24-Jun-25 | 2420420 | TQU002  | Mnqumeni Final  | E.coli*         | 0        | ±14%  | MPN/100mL |
| 24-Jun-25 | 2420420 | TQU002  | Mnqumeni Final  | HPC 37*         | 4        | ±21%  | cfu/mL    |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

|           |         |         |                    |                 |          |       |           |
|-----------|---------|---------|--------------------|-----------------|----------|-------|-----------|
| 24-Jun-25 | 2420419 | TQU002  | Mnqumeni Final     | pH OS*          | 7.20     | -     | -         |
| 24-Jun-25 | 2420419 | TQU002  | Mnqumeni Final     | Temperature OS* | 13.8     | -     | °C        |
| 24-Jun-25 | 2420422 | TQU002  | Mnqumeni Final     | Turbidity       | 1.0      | ±6.1% | NTU       |
| 24-Jun-25 | 2420434 | TSQ002  | Esiqanduleni Final | Al (AE)         | 39.4     | ±7.6% | µg Al/L   |
| 24-Jun-25 | 2420429 | TSQ002  | Esiqanduleni Final | Batch No.*      | 20250201 | -     | -         |
| 24-Jun-25 | 2420429 | TSQ002  | Esiqanduleni Final | Cl2 (F) OS*     | 1.26     | -     | mg Cl2/L  |
| 24-Jun-25 | 2420429 | TSQ002  | Esiqanduleni Final | Cl2 (T) OS*     | 1.40     | -     | mg Cl2/L  |
| 24-Jun-25 | 2420430 | TSQ002  | Esiqanduleni Final | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 24-Jun-25 | 2420429 | TSQ002  | Esiqanduleni Final | Coll Time OS*   | 08:20    | -     | -         |
| 24-Jun-25 | 2420433 | TSQ002  | Esiqanduleni Final | Conductivity    | 18.8     | ±1.5% | mS/m      |
| 24-Jun-25 | 2420430 | TSQ002  | Esiqanduleni Final | E.coli*         | 0        | ±14%  | MPN/100mL |
| 24-Jun-25 | 2420430 | TSQ002  | Esiqanduleni Final | HPC 37*         | 0        | ±21%  | cfu/mL    |
| 24-Jun-25 | 2420429 | TSQ002  | Esiqanduleni Final | pH OS*          | 7.40     | -     | -         |
| 24-Jun-25 | 2420429 | TSQ002  | Esiqanduleni Final | Temperature OS* | 16.2     | -     | °C        |
| 24-Jun-25 | 2420432 | TSQ002  | Esiqanduleni Final | Turbidity       | 0.2      | ±6.1% | NTU       |
| 25-Jun-25 | 2420890 | TBU002  | Bulwer Final       | Batch No.*      | 20250201 | -     | -         |
| 25-Jun-25 | 2420890 | TBU002  | Bulwer Final       | Cl2 (F) OS*     | 0.48     | -     | mg Cl2/L  |
| 25-Jun-25 | 2420890 | TBU002  | Bulwer Final       | Cl2 (T) OS*     | 0.58     | -     | mg Cl2/L  |
| 25-Jun-25 | 2420891 | TBU002  | Bulwer Final       | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 25-Jun-25 | 2420890 | TBU002  | Bulwer Final       | Coll Time OS*   | 10:30    | -     | -         |
| 25-Jun-25 | 2420894 | TBU002  | Bulwer Final       | Conductivity    | 7.11     | ±1.5% | mS/m      |
| 25-Jun-25 | 2420891 | TBU002  | Bulwer Final       | E.coli*         | 0        | ±14%  | MPN/100mL |
| 25-Jun-25 | 2420891 | TBU002  | Bulwer Final       | HPC 37*         | 3        | ±21%  | cfu/mL    |
| 25-Jun-25 | 2420890 | TBU002  | Bulwer Final       | pH OS*          | 7.30     | -     | -         |
| 25-Jun-25 | 2420890 | TBU002  | Bulwer Final       | Temperature OS* | 14.0     | -     | °C        |
| 25-Jun-25 | 2420893 | TBU002  | Bulwer Final       | Turbidity       | 2.1      | ±6.1% | NTU       |
| 25-Jun-25 | 2420905 | TCR002  | Creighton Final    | Al (AE)         | 280      | ±7.6% | µg Al/L   |
| 25-Jun-25 | 2420900 | TCR002  | Creighton Final    | Batch No.*      | 20250201 | -     | -         |
| 25-Jun-25 | 2420900 | TCR002  | Creighton Final    | Cl2 (F) OS*     | 1.60     | -     | mg Cl2/L  |
| 25-Jun-25 | 2420900 | TCR002  | Creighton Final    | Cl2 (T) OS*     | 1.74     | -     | mg Cl2/L  |
| 25-Jun-25 | 2420901 | TCR002  | Creighton Final    | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 25-Jun-25 | 2420900 | TCR002  | Creighton Final    | Coll Time OS*   | 08:00    | -     | -         |
| 25-Jun-25 | 2420904 | TCR002  | Creighton Final    | Conductivity    | 9.87     | ±1.5% | mS/m      |
| 25-Jun-25 | 2420901 | TCR002  | Creighton Final    | E.coli*         | 0        | ±14%  | MPN/100mL |
| 25-Jun-25 | 2420901 | TCR002  | Creighton Final    | HPC 37*         | 1        | ±21%  | cfu/mL    |
| 25-Jun-25 | 2420900 | TCR002  | Creighton Final    | pH OS*          | 7.30     | -     | -         |
| 25-Jun-25 | 2420900 | TCR002  | Creighton Final    | Temperature OS* | 11.7     | -     | °C        |
| 25-Jun-25 | 2420903 | TCR002  | Creighton Final    | Turbidity       | 0.6      | ±6.1% | NTU       |
| 25-Jun-25 | 2420924 | TMAN002 | Mangwaneni Final   | Batch No.*      | 20250201 | -     | -         |
| 25-Jun-25 | 2420924 | TMAN002 | Mangwaneni Final   | Cl2 (F) OS*     | 0.61     | -     | mg Cl2/L  |
| 25-Jun-25 | 2420924 | TMAN002 | Mangwaneni Final   | Cl2 (T) OS*     | 0.80     | -     | mg Cl2/L  |
| 25-Jun-25 | 2420925 | TMAN002 | Mangwaneni Final   | Coliforms*      | 0        | ±15%  | MPN/100mL |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

|           |         |         |                       |                 |          |       |           |
|-----------|---------|---------|-----------------------|-----------------|----------|-------|-----------|
| 25-Jun-25 | 2420924 | TMAN002 | Mangwaneni Final      | Coll Time OS*   | 11:14    | -     | -         |
| 25-Jun-25 | 2420928 | TMAN002 | Mangwaneni Final      | Conductivity    | 11.1     | ±1.5% | mS/m      |
| 25-Jun-25 | 2420925 | TMAN002 | Mangwaneni Final      | E.coli*         | 0        | ±14%  | MPN/100mL |
| 25-Jun-25 | 2420925 | TMAN002 | Mangwaneni Final      | HPC 37*         | 1        | ±21%  | cfu/mL    |
| 25-Jun-25 | 2420924 | TMAN002 | Mangwaneni Final      | pH OS*          | 7.40     | -     | -         |
| 25-Jun-25 | 2420924 | TMAN002 | Mangwaneni Final      | Temperature OS* | 10.6     | -     | °C        |
| 25-Jun-25 | 2420927 | TMAN002 | Mangwaneni Final      | Turbidity       | 0.5      | ±6.1% | NTU       |
| 25-Jun-25 | 2420933 | TMQA002 | Mqatsheni Final       | Batch No.*      | 20250201 | -     | -         |
| 25-Jun-25 | 2420933 | TMQA002 | Mqatsheni Final       | Cl2 (F) OS*     | 1.11     | -     | mg Cl2/L  |
| 25-Jun-25 | 2420933 | TMQA002 | Mqatsheni Final       | Cl2 (T) OS*     | 1.30     | -     | mg Cl2/L  |
| 25-Jun-25 | 2420934 | TMQA002 | Mqatsheni Final       | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 25-Jun-25 | 2420933 | TMQA002 | Mqatsheni Final       | Coll Time OS*   | 09:20    | -     | -         |
| 25-Jun-25 | 2420937 | TMQA002 | Mqatsheni Final       | Conductivity    | 26.5     | ±1.5% | mS/m      |
| 25-Jun-25 | 2420934 | TMQA002 | Mqatsheni Final       | E.coli*         | 0        | ±14%  | MPN/100mL |
| 25-Jun-25 | 2420934 | TMQA002 | Mqatsheni Final       | HPC 37*         | 0        | ±21%  | cfu/mL    |
| 25-Jun-25 | 2420933 | TMQA002 | Mqatsheni Final       | pH OS*          | 8.30     | -     | -         |
| 25-Jun-25 | 2420933 | TMQA002 | Mqatsheni Final       | Temperature OS* | 11.1     | -     | °C        |
| 25-Jun-25 | 2420936 | TMQA002 | Mqatsheni Final       | Turbidity       | 0.3      | ±6.1% | NTU       |
| 25-Jun-25 | 2420948 | TRV002  | Riverside Final       | Al (AE)         | 1662     | ±7.6% | µg Al/L   |
| 25-Jun-25 | 2420943 | TRV002  | Riverside Final       | Batch No.*      | 20250201 | -     | -         |
| 25-Jun-25 | 2420943 | TRV002  | Riverside Final       | Cl2 (F) OS*     | 1.84     | -     | mg Cl2/L  |
| 25-Jun-25 | 2420943 | TRV002  | Riverside Final       | Cl2 (T) OS*     | 1.96     | -     | mg Cl2/L  |
| 25-Jun-25 | 2420944 | TRV002  | Riverside Final       | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 25-Jun-25 | 2420944 | TRV002  | Riverside Final       | Coliphages*     | 0        | ±8%   | PFU/10ml  |
| 25-Jun-25 | 2420943 | TRV002  | Riverside Final       | Coll Time OS*   | 08:40    | -     | -         |
| 25-Jun-25 | 2420947 | TRV002  | Riverside Final       | Conductivity    | 10.9     | ±1.5% | mS/m      |
| 25-Jun-25 | 2420944 | TRV002  | Riverside Final       | E.coli*         | 0        | ±14%  | MPN/100mL |
| 25-Jun-25 | 2420944 | TRV002  | Riverside Final       | HPC 37*         | 0        | ±21%  | cfu/mL    |
| 25-Jun-25 | 2420943 | TRV002  | Riverside Final       | pH OS*          | 7.40     | -     | -         |
| 25-Jun-25 | 2420943 | TRV002  | Riverside Final       | Temperature OS* | 12.1     | -     | °C        |
| 25-Jun-25 | 2420946 | TRV002  | Riverside Final       | Turbidity       | 1.5      | ±6.1% | NTU       |
| 25-Jun-25 | 2420959 | TST002  | St Appollinaris Final | Al (AE)         | 163      | ±7.6% | µg Al/L   |
| 25-Jun-25 | 2420954 | TST002  | St Appollinaris Final | Batch No.*      | 20250201 | -     | -         |
| 25-Jun-25 | 2420954 | TST002  | St Appollinaris Final | Cl2 (F) OS*     | 1.02     | -     | mg Cl2/L  |
| 25-Jun-25 | 2420954 | TST002  | St Appollinaris Final | Cl2 (T) OS*     | 1.09     | -     | mg Cl2/L  |
| 25-Jun-25 | 2420955 | TST002  | St Appollinaris Final | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 25-Jun-25 | 2420954 | TST002  | St Appollinaris Final | Coll Time OS*   | 09:40    | -     | -         |
| 25-Jun-25 | 2420958 | TST002  | St Appollinaris Final | Conductivity    | 9.87     | ±1.5% | mS/m      |
| 25-Jun-25 | 2420955 | TST002  | St Appollinaris Final | E.coli*         | 0        | ±14%  | MPN/100mL |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

|           |         |        |                       |                 |          |       |           |
|-----------|---------|--------|-----------------------|-----------------|----------|-------|-----------|
| 25-Jun-25 | 2420955 | TST002 | St Appollinaris Final | HPC 37*         | 0        | ±21%  | cfu/mL    |
| 25-Jun-25 | 2420954 | TST002 | St Appollinaris Final | pH OS*          | 7.30     | -     | -         |
| 25-Jun-25 | 2420954 | TST002 | St Appollinaris Final | Temperature OS* | 14.1     | -     | °C        |
| 25-Jun-25 | 2420957 | TST002 | St Appollinaris Final | Turbidity       | 2.2      | ±6.1% | NTU       |
| 25-Jun-25 | 2420970 | TUN002 | Underberg Final       | Al (AE)         | 63.9     | ±7.6% | µg Al/L   |
| 25-Jun-25 | 2420965 | TUN002 | Underberg Final       | Batch No.*      | 20250201 | -     | -         |
| 25-Jun-25 | 2420965 | TUN002 | Underberg Final       | Cl2 (F) OS*     | 0.34     | -     | mg Cl2/L  |
| 25-Jun-25 | 2420965 | TUN002 | Underberg Final       | Cl2 (T) OS*     | 0.50     | -     | mg Cl2/L  |
| 25-Jun-25 | 2420966 | TUN002 | Underberg Final       | Coliforms*      | 11       | ±15%  | MPN/100mL |
| 25-Jun-25 | 2420965 | TUN002 | Underberg Final       | Coll Time OS*   | 09:59    | -     | -         |
| 25-Jun-25 | 2420969 | TUN002 | Underberg Final       | Conductivity    | 6.88     | ±1.5% | mS/m      |
| 25-Jun-25 | 2420966 | TUN002 | Underberg Final       | E.coli*         | 1        | ±14%  | MPN/100mL |
| 25-Jun-25 | 2420966 | TUN002 | Underberg Final       | HPC 37*         | 22       | ±21%  | cfu/mL    |
| 25-Jun-25 | 2420965 | TUN002 | Underberg Final       | pH OS*          | 7.20     | -     | -         |
| 25-Jun-25 | 2420965 | TUN002 | Underberg Final       | Temperature OS* | 11.0     | -     | °C        |
| 25-Jun-25 | 2420968 | TUN002 | Underberg Final       | Turbidity       | 0.6      | ±6.1% | NTU       |
| 26-Jun-25 | 2421591 | TMZ002 | Umzimkhulu Final      | Al (AE)         | 288      | ±7.6% | µg Al/L   |
| 26-Jun-25 | 2421586 | TMZ002 | Umzimkhulu Final      | Batch No.*      | 20250201 | -     | -         |
| 26-Jun-25 | 2421586 | TMZ002 | Umzimkhulu Final      | Cl2 (F) OS*     | 0.32     | -     | mg Cl2/L  |
| 26-Jun-25 | 2421586 | TMZ002 | Umzimkhulu Final      | Cl2 (T) OS*     | 0.45     | -     | mg Cl2/L  |
| 26-Jun-25 | 2421587 | TMZ002 | Umzimkhulu Final      | Coliforms*      | >201     | ±15%  | MPN/100mL |
| 26-Jun-25 | 2421587 | TMZ002 | Umzimkhulu Final      | Coliphages*     | 0        | ±8%   | PFU/10ml  |
| 26-Jun-25 | 2421586 | TMZ002 | Umzimkhulu Final      | Coll Time OS*   | 08:00    | -     | -         |
| 26-Jun-25 | 2421590 | TMZ002 | Umzimkhulu Final      | Conductivity    | 9.99     | ±1.5% | mS/m      |
| 26-Jun-25 | 2421587 | TMZ002 | Umzimkhulu Final      | E.coli*         | 15       | ±14%  | MPN/100mL |
| 26-Jun-25 | 2421587 | TMZ002 | Umzimkhulu Final      | HPC 37*         | 37       | ±21%  | cfu/mL    |
| 26-Jun-25 | 2421586 | TMZ002 | Umzimkhulu Final      | pH OS*          | 7.30     | -     | -         |
| 26-Jun-25 | 2421586 | TMZ002 | Umzimkhulu Final      | Temperature OS* | 13.1     | -     | °C        |
| 26-Jun-25 | 2421589 | TMZ002 | Umzimkhulu Final      | Turbidity       | 2.5      | ±6.1% | NTU       |
| 26-Jun-25 | 2421602 | TNO002 | Nokweja Final         | Al (AE)         | 300      | ±7.6% | µg Al/L   |
| 26-Jun-25 | 2421597 | TNO002 | Nokweja Final         | Batch No.*      | 20250201 | -     | -         |
| 26-Jun-25 | 2421597 | TNO002 | Nokweja Final         | Cl2 (F) OS*     | 0.90     | -     | mg Cl2/L  |
| 26-Jun-25 | 2421597 | TNO002 | Nokweja Final         | Cl2 (T) OS*     | 1.10     | -     | mg Cl2/L  |
| 26-Jun-25 | 2421598 | TNO002 | Nokweja Final         | Coliforms*      | 0        | ±15%  | MPN/100mL |
| 26-Jun-25 | 2421598 | TNO002 | Nokweja Final         | Coliphages*     | 0        | ±8%   | PFU/10ml  |
| 26-Jun-25 | 2421597 | TNO002 | Nokweja Final         | Coll Time OS*   | 08:37    | -     | -         |
| 26-Jun-25 | 2421601 | TNO002 | Nokweja Final         | Conductivity    | 10.1     | ±1.5% | mS/m      |
| 26-Jun-25 | 2421598 | TNO002 | Nokweja Final         | E.coli*         | 0        | ±14%  | MPN/100mL |
| 26-Jun-25 | 2421598 | TNO002 | Nokweja Final         | HPC 37*         | 11       | ±21%  | cfu/mL    |
| 26-Jun-25 | 2421597 | TNO002 | Nokweja Final         | pH OS*          | 7.20     | -     | -         |
| 26-Jun-25 | 2421597 | TNO002 | Nokweja Final         | Temperature OS* | 11.7     | -     | °C        |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

|           |         |        |               |                         |          |       |                       |
|-----------|---------|--------|---------------|-------------------------|----------|-------|-----------------------|
| 26-Jun-25 | 2421600 | TNO002 | Nokweja Final | Turbidity               | 2.0      | ±6.1% | NTU                   |
| 27-Jun-25 | 2421825 | TIB002 | Ibisi Final   | Al (AE)                 | 132      | ±7.6% | µg Al/L               |
| 27-Jun-25 | 2421820 | TIB002 | Ibisi Final   | Batch No.*              | 20250201 | -     | -                     |
| 27-Jun-25 | 2421820 | TIB002 | Ibisi Final   | Cl <sub>2</sub> (F) OS* | 1.35     | -     | mg Cl <sub>2</sub> /L |
| 27-Jun-25 | 2421820 | TIB002 | Ibisi Final   | Cl <sub>2</sub> (T) OS* | 1.40     | -     | mg Cl <sub>2</sub> /L |
| 27-Jun-25 | 2421821 | TIB002 | Ibisi Final   | Coliforms*              | 0        | ±15%  | MPN/100mL             |
| 27-Jun-25 | 2421821 | TIB002 | Ibisi Final   | Coliphages*             | 0        | ±8%   | PFU/10ml              |
| 27-Jun-25 | 2421820 | TIB002 | Ibisi Final   | Coll Time OS*           | 07:00    | -     | -                     |
| 27-Jun-25 | 2421824 | TIB002 | Ibisi Final   | Conductivity            | 10.1     | ±1.5% | mS/m                  |
| 27-Jun-25 | 2421821 | TIB002 | Ibisi Final   | E.coli*                 | 0        | ±14%  | MPN/100mL             |
| 27-Jun-25 | 2421821 | TIB002 | Ibisi Final   | HPC 37*                 | 0        | ±21%  | cfu/mL                |
| 27-Jun-25 | 2421820 | TIB002 | Ibisi Final   | pH OS*                  | 7.40     | -     | -                     |
| 27-Jun-25 | 2421820 | TIB002 | Ibisi Final   | Temperature OS*         | 12.1     | -     | °C                    |
| 27-Jun-25 | 2421823 | TIB002 | Ibisi Final   | Turbidity               | 1.3      | ±6.1% | NTU                   |

## uMngeni-uThukela Water

### HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,  
Telephone (033) 341 1111  
E-mail: [info@umngeni.co.za](mailto:info@umngeni.co.za) • Website: <https://www.umngeni-uthukela.co.za/>

**Board Members:** Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)