

Date: 10 July 2025

The Executive Director: Water Services Department

Harry Gwala District Municipality

40 Main Street

Ixopo

3276

Attention: Basetsana Khathalib and Bheki Nene

JUNE 2025 UNTREATED WATER (RAW) RESULTS

Please find June 2025 Untreated Water (Raw) results tabulated below for samples received during June 2025. Determinands marked with an asterix are unaccredited and are not included in uMngeni-uThukela Water's schedule of accreditation.

Please contact us immediately should you have any queries.

Yours' Sincerely

Mr M Sewcharan

Client Services Manager

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

Sample Date	Sample Number	Sampling Point	Description	Determinand	Result	UOM	Unit
02-Jun-25	2406983	TFR001	Franklin Raw	Al (AE)	235	±7.6%	µg Al/L
02-Jun-25	2406980	TFR001	Franklin Raw	Coliforms*	>2420	±22%	MPN/100mL
02-Jun-25	2406980	TFR001	Franklin Raw	Coliphages*	>500	±4%	PFU/10ml
02-Jun-25	2406979	TFR001	Franklin Raw	Coll Time OS*	8:36	-	-
02-Jun-25	2406982	TFR001	Franklin Raw	Conductivity	9.29	±1.5%	mS/m
02-Jun-25	2406980	TFR001	Franklin Raw	E.coli*	1553	±21%	MPN/100mL
02-Jun-25	2406979	TFR001	Franklin Raw	pH OS*	7.50	-	-
02-Jun-25	2406979	TFR001	Franklin Raw	Temperature OS*	8.8	-	°C
02-Jun-25	2406981	TFR001	Franklin Raw	Turbidity	16.5	±6.1%	NTU
02-Jun-25	2407015	TKK001	Kokstad River Raw	Al (AE)	376	±7.6%	µg Al/L
02-Jun-25	2407012	TKK001	Kokstad River Raw	Coliforms*	517	±22%	MPN/100mL
02-Jun-25	2407012	TKK001	Kokstad River Raw	Coliphages*	19	±8%	PFU/10ml
02-Jun-25	2407011	TKK001	Kokstad River Raw	Coll Time OS*	9:25	-	-
02-Jun-25	2407013	TKK001	Kokstad River Raw	Colour	16.0	±6.5%	mg Pt-Co/L
02-Jun-25	2407014	TKK001	Kokstad River Raw	Conductivity	12.6	±1.5%	mS/m
02-Jun-25	2407012	TKK001	Kokstad River Raw	E.coli*	133	±21%	MPN/100mL
02-Jun-25	2407015	TKK001	Kokstad River Raw	Fe (AE)	0.99	±5.4%	mg Fe/L
02-Jun-25	2407015	TKK001	Kokstad River Raw	Mn (AE)	0.02	±6.2%	mg Mn/L
02-Jun-25	2407013	TKK001	Kokstad River Raw	Odour*	Nil	-	-
02-Jun-25	2407011	TKK001	Kokstad River Raw	pH OS*	7.20	-	-
02-Jun-25	2407011	TKK001	Kokstad River Raw	Temperature OS*	12.9	-	°C
02-Jun-25	2407013	TKK001	Kokstad River Raw	Turbidity	11.1	±6.1%	NTU
02-Jun-25	2407026	TKK003	Kokstad Crystal Spring Raw	Al (AE)	367	±7.6%	µg Al/L
02-Jun-25	2407023	TKK003	Kokstad Crystal Spring Raw	Coliforms*	194	±22%	MPN/100mL
02-Jun-25	2407023	TKK003	Kokstad Crystal Spring Raw	Coliphages*	1	±8%	PFU/10ml
02-Jun-25	2407022	TKK003	Kokstad Crystal Spring Raw	Coll Time OS*	9:44	-	-
02-Jun-25	2407024	TKK003	Kokstad Crystal Spring Raw	Colour	12.5	±6.5%	mg Pt-Co/L
02-Jun-25	2407025	TKK003	Kokstad Crystal Spring Raw	Conductivity	8.11	±1.5%	mS/m
02-Jun-25	2407023	TKK003	Kokstad Crystal Spring Raw	E.coli*	3	±21%	MPN/100mL
02-Jun-25	2407026	TKK003	Kokstad Crystal Spring Raw	Fe (AE)	0.90	±5.4%	mg Fe/L
02-Jun-25	2407024	TKK003	Kokstad Crystal Spring Raw	Odour*	Nil	-	-
02-Jun-25	2407022	TKK003	Kokstad Crystal Spring Raw	pH OS*	7.30	-	-
02-Jun-25	2407022	TKK003	Kokstad Crystal Spring Raw	Temperature OS*	12.1	-	°C
02-Jun-25	2407024	TKK003	Kokstad Crystal Spring Raw	Turbidity	4.8	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

03-Jun-25	2407699	TQU001	Mnqumeni Raw	Coliforms*	179	±22%	MPN/100mL
03-Jun-25	2407698	TQU001	Mnqumeni Raw	Coll Time OS*	08:30	-	-
03-Jun-25	2407700	TQU001	Mnqumeni Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
03-Jun-25	2407701	TQU001	Mnqumeni Raw	Conductivity	11.8	±1.5%	mS/m
03-Jun-25	2407699	TQU001	Mnqumeni Raw	E.coli*	11	±21%	MPN/100mL
03-Jun-25	2407700	TQU001	Mnqumeni Raw	Odour*	Nil	-	-
03-Jun-25	2407698	TQU001	Mnqumeni Raw	pH OS*	8.30	-	-
03-Jun-25	2407698	TQU001	Mnqumeni Raw	Temperature OS*	15.3	-	°C
03-Jun-25	2407700	TQU001	Mnqumeni Raw	Turbidity	6.0	±6.1%	NTU
03-Jun-25	2407712	TSQ001	Esiqanduleni Raw	Al (AE)	89.4	±7.6%	µg Al/L
03-Jun-25	2407709	TSQ001	Esiqanduleni Raw	Coliforms*	649	±22%	MPN/100mL
03-Jun-25	2407709	TSQ001	Esiqanduleni Raw	Coliphages*	0	±8%	PFU/10ml
03-Jun-25	2407708	TSQ001	Esiqanduleni Raw	Coll Time OS*	07:20	-	-
03-Jun-25	2407711	TSQ001	Esiqanduleni Raw	Conductivity	15.1	±1.5%	mS/m
03-Jun-25	2407709	TSQ001	Esiqanduleni Raw	E.coli*	17	±21%	MPN/100mL
03-Jun-25	2407708	TSQ001	Esiqanduleni Raw	pH OS*	7.50	-	-
03-Jun-25	2407708	TSQ001	Esiqanduleni Raw	Temperature OS*	17.1	-	°C
03-Jun-25	2407710	TSQ001	Esiqanduleni Raw	Turbidity	2.7	±6.1%	NTU
04-Jun-25	2408280	TBU001	Bulwer Raw	Al (AE)	237	±7.6%	µg Al/L
04-Jun-25	2408277	TBU001	Bulwer Raw	Coliforms*	866	±22%	MPN/100mL
04-Jun-25	2408276	TBU001	Bulwer Raw	Coll Time OS*	10:45	-	-
04-Jun-25	2408278	TBU001	Bulwer Raw	Colour	1.90	±6.5%	mg Pt-Co/L
04-Jun-25	2408279	TBU001	Bulwer Raw	Conductivity	5.41	±1.5%	mS/m
04-Jun-25	2408277	TBU001	Bulwer Raw	E.coli*	46	±21%	MPN/100mL
04-Jun-25	2408280	TBU001	Bulwer Raw	Fe (AE)	0.33	±5.4%	mg Fe/L
04-Jun-25	2408278	TBU001	Bulwer Raw	Odour*	Nil	-	-
04-Jun-25	2408276	TBU001	Bulwer Raw	pH OS*	7.40	-	-
04-Jun-25	2408276	TBU001	Bulwer Raw	Temperature OS*	14.6	-	°C
04-Jun-25	2408278	TBU001	Bulwer Raw	Turbidity	5.4	±6.1%	NTU
04-Jun-25	2408296	TCR001	Creighton Raw	Al (AE)	81.3	±7.6%	µg Al/L
04-Jun-25	2408293	TCR001	Creighton Raw	Coliforms*	21	±22%	MPN/100mL
04-Jun-25	2408292	TCR001	Creighton Raw	Coll Time OS*	08:35	-	-
04-Jun-25	2408294	TCR001	Creighton Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
04-Jun-25	2408295	TCR001	Creighton Raw	Conductivity	7.16	±1.5%	mS/m
04-Jun-25	2408293	TCR001	Creighton Raw	E.coli*	1	±21%	MPN/100mL
04-Jun-25	2408296	TCR001	Creighton Raw	Fe (AE)	0.07	±5.4%	mg Fe/L
04-Jun-25	2408296	TCR001	Creighton Raw	Mn (AE)	<0.01	±6.2%	mg Mn/L
04-Jun-25	2408294	TCR001	Creighton Raw	Odour*	Nil	-	-
04-Jun-25	2408292	TCR001	Creighton Raw	pH OS*	7.20	-	-
04-Jun-25	2408292	TCR001	Creighton Raw	Temperature OS*	10.4	-	°C
04-Jun-25	2408294	TCR001	Creighton Raw	Turbidity	1.8	±6.1%	NTU
04-Jun-25	2408314	THL001	Hlanganani Raw	Coliforms*	548	±22%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

04-Jun-25	2408313	THL001	Hlanganani Raw	Coll Time OS*	11:58	-	-
04-Jun-25	2408315	THL001	Hlanganani Raw	Colour	2.00	±6.5%	mg Pt-Co/L
04-Jun-25	2408316	THL001	Hlanganani Raw	Conductivity	9.32	±1.5%	mS/m
04-Jun-25	2408314	THL001	Hlanganani Raw	E.coli*	14	±21%	MPN/100mL
04-Jun-25	2408315	THL001	Hlanganani Raw	Odour*	Nil	-	-
04-Jun-25	2408313	THL001	Hlanganani Raw	pH OS*	7.30	-	-
04-Jun-25	2408313	THL001	Hlanganani Raw	Temperature OS*	14.0	-	°C
04-Jun-25	2408315	THL001	Hlanganani Raw	Turbidity	3.3	±6.1%	NTU
04-Jun-25	2408352	TMQA001	Mqatsheni Raw	Al (AE)	<25.0	±7.6%	µg Al/L
04-Jun-25	2408349	TMQA001	Mqatsheni Raw	Coliforms*	0	±22%	MPN/100mL
04-Jun-25	2408348	TMQA001	Mqatsheni Raw	Coll Time OS*	09:21	-	-
04-Jun-25	2408350	TMQA001	Mqatsheni Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
04-Jun-25	2408351	TMQA001	Mqatsheni Raw	Conductivity	27.2	±1.5%	mS/m
04-Jun-25	2408349	TMQA001	Mqatsheni Raw	E.coli*	0	±21%	MPN/100mL
04-Jun-25	2408352	TMQA001	Mqatsheni Raw	Fe (AE)	<0.02	±5.4%	mg Fe/L
04-Jun-25	2408350	TMQA001	Mqatsheni Raw	Odour*	Nil	-	-
04-Jun-25	2408348	TMQA001	Mqatsheni Raw	pH OS*	9.10	-	-
04-Jun-25	2408348	TMQA001	Mqatsheni Raw	Temperature OS*	13.0	-	°C
04-Jun-25	2408350	TMQA001	Mqatsheni Raw	Turbidity	0.5	±6.1%	NTU
04-Jun-25	2408368	TRV001	Riversside Raw	Al (AE)	2544	±7.6%	µg Al/L
04-Jun-25	2408365	TRV001	Riversside Raw	Coliforms*	19	±22%	MPN/100mL
04-Jun-25	2408364	TRV001	Riversside Raw	Coll Time OS*	09:06	-	-
04-Jun-25	2408366	TRV001	Riversside Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
04-Jun-25	2408367	TRV001	Riversside Raw	Conductivity	8.26	±1.5%	mS/m
04-Jun-25	2408365	TRV001	Riversside Raw	E.coli*	2	±21%	MPN/100mL
04-Jun-25	2408368	TRV001	Riversside Raw	Fe (AE)	0.23	±5.4%	mg Fe/L
04-Jun-25	2408366	TRV001	Riversside Raw	Odour*	Nil	-	-
04-Jun-25	2408364	TRV001	Riversside Raw	pH OS*	7.10	-	-
04-Jun-25	2408364	TRV001	Riversside Raw	Temperature OS*	10.1	-	°C
04-Jun-25	2408366	TRV001	Riversside Raw	Turbidity	4.2	±6.1%	NTU
04-Jun-25	2408383	TST001	St Appollinaris Raw	Al (AE)	452	±7.6%	µg Al/L
04-Jun-25	2408380	TST001	St Appollinaris Raw	Coliforms*	344	±22%	MPN/100mL
04-Jun-25	2408379	TST001	St Appollinaris Raw	Coll Time OS*	10:28	-	-
04-Jun-25	2408381	TST001	St Appollinaris Raw	Colour	2.40	±6.5%	mg Pt-Co/L
04-Jun-25	2408382	TST001	St Appollinaris Raw	Conductivity	8.16	±1.5%	mS/m
04-Jun-25	2408380	TST001	St Appollinaris Raw	E.coli*	38	±21%	MPN/100mL
04-Jun-25	2408383	TST001	St Appollinaris Raw	Fe (AE)	0.16	±5.4%	mg Fe/L
04-Jun-25	2408381	TST001	St Appollinaris Raw	Odour*	Nil	-	-
04-Jun-25	2408379	TST001	St Appollinaris Raw	pH OS*	7.20	-	-
04-Jun-25	2408379	TST001	St Appollinaris Raw	Temperature OS*	13.8	-	°C
04-Jun-25	2408381	TST001	St Appollinaris Raw	Turbidity	2.3	±6.1%	NTU
04-Jun-25	2408394	TUN001	Underberg Raw	Al (AE)	<25.0	±7.6%	µg Al/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

04-Jun-25	2408391	TUN001	Underberg Raw	Coliforms*	328	±22%	MPN/100mL
04-Jun-25	2408391	TUN001	Underberg Raw	Coliphages*	13	±8%	PFU/10ml
04-Jun-25	2408390	TUN001	Underberg Raw	Coll Time OS*	07:40	-	-
04-Jun-25	2408392	TUN001	Underberg Raw	Colour	4.00	±6.5%	mg Pt-Co/L
04-Jun-25	2408393	TUN001	Underberg Raw	Conductivity	6.62	±1.5%	mS/m
04-Jun-25	2408391	TUN001	Underberg Raw	E.coli*	96	±21%	MPN/100mL
04-Jun-25	2408394	TUN001	Underberg Raw	Fe (AE)	0.07	±5.4%	mg Fe/L
04-Jun-25	2408392	TUN001	Underberg Raw	Odour*	Nil	-	-
04-Jun-25	2408390	TUN001	Underberg Raw	pH OS*	8.20	-	-
04-Jun-25	2408390	TUN001	Underberg Raw	Temperature OS*	9.0	-	°C
04-Jun-25	2408392	TUN001	Underberg Raw	Turbidity	1.1	±6.1%	NTU
05-Jun-25	2409053	TMZ001	Umzimkhulu Raw	Al (AE)	172	±7.6%	µg Al/L
05-Jun-25	2409050	TMZ001	Umzimkhulu Raw	Coliforms*	387	±22%	MPN/100mL
05-Jun-25	2409050	TMZ001	Umzimkhulu Raw	Coliphages*	15	±8%	PFU/10ml
05-Jun-25	2409049	TMZ001	Umzimkhulu Raw	Coll Time OS*	08:49	-	-
05-Jun-25	2409052	TMZ001	Umzimkhulu Raw	Conductivity	9.97	±1.5%	mS/m
05-Jun-25	2409050	TMZ001	Umzimkhulu Raw	E.coli*	46	±21%	MPN/100mL
05-Jun-25	2409049	TMZ001	Umzimkhulu Raw	pH OS*	7.50	-	-
05-Jun-25	2409049	TMZ001	Umzimkhulu Raw	Temperature OS*	13.0	-	°C
05-Jun-25	2409051	TMZ001	Umzimkhulu Raw	Turbidity	6.2	±6.1%	NTU
05-Jun-25	2409080	TNO001	Nokweja Raw	Al (AE)	183	±7.6%	µg Al/L
05-Jun-25	2409077	TNO001	Nokweja Raw	Coliforms*	>2420	±22%	MPN/100mL
05-Jun-25	2409077	TNO001	Nokweja Raw	Coliphages*	49	±8%	PFU/10ml
05-Jun-25	2409076	TNO001	Nokweja Raw	Coll Time OS*	09:24	-	-
05-Jun-25	2409079	TNO001	Nokweja Raw	Conductivity	9.42	±1.5%	mS/m
05-Jun-25	2409077	TNO001	Nokweja Raw	E.coli*	1553	±21%	MPN/100mL
05-Jun-25	2409076	TNO001	Nokweja Raw	pH OS*	7.30	-	-
05-Jun-25	2409076	TNO001	Nokweja Raw	Temperature OS*	17.0	-	°C
05-Jun-25	2409078	TNO001	Nokweja Raw	Turbidity	3.4	±6.1%	NTU
05-Jun-25	2409099	TWA001	Washbank Raw	Al (AE)	379	±7.6%	µg Al/L
05-Jun-25	2409096	TWA001	Washbank Raw	Coliforms*	>2420	±22%	MPN/100mL
05-Jun-25	2409095	TWA001	Washbank Raw	Coll Time OS*	08:06	-	-
05-Jun-25	2409098	TWA001	Washbank Raw	Conductivity	6.30	±1.5%	mS/m
05-Jun-25	2409096	TWA001	Washbank Raw	E.coli*	18	±21%	MPN/100mL
05-Jun-25	2409095	TWA001	Washbank Raw	pH OS*	7.20	-	-
05-Jun-25	2409095	TWA001	Washbank Raw	Temperature OS*	12.2	-	°C
05-Jun-25	2409097	TWA001	Washbank Raw	Turbidity	43.7	±6.1%	NTU
06-Jun-25	2409377	TRT001	Rietvlei Raw	Coliforms*	>2420	±22%	MPN/100mL
06-Jun-25	2409376	TRT001	Rietvlei Raw	Coll Time OS*	06:50	-	-
06-Jun-25	2409379	TRT001	Rietvlei Raw	Conductivity	15.2	±1.5%	mS/m
06-Jun-25	2409377	TRT001	Rietvlei Raw	E.coli*	272	±21%	MPN/100mL
06-Jun-25	2409376	TRT001	Rietvlei Raw	pH OS*	7.00	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

06-Jun-25	2409376	TRT001	Rietvlei Raw	Temperature OS*	14.1	-	°C
06-Jun-25	2409378	TRT001	Rietvlei Raw	Turbidity	12.8	±6.1%	NTU
09-Jun-25	2411550	TFR001	Franklin Raw	Al (AE)	415	±7.6%	µg Al/L
09-Jun-25	2411547	TFR001	Franklin Raw	Coliforms*	>2420	±22%	MPN/100mL
09-Jun-25	2411547	TFR001	Franklin Raw	Coliphages*	>500	±4%	PFU/10ml
09-Jun-25	2411546	TFR001	Franklin Raw	Coll Time OS*	08:47	-	-
09-Jun-25	2411549	TFR001	Franklin Raw	Conductivity	9.15	±1.5%	mS/m
09-Jun-25	2411547	TFR001	Franklin Raw	E.coli*	>2420	±21%	MPN/100mL
09-Jun-25	2411546	TFR001	Franklin Raw	pH OS*	7.20	-	-
09-Jun-25	2411546	TFR001	Franklin Raw	Temperature OS*	11.9	-	°C
09-Jun-25	2411548	TFR001	Franklin Raw	Turbidity	18.2	±6.1%	NTU
09-Jun-25	2411570	TKK001	Kokstad River Raw	Al (AE)	432	±7.6%	µg Al/L
09-Jun-25	2411567	TKK001	Kokstad River Raw	Coliforms*	>2420	±22%	MPN/100mL
09-Jun-25	2411567	TKK001	Kokstad River Raw	Coliphages*	22	±8%	PFU/10ml
09-Jun-25	2411566	TKK001	Kokstad River Raw	Coll Time OS*	08:00	-	-
09-Jun-25	2411569	TKK001	Kokstad River Raw	Conductivity	12.8	±1.5%	mS/m
09-Jun-25	2411567	TKK001	Kokstad River Raw	E.coli*	365	±21%	MPN/100mL
09-Jun-25	2411566	TKK001	Kokstad River Raw	pH OS*	7.60	-	-
09-Jun-25	2411566	TKK001	Kokstad River Raw	Temperature OS*	12.1	-	°C
09-Jun-25	2411568	TKK001	Kokstad River Raw	Turbidity	11.3	±6.1%	NTU
09-Jun-25	2411581	TKK003	Kokstad Crystal Spring Raw	Al (AE)	308	±7.6%	µg Al/L
09-Jun-25	2411578	TKK003	Kokstad Crystal Spring Raw	Coliforms*	165	±22%	MPN/100mL
09-Jun-25	2411578	TKK003	Kokstad Crystal Spring Raw	Coliphages*	0	±8%	PFU/10ml
09-Jun-25	2411577	TKK003	Kokstad Crystal Spring Raw	Coll Time OS*	08:20	-	-
09-Jun-25	2411580	TKK003	Kokstad Crystal Spring Raw	Conductivity	8.67	±1.5%	mS/m
09-Jun-25	2411578	TKK003	Kokstad Crystal Spring Raw	E.coli*	2	±21%	MPN/100mL
09-Jun-25	2411577	TKK003	Kokstad Crystal Spring Raw	pH OS*	7.40	-	-
09-Jun-25	2411577	TKK003	Kokstad Crystal Spring Raw	Temperature OS*	11.4	-	°C
09-Jun-25	2411579	TKK003	Kokstad Crystal Spring Raw	Turbidity	3.9	±6.1%	NTU
11-Jun-25	2412733	TBU001	Bulwer Raw	Al (AE)	544	±7.6%	µg Al/L
11-Jun-25	2412730	TBU001	Bulwer Raw	Coliforms*	>2420	±22%	MPN/100mL
11-Jun-25	2412729	TBU001	Bulwer Raw	Coll Time OS*	10:34	-	-
11-Jun-25	2412731	TBU001	Bulwer Raw	Colour	6.00	±6.5%	mg Pt-Co/L
11-Jun-25	2412732	TBU001	Bulwer Raw	Conductivity	5.63	±1.5%	mS/m
11-Jun-25	2412730	TBU001	Bulwer Raw	E.coli*	196	±21%	MPN/100mL
11-Jun-25	2412729	TBU001	Bulwer Raw	pH OS*	7.40	-	-
11-Jun-25	2412729	TBU001	Bulwer Raw	Temperature OS*	10.2	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

11-Jun-25	2412731	TBU001	Bulwer Raw	Turbidity	9.0	±6.1%	NTU
11-Jun-25	2412751	THL001	Hlanganani Raw	Coliforms*	>2420	±22%	MPN/100mL
11-Jun-25	2412750	THL001	Hlanganani Raw	Coll Time OS*	11:00	-	-
11-Jun-25	2412753	THL001	Hlanganani Raw	Conductivity	8.31	±1.5%	mS/m
11-Jun-25	2412751	THL001	Hlanganani Raw	E.coli*	1046	±21%	MPN/100mL
11-Jun-25	2412750	THL001	Hlanganani Raw	pH OS*	7.50	-	-
11-Jun-25	2412750	THL001	Hlanganani Raw	Temperature OS*	11.3	-	°C
11-Jun-25	2412752	THL001	Hlanganani Raw	Turbidity	48.2	±6.1%	NTU
11-Jun-25	2412775	TMQA001	Mqatsheni Raw	Coliforms*	0	±22%	MPN/100mL
11-Jun-25	2412774	TMQA001	Mqatsheni Raw	Coll Time OS*	10:04	-	-
11-Jun-25	2412776	TMQA001	Mqatsheni Raw	Colour	1.00	±6.5%	mg Pt-Co/L
11-Jun-25	2412777	TMQA001	Mqatsheni Raw	Conductivity	27.6	±1.5%	mS/m
11-Jun-25	2412775	TMQA001	Mqatsheni Raw	E.coli*	0	±21%	MPN/100mL
11-Jun-25	2412774	TMQA001	Mqatsheni Raw	pH OS*	8.80	-	-
11-Jun-25	2412774	TMQA001	Mqatsheni Raw	Temperature OS*	10.0	-	°C
11-Jun-25	2412776	TMQA001	Mqatsheni Raw	Turbidity	0.6	±6.1%	NTU
11-Jun-25	2412787	TRV001	Riversside Raw	Al (AE)	25804	±7.6%	µg Al/L
11-Jun-25	2412784	TRV001	Riversside Raw	Coliforms*	>2420	±22%	MPN/100mL
11-Jun-25	2412783	TRV001	Riversside Raw	Coll Time OS*	08:40	-	-
11-Jun-25	2412785	TRV001	Riversside Raw	Colour	12.4	±6.5%	mg Pt-Co/L
11-Jun-25	2412786	TRV001	Riversside Raw	Conductivity	5.85	±1.5%	mS/m
11-Jun-25	2412784	TRV001	Riversside Raw	E.coli*	770	±21%	MPN/100mL
11-Jun-25	2412783	TRV001	Riversside Raw	pH OS*	7.50	-	-
11-Jun-25	2412783	TRV001	Riversside Raw	Temperature OS*	10.1	-	°C
11-Jun-25	2412785	TRV001	Riversside Raw	Turbidity	66.8	±6.1%	NTU
11-Jun-25	2412798	TST001	St Appollinaris Raw	Al (AE)	493	±7.6%	µg Al/L
11-Jun-25	2412795	TST001	St Appollinaris Raw	Coliforms*	>2420	±22%	MPN/100mL
11-Jun-25	2412794	TST001	St Appollinaris Raw	Coll Time OS*	09:47	-	-
11-Jun-25	2412797	TST001	St Appollinaris Raw	Conductivity	7.80	±1.5%	mS/m
11-Jun-25	2412795	TST001	St Appollinaris Raw	E.coli*	308	±21%	MPN/100mL
11-Jun-25	2412794	TST001	St Appollinaris Raw	pH OS*	7.50	-	-
11-Jun-25	2412794	TST001	St Appollinaris Raw	Temperature OS*	11.2	-	°C
11-Jun-25	2412796	TST001	St Appollinaris Raw	Turbidity	14.0	±6.1%	NTU
11-Jun-25	2412809	TUN001	Underberg Raw	Al (AE)	368	±7.6%	µg Al/L
11-Jun-25	2412806	TUN001	Underberg Raw	Coliforms*	>2420	±22%	MPN/100mL
11-Jun-25	2412806	TUN001	Underberg Raw	Coliphages*	117	±8%	PFU/10ml
11-Jun-25	2412805	TUN001	Underberg Raw	Coll Time OS*	11:14	-	-
11-Jun-25	2412808	TUN001	Underberg Raw	Conductivity	6.86	±1.5%	mS/m
11-Jun-25	2412806	TUN001	Underberg Raw	E.coli*	>2420	±21%	MPN/100mL
11-Jun-25	2412805	TUN001	Underberg Raw	pH OS*	7.10	-	-
11-Jun-25	2412805	TUN001	Underberg Raw	Temperature OS*	10.3	-	°C
11-Jun-25	2412807	TUN001	Underberg Raw	Turbidity	8.0	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtololo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

12-Jun-25	2413470	TMZ001	Umzimkhulu Raw	Al (AE)	843	±7.6%	µg Al/L
12-Jun-25	2413467	TMZ001	Umzimkhulu Raw	Coliforms*	>2420	±22%	MPN/100mL
12-Jun-25	2413467	TMZ001	Umzimkhulu Raw	Coliphages*	>500	±4%	PFU/10ml
12-Jun-25	2413466	TMZ001	Umzimkhulu Raw	Coll Time OS*	10:30	-	-
12-Jun-25	2413468	TMZ001	Umzimkhulu Raw	Colour	10.0	±6.5%	mg Pt-Co/L
12-Jun-25	2413469	TMZ001	Umzimkhulu Raw	Conductivity	8.30	±1.5%	mS/m
12-Jun-25	2413467	TMZ001	Umzimkhulu Raw	E.coli*	>2420	±21%	MPN/100mL
12-Jun-25	2413470	TMZ001	Umzimkhulu Raw	Fe (AE)	1.26	±5.4%	mg Fe/L
12-Jun-25	2413468	TMZ001	Umzimkhulu Raw	Odour*	Nil	-	-
12-Jun-25	2413466	TMZ001	Umzimkhulu Raw	pH OS*	7.40	-	-
12-Jun-25	2413466	TMZ001	Umzimkhulu Raw	Temperature OS*	14.1	-	°C
12-Jun-25	2413468	TMZ001	Umzimkhulu Raw	Turbidity	63.8	±6.1%	NTU
12-Jun-25	2413483	TNO001	Nokweja Raw	Al (AE)	1034	±7.6%	µg Al/L
12-Jun-25	2413480	TNO001	Nokweja Raw	Coliforms*	>2420	±22%	MPN/100mL
12-Jun-25	2413480	TNO001	Nokweja Raw	Coliphages*	>500	±4%	PFU/10ml
12-Jun-25	2413479	TNO001	Nokweja Raw	Coll Time OS*	09:00	-	-
12-Jun-25	2413481	TNO001	Nokweja Raw	Colour	13.7	±6.5%	mg Pt-Co/L
12-Jun-25	2413482	TNO001	Nokweja Raw	Conductivity	7.09	±1.5%	mS/m
12-Jun-25	2413480	TNO001	Nokweja Raw	E.coli*	>2420	±21%	MPN/100mL
12-Jun-25	2413483	TNO001	Nokweja Raw	Fe (AE)	1.97	±5.4%	mg Fe/L
12-Jun-25	2413481	TNO001	Nokweja Raw	Odour*	Mild Earthy	-	-
12-Jun-25	2413479	TNO001	Nokweja Raw	pH OS*	7.50	-	-
12-Jun-25	2413479	TNO001	Nokweja Raw	Temperature OS*	12.5	-	°C
12-Jun-25	2413481	TNO001	Nokweja Raw	Turbidity	117.0	±6.1%	NTU
12-Jun-25	2412206	TQU001	Mnqumeni Raw	Coliforms*	261	±22%	MPN/100mL
12-Jun-25	2412205	TQU001	Mnqumeni Raw	Coll Time OS*	07:53	-	-
12-Jun-25	2412208	TQU001	Mnqumeni Raw	Conductivity	25.8	±1.5%	mS/m
12-Jun-25	2412206	TQU001	Mnqumeni Raw	E.coli*	4	±21%	MPN/100mL
12-Jun-25	2412205	TQU001	Mnqumeni Raw	pH OS*	7.10	-	-
12-Jun-25	2412205	TQU001	Mnqumeni Raw	Temperature OS*	12.4	-	°C
12-Jun-25	2412207	TQU001	Mnqumeni Raw	Turbidity	14.9	±6.1%	NTU
17-Jun-25	2416493	TSQ001	Esiqanduleni Raw	Al (AE)	213	±7.6%	µg Al/L
17-Jun-25	2416490	TSQ001	Esiqanduleni Raw	Coliforms*	613	±22%	MPN/100mL
17-Jun-25	2416490	TSQ001	Esiqanduleni Raw	Coliphages*	6	±8%	PFU/10ml
17-Jun-25	2416489	TSQ001	Esiqanduleni Raw	Coll Time OS*	07:00	-	-
17-Jun-25	2416492	TSQ001	Esiqanduleni Raw	Conductivity	15.6	±1.5%	mS/m
17-Jun-25	2416490	TSQ001	Esiqanduleni Raw	E.coli*	43	±21%	MPN/100mL
17-Jun-25	2416489	TSQ001	Esiqanduleni Raw	pH OS*	7.40	-	-
17-Jun-25	2416489	TSQ001	Esiqanduleni Raw	Temperature OS*	15.2	-	°C
17-Jun-25	2416491	TSQ001	Esiqanduleni Raw	Turbidity	4.1	±6.1%	NTU
18-Jun-25	2417099	TBU001	Bulwer Raw	Al (AE)	272	±7.6%	µg Al/L
18-Jun-25	2417096	TBU001	Bulwer Raw	Coliforms*	613	±22%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

18-Jun-25	2417095	TBU001	Bulwer Raw	Coll Time OS*	09:24	-	-
18-Jun-25	2417097	TBU001	Bulwer Raw	Colour	2.00	±6.5%	mg Pt-Co/L
18-Jun-25	2417098	TBU001	Bulwer Raw	Conductivity	5.67	±1.5%	mS/m
18-Jun-25	2417096	TBU001	Bulwer Raw	E.coli*	23	±21%	MPN/100mL
18-Jun-25	2417097	TBU001	Bulwer Raw	Odour*	Nil	-	-
18-Jun-25	2417095	TBU001	Bulwer Raw	pH OS*	7.20	-	-
18-Jun-25	2417095	TBU001	Bulwer Raw	Temperature OS*	13.1	-	°C
18-Jun-25	2417097	TBU001	Bulwer Raw	Turbidity	4.4	±6.1%	NTU
18-Jun-25	2417113	TCR001	Creighton Raw	Al (AE)	146	±7.6%	µg Al/L
18-Jun-25	2417110	TCR001	Creighton Raw	Coliforms*	26	±22%	MPN/100mL
18-Jun-25	2417109	TCR001	Creighton Raw	Coll Time OS*	07:45	-	-
18-Jun-25	2417111	TCR001	Creighton Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
18-Jun-25	2417112	TCR001	Creighton Raw	Conductivity	7.35	±1.5%	mS/m
18-Jun-25	2417110	TCR001	Creighton Raw	E.coli*	1	±21%	MPN/100mL
18-Jun-25	2417109	TCR001	Creighton Raw	pH OS*	7.40	-	-
18-Jun-25	2417109	TCR001	Creighton Raw	Temperature OS*	12.0	-	°C
18-Jun-25	2417111	TCR001	Creighton Raw	Turbidity	2.0	±6.1%	NTU
18-Jun-25	2417130	THL001	Hlanganani Raw	Coliforms*	299	±22%	MPN/100mL
18-Jun-25	2417129	THL001	Hlanganani Raw	Coll Time OS*	10:07	-	-
18-Jun-25	2417132	THL001	Hlanganani Raw	Conductivity	10.3	±1.5%	mS/m
18-Jun-25	2417130	THL001	Hlanganani Raw	E.coli*	39	±21%	MPN/100mL
18-Jun-25	2417129	THL001	Hlanganani Raw	pH OS*	7.10	-	-
18-Jun-25	2417129	THL001	Hlanganani Raw	Temperature OS*	15.5	-	°C
18-Jun-25	2417131	THL001	Hlanganani Raw	Turbidity	4.9	±6.1%	NTU
18-Jun-25	2417161	TMQA001	Mqatsheni Raw	Coliforms*	0	±22%	MPN/100mL
18-Jun-25	2417160	TMQA001	Mqatsheni Raw	Coll Time OS*	10:12	-	-
18-Jun-25	2417162	TMQA001	Mqatsheni Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
18-Jun-25	2417163	TMQA001	Mqatsheni Raw	Conductivity	27.8	±1.5%	mS/m
18-Jun-25	2417161	TMQA001	Mqatsheni Raw	E.coli*	0	±21%	MPN/100mL
18-Jun-25	2417162	TMQA001	Mqatsheni Raw	Odour*	Nil	-	-
18-Jun-25	2417160	TMQA001	Mqatsheni Raw	pH OS*	8.30	-	-
18-Jun-25	2417160	TMQA001	Mqatsheni Raw	Temperature OS*	14.5	-	°C
18-Jun-25	2417162	TMQA001	Mqatsheni Raw	Turbidity	0.4	±6.1%	NTU
18-Jun-25	2417192	TST001	St Appollinaris Raw	Al (AE)	228	±7.6%	µg Al/L
18-Jun-25	2417189	TST001	St Appollinaris Raw	Coliforms*	488	±22%	MPN/100mL
18-Jun-25	2417188	TST001	St Appollinaris Raw	Coll Time OS*	08:43	-	-
18-Jun-25	2417191	TST001	St Appollinaris Raw	Conductivity	8.01	±1.5%	mS/m
18-Jun-25	2417189	TST001	St Appollinaris Raw	E.coli*	45	±21%	MPN/100mL
18-Jun-25	2417188	TST001	St Appollinaris Raw	pH OS*	7.30	-	-
18-Jun-25	2417188	TST001	St Appollinaris Raw	Temperature OS*	12.7	-	°C
18-Jun-25	2417190	TST001	St Appollinaris Raw	Turbidity	3.4	±6.1%	NTU
18-Jun-25	2417203	TUN001	Underberg Raw	Al (AE)	49.8	±7.6%	µg Al/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtololo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

18-Jun-25	2417200	TUN001	Underberg Raw	Coliforms*	236	±22%	MPN/100mL
18-Jun-25	2417200	TUN001	Underberg Raw	Coliphages*	6	±8%	PFU/10ml
18-Jun-25	2417199	TUN001	Underberg Raw	Coll Time OS*	08:26	-	-
18-Jun-25	2417202	TUN001	Underberg Raw	Conductivity	6.81	±1.5%	mS/m
18-Jun-25	2417200	TUN001	Underberg Raw	E.coli*	66	±21%	MPN/100mL
18-Jun-25	2417199	TUN001	Underberg Raw	pH OS*	7.10	-	-
18-Jun-25	2417199	TUN001	Underberg Raw	Temperature OS*	10.3	-	°C
18-Jun-25	2417201	TUN001	Underberg Raw	Turbidity	1.2	±6.1%	NTU
19-Jun-25	2417822	TMZ001	Umzimkhulu Raw	Al (AE)	669	±7.6%	µg Al/L
19-Jun-25	2417819	TMZ001	Umzimkhulu Raw	Coliforms*	727	±22%	MPN/100mL
19-Jun-25	2417819	TMZ001	Umzimkhulu Raw	Coliphages*	26	±8%	PFU/10ml
19-Jun-25	2417818	TMZ001	Umzimkhulu Raw	Coll Time OS*	08.36	-	-
19-Jun-25	2417821	TMZ001	Umzimkhulu Raw	Conductivity	9.81	±1.5%	mS/m
19-Jun-25	2417819	TMZ001	Umzimkhulu Raw	E.coli*	41	±21%	MPN/100mL
19-Jun-25	2417818	TMZ001	Umzimkhulu Raw	pH OS*	7.10	-	-
19-Jun-25	2417818	TMZ001	Umzimkhulu Raw	Temperature OS*	12.4	-	°C
19-Jun-25	2417820	TMZ001	Umzimkhulu Raw	Turbidity	12.4	±6.1%	NTU
19-Jun-25	2417853	TNO001	Nokweja Raw	Al (AE)	718	±7.6%	µg Al/L
19-Jun-25	2417850	TNO001	Nokweja Raw	Coliforms*	>2420	±22%	MPN/100mL
19-Jun-25	2417850	TNO001	Nokweja Raw	Coliphages*	95	±8%	PFU/10ml
19-Jun-25	2417849	TNO001	Nokweja Raw	Coll Time OS*	09:07	-	-
19-Jun-25	2417852	TNO001	Nokweja Raw	Conductivity	9.39	±1.5%	mS/m
19-Jun-25	2417850	TNO001	Nokweja Raw	E.coli*	921	±21%	MPN/100mL
19-Jun-25	2417849	TNO001	Nokweja Raw	pH OS*	7.40	-	-
19-Jun-25	2417849	TNO001	Nokweja Raw	Temperature OS*	16.0	-	°C
19-Jun-25	2417851	TNO001	Nokweja Raw	Turbidity	11.9	±6.1%	NTU
19-Jun-25	2417874	TWA001	Washbank Raw	Al (AE)	298	±7.6%	µg Al/L
19-Jun-25	2417871	TWA001	Washbank Raw	Coliforms*	>2420	±22%	MPN/100mL
19-Jun-25	2417870	TWA001	Washbank Raw	Coll Time OS*	07:28	-	-
19-Jun-25	2417872	TWA001	Washbank Raw	Colour	3.40	±6.5%	mg Pt-Co/L
19-Jun-25	2417873	TWA001	Washbank Raw	Conductivity	7.01	±1.5%	mS/m
19-Jun-25	2417871	TWA001	Washbank Raw	E.coli*	6	±21%	MPN/100mL
19-Jun-25	2417870	TWA001	Washbank Raw	pH OS*	7.30	-	-
19-Jun-25	2417870	TWA001	Washbank Raw	Temperature OS*	11.7	-	°C
19-Jun-25	2417872	TWA001	Washbank Raw	Turbidity	13.1	±6.1%	NTU
20-Jun-25	2416387	TFR001	Franklin Raw	Al (AE)	289	±7.6%	µg Al/L
20-Jun-25	2416384	TFR001	Franklin Raw	Coliforms*	>2420	±22%	MPN/100mL
20-Jun-25	2416384	TFR001	Franklin Raw	Coliphages*	21	±8%	PFU/10ml
20-Jun-25	2416383	TFR001	Franklin Raw	Coll Time OS*	08:14	-	-
20-Jun-25	2416386	TFR001	Franklin Raw	Conductivity	11.4	±1.5%	mS/m
20-Jun-25	2416384	TFR001	Franklin Raw	E.coli*	435	±21%	MPN/100mL
20-Jun-25	2416383	TFR001	Franklin Raw	pH OS*	7.00	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

20-Jun-25	2416383	TFR001	Franklin Raw	Temperature OS*	9.5	-	°C
20-Jun-25	2416385	TFR001	Franklin Raw	Turbidity	22.9	±6.1%	NTU
20-Jun-25	2418173	TIB001	Ibisi Raw	Al (AE)	367	±7.6%	µg Al/L
20-Jun-25	2418170	TIB001	Ibisi Raw	Coliforms*	1203	±22%	MPN/100mL
20-Jun-25	2418170	TIB001	Ibisi Raw	Coliphages*	10	±8%	PFU/10ml
20-Jun-25	2418169	TIB001	Ibisi Raw	Coll Time OS*	07:05	-	-
20-Jun-25	2418172	TIB001	Ibisi Raw	Conductivity	8.89	±1.5%	mS/m
20-Jun-25	2418170	TIB001	Ibisi Raw	E.coli*	73	±21%	MPN/100mL
20-Jun-25	2418169	TIB001	Ibisi Raw	pH OS*	7.30	-	-
20-Jun-25	2418169	TIB001	Ibisi Raw	Temperature OS*	10.5	-	°C
20-Jun-25	2418171	TIB001	Ibisi Raw	Turbidity	19.4	±6.1%	NTU
20-Jun-25	2415829	TKK001	Kokstad River Raw	Al (AE)	425	±7.6%	µg Al/L
20-Jun-25	2415826	TKK001	Kokstad River Raw	Coliforms*	0	±22%	MPN/100mL
20-Jun-25	2415826	TKK001	Kokstad River Raw	Coliphages*	0	±8%	PFU/10ml
20-Jun-25	2415825	TKK001	Kokstad River Raw	Coll Time OS*	08:55	-	-
20-Jun-25	2415828	TKK001	Kokstad River Raw	Conductivity	8.59	±1.5%	mS/m
20-Jun-25	2415826	TKK001	Kokstad River Raw	E.coli*	0	±21%	MPN/100mL
20-Jun-25	2415825	TKK001	Kokstad River Raw	pH OS*	7.30	-	-
20-Jun-25	2415825	TKK001	Kokstad River Raw	Temperature OS*	13.9	-	°C
20-Jun-25	2415827	TKK001	Kokstad River Raw	Turbidity	13.2	±6.1%	NTU
20-Jun-25	2415840	TKK003	Kokstad Crystal Spring Raw	Al (AE)	227	±7.6%	µg Al/L
20-Jun-25	2415837	TKK003	Kokstad Crystal Spring Raw	Coliforms*	1203	±22%	MPN/100mL
20-Jun-25	2415837	TKK003	Kokstad Crystal Spring Raw	Coliphages*	0	±8%	PFU/10ml
20-Jun-25	2415836	TKK003	Kokstad Crystal Spring Raw	Coll Time OS*	09:00	-	-
20-Jun-25	2415839	TKK003	Kokstad Crystal Spring Raw	Conductivity	8.11	±1.5%	mS/m
20-Jun-25	2415837	TKK003	Kokstad Crystal Spring Raw	E.coli*	6	±21%	MPN/100mL
20-Jun-25	2415836	TKK003	Kokstad Crystal Spring Raw	pH OS*	7.20	-	-
20-Jun-25	2415836	TKK003	Kokstad Crystal Spring Raw	Temperature OS*	12.2	-	°C
20-Jun-25	2415838	TKK003	Kokstad Crystal Spring Raw	Turbidity	12.7	±6.1%	NTU
23-Jun-25	2419848	TFR001	Franklin Raw	Al (AE)	2856	±7.6%	µg Al/L
23-Jun-25	2419845	TFR001	Franklin Raw	Coliforms*	>2420	±22%	MPN/100mL
23-Jun-25	2419845	TFR001	Franklin Raw	Coliphages*	66	±8%	PFU/10ml
23-Jun-25	2419844	TFR001	Franklin Raw	Coll Time OS*	08:31	-	-
23-Jun-25	2419846	TFR001	Franklin Raw	Colour	30.1	±6.5%	mg Pt-Co/L
23-Jun-25	2419847	TFR001	Franklin Raw	Conductivity	11.2	±1.5%	mS/m
23-Jun-25	2419845	TFR001	Franklin Raw	E.coli*	261	±21%	MPN/100mL
23-Jun-25	2419848	TFR001	Franklin Raw	Fe (AE)	1.69	±5.4%	mg Fe/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

23-Jun-25	2419848	TFR001	Franklin Raw	Mn (AE)	<0.01	±6.2%	mg Mn/L
23-Jun-25	2419846	TFR001	Franklin Raw	Odour*	Nil	-	-
23-Jun-25	2419844	TFR001	Franklin Raw	pH OS*	8.00	-	-
23-Jun-25	2419844	TFR001	Franklin Raw	Temperature OS*	9.5	-	°C
23-Jun-25	2419846	TFR001	Franklin Raw	Turbidity	25.2	±6.1%	NTU
23-Jun-25	2419868	TKK001	Kokstad River Raw	Al (AE)	512	±7.6%	µg Al/L
23-Jun-25	2419865	TKK001	Kokstad River Raw	Coliforms*	0	±22%	MPN/100mL
23-Jun-25	2419865	TKK001	Kokstad River Raw	Coliphages*	0	±8%	PFU/10ml
23-Jun-25	2419864	TKK001	Kokstad River Raw	Coll Time OS*	09:02	-	-
23-Jun-25	2419867	TKK001	Kokstad River Raw	Conductivity	8.31	±1.5%	mS/m
23-Jun-25	2419865	TKK001	Kokstad River Raw	E.coli*	0	±21%	MPN/100mL
23-Jun-25	2419864	TKK001	Kokstad River Raw	pH OS*	7.20	-	-
23-Jun-25	2419864	TKK001	Kokstad River Raw	Temperature OS*	15.2	-	°C
23-Jun-25	2419866	TKK001	Kokstad River Raw	Turbidity	10.7	±6.1%	NTU
23-Jun-25	2419879	TKK003	Kokstad Crystal Spring Raw	Al (AE)	146	±7.6%	µg Al/L
23-Jun-25	2419876	TKK003	Kokstad Crystal Spring Raw	Coliforms*	225	±22%	MPN/100mL
23-Jun-25	2419876	TKK003	Kokstad Crystal Spring Raw	Coliphages*	0	±8%	PFU/10ml
23-Jun-25	2419875	TKK003	Kokstad Crystal Spring Raw	Coll Time OS*	09:20	-	-
23-Jun-25	2419878	TKK003	Kokstad Crystal Spring Raw	Conductivity	7.82	±1.5%	mS/m
23-Jun-25	2419876	TKK003	Kokstad Crystal Spring Raw	E.coli*	4	±21%	MPN/100mL
23-Jun-25	2419875	TKK003	Kokstad Crystal Spring Raw	pH OS*	7.10	-	-
23-Jun-25	2419875	TKK003	Kokstad Crystal Spring Raw	Temperature OS*	14.0	-	°C
23-Jun-25	2419877	TKK003	Kokstad Crystal Spring Raw	Turbidity	10.6	±6.1%	NTU
24-Jun-25	2420416	TQU001	Mnqumeni Raw	Coliforms*	1120	±22%	MPN/100mL
24-Jun-25	2420415	TQU001	Mnqumeni Raw	Coll Time OS*	08:25	-	-
24-Jun-25	2420418	TQU001	Mnqumeni Raw	Conductivity	11.6	±1.5%	mS/m
24-Jun-25	2420416	TQU001	Mnqumeni Raw	E.coli*	60	±21%	MPN/100mL
24-Jun-25	2420415	TQU001	Mnqumeni Raw	pH OS*	7.20	-	-
24-Jun-25	2420415	TQU001	Mnqumeni Raw	Temperature OS*	13.4	-	°C
24-Jun-25	2420417	TQU001	Mnqumeni Raw	Turbidity	10.0	±6.1%	NTU
24-Jun-25	2420428	TSQ001	Esiqanduleni Raw	Al (AE)	103	±7.6%	µg Al/L
24-Jun-25	2420425	TSQ001	Esiqanduleni Raw	Coliforms*	488	±22%	MPN/100mL
24-Jun-25	2420425	TSQ001	Esiqanduleni Raw	Coliphages*	1	±8%	PFU/10ml
24-Jun-25	2420424	TSQ001	Esiqanduleni Raw	Coll Time OS*	08:40	-	-
24-Jun-25	2420427	TSQ001	Esiqanduleni Raw	Conductivity	16.7	±1.5%	mS/m
24-Jun-25	2420425	TSQ001	Esiqanduleni Raw	E.coli*	17	±21%	MPN/100mL
24-Jun-25	2420424	TSQ001	Esiqanduleni Raw	pH OS*	7.50	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

24-Jun-25	2420424	TSQ001	Esiqanduleni Raw	Temperature OS*	12.1	-	°C
24-Jun-25	2420426	TSQ001	Esiqanduleni Raw	Turbidity	2.2	±6.1%	NTU
25-Jun-25	2420889	TBU001	Bulwer Raw	AI (AE)	286	±7.6%	µg AI/L
25-Jun-25	2420886	TBU001	Bulwer Raw	Coliforms*	980	±22%	MPN/100mL
25-Jun-25	2420885	TBU001	Bulwer Raw	Coll Time OS*	10:20	-	-
25-Jun-25	2420887	TBU001	Bulwer Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
25-Jun-25	2420888	TBU001	Bulwer Raw	Conductivity	5.85	±1.5%	mS/m
25-Jun-25	2420886	TBU001	Bulwer Raw	E.coli*	32	±21%	MPN/100mL
25-Jun-25	2420885	TBU001	Bulwer Raw	pH OS*	7.30	-	-
25-Jun-25	2420885	TBU001	Bulwer Raw	Temperature OS*	14.5	-	°C
25-Jun-25	2420887	TBU001	Bulwer Raw	Turbidity	5.4	±6.1%	NTU
25-Jun-25	2420899	TCR001	Creighton Raw	AI (AE)	90.3	±7.6%	µg AI/L
25-Jun-25	2420896	TCR001	Creighton Raw	Coliforms*	20	±22%	MPN/100mL
25-Jun-25	2420895	TCR001	Creighton Raw	Coll Time OS*	08:06	-	-
25-Jun-25	2420897	TCR001	Creighton Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
25-Jun-25	2420898	TCR001	Creighton Raw	Conductivity	7.72	±1.5%	mS/m
25-Jun-25	2420896	TCR001	Creighton Raw	E.coli*	1	±21%	MPN/100mL
25-Jun-25	2420895	TCR001	Creighton Raw	pH OS*	7.30	-	-
25-Jun-25	2420895	TCR001	Creighton Raw	Temperature OS*	11.0	-	°C
25-Jun-25	2420897	TCR001	Creighton Raw	Turbidity	1.1	±6.1%	NTU
25-Jun-25	2420907	THL001	Hlanganani Raw	Coliforms*	344	±22%	MPN/100mL
25-Jun-25	2420906	THL001	Hlanganani Raw	Coll Time OS*	11:00	-	-
25-Jun-25	2420909	THL001	Hlanganani Raw	Conductivity	9.30	±1.5%	mS/m
25-Jun-25	2420907	THL001	Hlanganani Raw	E.coli*	33	±21%	MPN/100mL
25-Jun-25	2420906	THL001	Hlanganani Raw	pH OS*	7.30	-	-
25-Jun-25	2420906	THL001	Hlanganani Raw	Temperature OS*	16.2	-	°C
25-Jun-25	2420908	THL001	Hlanganani Raw	Turbidity	4.6	±6.1%	NTU
25-Jun-25	2420921	TMAN001	Mangwaneni Raw	Coliforms*	649	±22%	MPN/100mL
25-Jun-25	2420920	TMAN001	Mangwaneni Raw	Coll Time OS*	11:12	-	-
25-Jun-25	2420922	TMAN001	Mangwaneni Raw	Colour	4.30	±6.5%	mg Pt-Co/L
25-Jun-25	2420923	TMAN001	Mangwaneni Raw	Conductivity	9.88	±1.5%	mS/m
25-Jun-25	2420921	TMAN001	Mangwaneni Raw	E.coli*	29	±21%	MPN/100mL
25-Jun-25	2420920	TMAN001	Mangwaneni Raw	pH OS*	7.30	-	-
25-Jun-25	2420920	TMAN001	Mangwaneni Raw	Temperature OS*	12.0	-	°C
25-Jun-25	2420922	TMAN001	Mangwaneni Raw	Turbidity	2.8	±6.1%	NTU
25-Jun-25	2420930	TMQA001	Mqatsheni Raw	Coliforms*	2	±22%	MPN/100mL
25-Jun-25	2420929	TMQA001	Mqatsheni Raw	Coll Time OS*	09:22	-	-
25-Jun-25	2420931	TMQA001	Mqatsheni Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
25-Jun-25	2420932	TMQA001	Mqatsheni Raw	Conductivity	28.2	±1.5%	mS/m
25-Jun-25	2420930	TMQA001	Mqatsheni Raw	E.coli*	0	±21%	MPN/100mL
25-Jun-25	2420929	TMQA001	Mqatsheni Raw	pH OS*	8.70	-	-
25-Jun-25	2420929	TMQA001	Mqatsheni Raw	Temperature OS*	14.1	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolu | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

25-Jun-25	2420931	TMQA001	Mqatsheni Raw	Turbidity	0.5	±6.1%	NTU
25-Jun-25	2420942	TRV001	Riversside Raw	Al (AE)	3320	±7.6%	µg Al/L
25-Jun-25	2420939	TRV001	Riversside Raw	Coliforms*	82	±22%	MPN/100mL
25-Jun-25	2420938	TRV001	Riversside Raw	Coll Time OS*	08:45	-	-
25-Jun-25	2420940	TRV001	Riversside Raw	Colour	4.90	±6.5%	mg Pt-Co/L
25-Jun-25	2420941	TRV001	Riversside Raw	Conductivity	7.95	±1.5%	mS/m
25-Jun-25	2420939	TRV001	Riversside Raw	E.coli*	7	±21%	MPN/100mL
25-Jun-25	2420938	TRV001	Riversside Raw	pH OS*	7.20	-	-
25-Jun-25	2420938	TRV001	Riversside Raw	Temperature OS*	11.9	-	°C
25-Jun-25	2420940	TRV001	Riversside Raw	Turbidity	7.3	±6.1%	NTU
25-Jun-25	2420953	TST001	St Appollinaris Raw	Al (AE)	156	±7.6%	µg Al/L
25-Jun-25	2420950	TST001	St Appollinaris Raw	Coliforms*	411	±22%	MPN/100mL
25-Jun-25	2420949	TST001	St Appollinaris Raw	Coll Time OS*	09:43	-	-
25-Jun-25	2420952	TST001	St Appollinaris Raw	Conductivity	8.39	±1.5%	mS/m
25-Jun-25	2420950	TST001	St Appollinaris Raw	E.coli*	35	±21%	MPN/100mL
25-Jun-25	2420949	TST001	St Appollinaris Raw	pH OS*	7.10	-	-
25-Jun-25	2420949	TST001	St Appollinaris Raw	Temperature OS*	13.3	-	°C
25-Jun-25	2420951	TST001	St Appollinaris Raw	Turbidity	2.5	±6.1%	NTU
25-Jun-25	2420964	TUN001	Underberg Raw	Al (AE)	48.9	±7.6%	µg Al/L
25-Jun-25	2420961	TUN001	Underberg Raw	Coliforms*	980	±22%	MPN/100mL
25-Jun-25	2420961	TUN001	Underberg Raw	Coliphages*	23	±8%	PFU/10ml
25-Jun-25	2420960	TUN001	Underberg Raw	Coll Time OS*	10:01	-	-
25-Jun-25	2420963	TUN001	Underberg Raw	Conductivity	7.41	±1.5%	mS/m
25-Jun-25	2420961	TUN001	Underberg Raw	E.coli*	55	±21%	MPN/100mL
25-Jun-25	2420960	TUN001	Underberg Raw	pH OS*	7.50	-	-
25-Jun-25	2420960	TUN001	Underberg Raw	Temperature OS*	10.3	-	°C
25-Jun-25	2420962	TUN001	Underberg Raw	Turbidity	1.2	±6.1%	NTU
26-Jun-25	2421585	TMZ001	Umzimkhulu Raw	Al (AE)	430	±7.6%	µg Al/L
26-Jun-25	2421582	TMZ001	Umzimkhulu Raw	Coliforms*	687	±22%	MPN/100mL
26-Jun-25	2421582	TMZ001	Umzimkhulu Raw	Coliphages*	27	±8%	PFU/10ml
26-Jun-25	2421581	TMZ001	Umzimkhulu Raw	Coll Time OS*	08:01	-	-
26-Jun-25	2421584	TMZ001	Umzimkhulu Raw	Conductivity	9.91	±1.5%	mS/m
26-Jun-25	2421582	TMZ001	Umzimkhulu Raw	E.coli*	47	±21%	MPN/100mL
26-Jun-25	2421581	TMZ001	Umzimkhulu Raw	pH OS*	7.20	-	-
26-Jun-25	2421581	TMZ001	Umzimkhulu Raw	Temperature OS*	12.3	-	°C
26-Jun-25	2421583	TMZ001	Umzimkhulu Raw	Turbidity	8.1	±6.1%	NTU
26-Jun-25	2421596	TNO001	Nokweja Raw	Al (AE)	463	±7.6%	µg Al/L
26-Jun-25	2421593	TNO001	Nokweja Raw	Coliforms*	>2420	±22%	MPN/100mL
26-Jun-25	2421593	TNO001	Nokweja Raw	Coliphages*	93	±8%	PFU/10ml
26-Jun-25	2421592	TNO001	Nokweja Raw	Coll Time OS*	08:35	-	-
26-Jun-25	2421595	TNO001	Nokweja Raw	Conductivity	10.1	±1.5%	mS/m
26-Jun-25	2421593	TNO001	Nokweja Raw	E.coli*	2420	±21%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

26-Jun-25	2421592	TNO001	Nokweja Raw	pH OS*	7.40	-	-
26-Jun-25	2421592	TNO001	Nokweja Raw	Temperature OS*	11.4	-	°C
26-Jun-25	2421594	TNO001	Nokweja Raw	Turbidity	7.3	±6.1%	NTU
26-Jun-25	2421607	TWA001	Washbank Raw	Al (AE)	244	±7.6%	µg Al/L
26-Jun-25	2421604	TWA001	Washbank Raw	Coliforms*	1120	±22%	MPN/100mL
26-Jun-25	2421603	TWA001	Washbank Raw	Coll Time OS*	07:20	-	-
26-Jun-25	2421606	TWA001	Washbank Raw	Conductivity	6.65	±1.5%	mS/m
26-Jun-25	2421604	TWA001	Washbank Raw	E.coli*	10	±21%	MPN/100mL
26-Jun-25	2421603	TWA001	Washbank Raw	pH OS*	7.20	-	-
26-Jun-25	2421603	TWA001	Washbank Raw	Temperature OS*	11.4	-	°C
26-Jun-25	2421605	TWA001	Washbank Raw	Turbidity	9.6	±6.1%	NTU
27-Jun-25	2421819	TIB001	Ibisi Raw	Al (AE)	322	±7.6%	µg Al/L
27-Jun-25	2421816	TIB001	Ibisi Raw	Coliforms*	980	±22%	MPN/100mL
27-Jun-25	2421816	TIB001	Ibisi Raw	Coliphages*	6	±8%	PFU/10ml
27-Jun-25	2421815	TIB001	Ibisi Raw	Coll Time OS*	07:15	-	-
27-Jun-25	2421818	TIB001	Ibisi Raw	Conductivity	9.37	±1.5%	mS/m
27-Jun-25	2421816	TIB001	Ibisi Raw	E.coli*	59	±21%	MPN/100mL
27-Jun-25	2421815	TIB001	Ibisi Raw	pH OS*	7.50	-	-
27-Jun-25	2421815	TIB001	Ibisi Raw	Temperature OS*	11.2	-	°C
27-Jun-25	2421817	TIB001	Ibisi Raw	Turbidity	13.6	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)