

Date: 08 April 2025

The Executive Director: Water Services Department

Harry Gwala District Municipality

40 Main Street

Ixopo

3276

Attention: Basetsana Khathalib and Bheki Nene

MARCH 2025 TREATED WATER (FINAL) RESULTS

Please find March 2025 Treated Water (Final) results tabulated below for samples received during March 2025. Determinands marked with an asterisk are unaccredited and are not included in uMngeni-uThukela Water's schedule of accreditation.

Please contact us immediately should you have any queries.

Yours' Sincerely

Mr M Sewcharan

Client Services Manager

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

Sample Date	Sample Number	Sampling Point	Description	Determinand	Result	UOM	Unit
03-Mar-25	2353916	TFR002	Franklin Final	Al (AE)	171	±7.6%	µg Al/L
03-Mar-25	2353911	TFR002	Franklin Final	Batch No.*	6241	-	-
03-Mar-25	2353911	TFR002	Franklin Final	Cl ₂ (F) OS*	0.90	-	mg Cl ₂ /L
03-Mar-25	2353911	TFR002	Franklin Final	Cl ₂ (T) OS*	0.98	-	mg Cl ₂ /L
03-Mar-25	2353912	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
03-Mar-25	2353912	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml
03-Mar-25	2353911	TFR002	Franklin Final	Coll Time OS*	07:31	-	-
03-Mar-25	2353915	TFR002	Franklin Final	Conductivity	13.7	±1.5%	mS/m
03-Mar-25	2353912	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
03-Mar-25	2353912	TFR002	Franklin Final	HPC 37*	0	±21%	cfu/mL
03-Mar-25	2353911	TFR002	Franklin Final	pH OS*	7.30	-	-
03-Mar-25	2353911	TFR002	Franklin Final	Temperature OS*	19.0	-	°C
03-Mar-25	2353914	TFR002	Franklin Final	Turbidity	1.4	±6.1%	NTU
03-Mar-25	2353982	TNJU002	KwaNjunga Final	Al (AE)	353	±7.6%	µg Al/L
03-Mar-25	2353977	TNJU002	KwaNjunga Final	Batch No.*	6241	-	-
03-Mar-25	2353977	TNJU002	KwaNjunga Final	Cl ₂ (F) OS*	<0.05	-	mg Cl ₂ /L
03-Mar-25	2353977	TNJU002	KwaNjunga Final	Cl ₂ (T) OS*	0.05	-	mg Cl ₂ /L
03-Mar-25	2353978	TNJU002	KwaNjunga Final	Coliforms*	>201	±15%	MPN/100mL
03-Mar-25	2353977	TNJU002	KwaNjunga Final	Coll Time OS*	06:39	-	-
03-Mar-25	2353981	TNJU002	KwaNjunga Final	Conductivity	12.1	±1.5%	mS/m
03-Mar-25	2353978	TNJU002	KwaNjunga Final	E.coli*	8	±14%	MPN/100mL
03-Mar-25	2353982	TNJU002	KwaNjunga Final	Fe (AE)	0.20	±5.4%	mg Fe/L
03-Mar-25	2353978	TNJU002	KwaNjunga Final	HPC 37*	108	±21%	cfu/mL
03-Mar-25	2353982	TNJU002	KwaNjunga Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
03-Mar-25	2353980	TNJU002	KwaNjunga Final	Odour*	Nil	-	-
03-Mar-25	2353977	TNJU002	KwaNjunga Final	pH OS*	7.40	-	-
03-Mar-25	2353977	TNJU002	KwaNjunga Final	Temperature OS*	17.7	-	°C
03-Mar-25	2353980	TNJU002	KwaNjunga Final	Turbidity	4.9	±6.1%	NTU
04-Mar-25	2356423	TQU002	Mnqumeni Final	Al (AE)	<25.0	±7.6%	µg Al/L
04-Mar-25	2356418	TQU002	Mnqumeni Final	Batch No.*	6241	-	-
04-Mar-25	2356418	TQU002	Mnqumeni Final	Cl ₂ (F) OS*	0.16	-	mg Cl ₂ /L
04-Mar-25	2356418	TQU002	Mnqumeni Final	Cl ₂ (T) OS*	0.25	-	mg Cl ₂ /L
04-Mar-25	2356419	TQU002	Mnqumeni Final	Coliforms*	1	±15%	MPN/100mL
04-Mar-25	2356418	TQU002	Mnqumeni Final	Coll Time OS*	07:18	-	-
04-Mar-25	2356422	TQU002	Mnqumeni Final	Conductivity	11.2	±1.5%	mS/m
04-Mar-25	2356419	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
04-Mar-25	2356423	TQU002	Mnqumeni Final	Fe (AE)	<0.02	±5.4%	mg Fe/L
04-Mar-25	2356419	TQU002	Mnqumeni Final	HPC 37*	26	±21%	cfu/mL
04-Mar-25	2356423	TQU002	Mnqumeni Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
04-Mar-25	2356421	TQU002	Mnqumeni Final	Odour*	Nil	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

04-Mar-25	2356418	TQU002	Mnqumeni Final	pH OS*	7.30	-	-
04-Mar-25	2356421	TQU002	Mnqumeni Final	Taste*	Nil	-	-
04-Mar-25	2356418	TQU002	Mnqumeni Final	Temperature OS*	22.7	-	°C
04-Mar-25	2356421	TQU002	Mnqumeni Final	Turbidity	0.3	±6.1%	NTU
04-Mar-25	2356434	TSQ002	Esiqanduleni Final	Al (AE)	200	±7.6%	µg Al/L
04-Mar-25	2356429	TSQ002	Esiqanduleni Final	Batch No.*	6241	-	-
04-Mar-25	2356429	TSQ002	Esiqanduleni Final	Cl ₂ (F) OS*	2.07	-	mg Cl ₂ /L
04-Mar-25	2356429	TSQ002	Esiqanduleni Final	Cl ₂ (T) OS*	2.20	-	mg Cl ₂ /L
04-Mar-25	2356430	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL
04-Mar-25	2356429	TSQ002	Esiqanduleni Final	Coll Time OS*	07:40	-	-
04-Mar-25	2356433	TSQ002	Esiqanduleni Final	Conductivity	9.73	±1.5%	mS/m
04-Mar-25	2356430	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
04-Mar-25	2356434	TSQ002	Esiqanduleni Final	Fe (AE)	0.10	±5.4%	mg Fe/L
04-Mar-25	2356430	TSQ002	Esiqanduleni Final	HPC 37*	5	±21%	cfu/mL
04-Mar-25	2356434	TSQ002	Esiqanduleni Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
04-Mar-25	2356429	TSQ002	Esiqanduleni Final	pH OS*	7.50	-	-
04-Mar-25	2356429	TSQ002	Esiqanduleni Final	Temperature OS*	19.3	-	°C
04-Mar-25	2356432	TSQ002	Esiqanduleni Final	Turbidity	4.1	±6.1%	NTU
05-Mar-25	2354540	TCR002	Creighton Final	Al (AE)	153	±7.6%	µg Al/L
05-Mar-25	2354535	TCR002	Creighton Final	Batch No.*	6241	-	-
05-Mar-25	2354535	TCR002	Creighton Final	Cl ₂ (F) OS*	0.17	-	mg Cl ₂ /L
05-Mar-25	2354535	TCR002	Creighton Final	Cl ₂ (T) OS*	0.28	-	mg Cl ₂ /L
05-Mar-25	2354536	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
05-Mar-25	2354535	TCR002	Creighton Final	Coll Time OS*	07:55	-	-
05-Mar-25	2354538	TCR002	Creighton Final	Colour	2.30	±6.5%	mg Pt-Co/L
05-Mar-25	2354539	TCR002	Creighton Final	Conductivity	22.9	±1.5%	mS/m
05-Mar-25	2354536	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
05-Mar-25	2354540	TCR002	Creighton Final	Fe (AE)	<0.02	±5.4%	mg Fe/L
05-Mar-25	2354536	TCR002	Creighton Final	HPC 37*	2	±21%	cfu/mL
05-Mar-25	2354540	TCR002	Creighton Final	Mn (AE)	<0.01	±6.2%	mg Mn/L
05-Mar-25	2354538	TCR002	Creighton Final	Odour*	Nil	-	-
05-Mar-25	2354535	TCR002	Creighton Final	pH OS*	7.40	-	-
05-Mar-25	2354535	TCR002	Creighton Final	Temperature OS*	20.0	-	°C
05-Mar-25	2354538	TCR002	Creighton Final	Turbidity	1.0	±6.1%	NTU
05-Mar-25	2354545	THL002	Hlanganani Final	Batch No.*	6241	-	-
05-Mar-25	2354545	THL002	Hlanganani Final	Cl ₂ (F) OS*	0.20	-	mg Cl ₂ /L
05-Mar-25	2354545	THL002	Hlanganani Final	Cl ₂ (T) OS*	0.38	-	mg Cl ₂ /L
05-Mar-25	2354546	THL002	Hlanganani Final	Coliforms*	0	±15%	MPN/100mL
05-Mar-25	2354545	THL002	Hlanganani Final	Coll Time OS*	10:16	-	-
05-Mar-25	2354549	THL002	Hlanganani Final	Conductivity	6.76	±1.5%	mS/m
05-Mar-25	2354546	THL002	Hlanganani Final	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

05-Mar-25	2354546	THL002	Hlanganani Final	HPC 37*	5	±21%	cfu/mL
05-Mar-25	2354545	THL002	Hlanganani Final	pH OS*	7.30	-	-
05-Mar-25	2354545	THL002	Hlanganani Final	Temperature OS*	26.0	-	°C
05-Mar-25	2354548	THL002	Hlanganani Final	Turbidity	0.2	±6.1%	NTU
05-Mar-25	2354571	TMQA002	Mqatsheni Final	Batch No.*	6241	-	-
05-Mar-25	2354571	TMQA002	Mqatsheni Final	Cl ₂ (F) OS*	1.40	-	mg Cl ₂ /L
05-Mar-25	2354571	TMQA002	Mqatsheni Final	Cl ₂ (T) OS*	1.59	-	mg Cl ₂ /L
05-Mar-25	2354572	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
05-Mar-25	2354571	TMQA002	Mqatsheni Final	Coll Time OS*	08:07	-	-
05-Mar-25	2354575	TMQA002	Mqatsheni Final	Conductivity	25.2	±1.5%	mS/m
05-Mar-25	2354572	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
05-Mar-25	2354576	TMQA002	Mqatsheni Final	Fe (AE)	0.03	±5.4%	mg Fe/L
05-Mar-25	2354572	TMQA002	Mqatsheni Final	HPC 37*	2	±21%	cfu/mL
05-Mar-25	2354571	TMQA002	Mqatsheni Final	pH OS*	8.90	-	-
05-Mar-25	2354571	TMQA002	Mqatsheni Final	Temperature OS*	21.4	-	°C
05-Mar-25	2354574	TMQA002	Mqatsheni Final	Turbidity	1.3	±6.1%	NTU
05-Mar-25	2354587	TRV002	Riverside Final	Al (AE)	<25.0	±7.6%	µg Al/L
05-Mar-25	2354582	TRV002	Riverside Final	Batch No.*	6241	-	-
05-Mar-25	2354582	TRV002	Riverside Final	Cl ₂ (F) OS*	0.19	-	mg Cl ₂ /L
05-Mar-25	2354582	TRV002	Riverside Final	Cl ₂ (T) OS*	0.32	-	mg Cl ₂ /L
05-Mar-25	2354583	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
05-Mar-25	2354583	TRV002	Riverside Final	Coliphages*	0	±8%	PFU/10ml
05-Mar-25	2354582	TRV002	Riverside Final	Coll Time OS*	08:32	-	-
05-Mar-25	2354586	TRV002	Riverside Final	Conductivity	19.5	±1.5%	mS/m
05-Mar-25	2354583	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
05-Mar-25	2354587	TRV002	Riverside Final	Fe (AE)	<0.02	±5.4%	mg Fe/L
05-Mar-25	2354583	TRV002	Riverside Final	HPC 37*	75	±21%	cfu/mL
05-Mar-25	2354582	TRV002	Riverside Final	pH OS*	7.40	-	-
05-Mar-25	2354582	TRV002	Riverside Final	Temperature OS*	20.0	-	°C
05-Mar-25	2354585	TRV002	Riverside Final	Turbidity	0.6	±6.1%	NTU
05-Mar-25	2354609	TUN002	Underberg Final	Al (AE)	201	±7.6%	µg Al/L
05-Mar-25	2354604	TUN002	Underberg Final	Batch No.*	6241	-	-
05-Mar-25	2354604	TUN002	Underberg Final	Cl ₂ (F) OS*	2.05	-	mg Cl ₂ /L
05-Mar-25	2354604	TUN002	Underberg Final	Cl ₂ (T) OS*	2.15	-	mg Cl ₂ /L
05-Mar-25	2354605	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
05-Mar-25	2354604	TUN002	Underberg Final	Coll Time OS*	09:27	-	-
05-Mar-25	2354608	TUN002	Underberg Final	Conductivity	6.19	±1.5%	mS/m
05-Mar-25	2354605	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
05-Mar-25	2354605	TUN002	Underberg Final	HPC 37*	2	±21%	cfu/mL
05-Mar-25	2354604	TUN002	Underberg Final	pH OS*	7.50	-	-
05-Mar-25	2354604	TUN002	Underberg Final	Temperature OS*	20.4	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

05-Mar-25	2354607	TUN002	Underberg Final	Turbidity	2.2	±6.1%	NTU
06-Mar-25	2355329	TMZ002	Umzimkhulu Final	Al (AE)	397	±7.6%	µg Al/L
06-Mar-25	2355324	TMZ002	Umzimkhulu Final	Batch No.*	6241	-	-
06-Mar-25	2355324	TMZ002	Umzimkhulu Final	Cl2 (F) OS*	1.07	-	mg Cl2/L
06-Mar-25	2355324	TMZ002	Umzimkhulu Final	Cl2 (T) OS*	1.24	-	mg Cl2/L
06-Mar-25	2355325	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
06-Mar-25	2355325	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10ml
06-Mar-25	2355324	TMZ002	Umzimkhulu Final	Coll Time OS*	07:09	-	-
06-Mar-25	2355328	TMZ002	Umzimkhulu Final	Conductivity	7.54	±1.5%	mS/m
06-Mar-25	2355325	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
06-Mar-25	2355325	TMZ002	Umzimkhulu Final	HPC 37*	0	±21%	cfu/mL
06-Mar-25	2355324	TMZ002	Umzimkhulu Final	pH OS*	7.40	-	-
06-Mar-25	2355324	TMZ002	Umzimkhulu Final	Temperature OS*	23.4	-	°C
06-Mar-25	2355327	TMZ002	Umzimkhulu Final	Turbidity	6.2	±6.1%	NTU
06-Mar-25	2355340	TNO002	Nokweja Final	Al (AE)	169	±7.6%	µg Al/L
06-Mar-25	2355335	TNO002	Nokweja Final	Batch No.*	6241	-	-
06-Mar-25	2355335	TNO002	Nokweja Final	Cl2 (F) OS*	1.08	-	mg Cl2/L
06-Mar-25	2355335	TNO002	Nokweja Final	Cl2 (T) OS*	1.26	-	mg Cl2/L
06-Mar-25	2355336	TNO002	Nokweja Final	Coliforms*	0	±15%	MPN/100mL
06-Mar-25	2355336	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10ml
06-Mar-25	2355335	TNO002	Nokweja Final	Coll Time OS*	08:02	-	-
06-Mar-25	2355339	TNO002	Nokweja Final	Conductivity	9.66	±1.5%	mS/m
06-Mar-25	2355336	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
06-Mar-25	2355336	TNO002	Nokweja Final	HPC 37*	7	±21%	cfu/mL
06-Mar-25	2355335	TNO002	Nokweja Final	pH OS*	7.50	-	-
06-Mar-25	2355335	TNO002	Nokweja Final	Temperature OS*	23.4	-	°C
06-Mar-25	2355338	TNO002	Nokweja Final	Turbidity	2.0	±6.1%	NTU
07-Mar-25	2355579	TIB002	Ibisi Final	Al (AE)	276	±7.6%	µg Al/L
07-Mar-25	2355574	TIB002	Ibisi Final	Batch No.*	6241	-	-
07-Mar-25	2355574	TIB002	Ibisi Final	Cl2 (F) OS*	1.94	-	mg Cl2/L
07-Mar-25	2355574	TIB002	Ibisi Final	Cl2 (T) OS*	2.11	-	mg Cl2/L
07-Mar-25	2355575	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
07-Mar-25	2355575	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
07-Mar-25	2355574	TIB002	Ibisi Final	Coll Time OS*	07:05	-	-
07-Mar-25	2355578	TIB002	Ibisi Final	Conductivity	7.41	±1.5%	mS/m
07-Mar-25	2355575	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
07-Mar-25	2355575	TIB002	Ibisi Final	HPC 37*	10	±21%	cfu/mL
07-Mar-25	2355574	TIB002	Ibisi Final	pH OS*	7.50	-	-
07-Mar-25	2355574	TIB002	Ibisi Final	Temperature OS*	22.4	-	°C
07-Mar-25	2355577	TIB002	Ibisi Final	Turbidity	7.3	±6.1%	NTU
10-Mar-25	2357231	TFR002	Franklin Final	Al (AE)	112	±7.6%	µg Al/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

10-Mar-25	2357226	TFR002	Franklin Final	Batch No.*	6241	-	-
10-Mar-25	2357226	TFR002	Franklin Final	Cl ₂ (F) OS*	0.65	-	mg Cl ₂ /L
10-Mar-25	2357226	TFR002	Franklin Final	Cl ₂ (T) OS*	0.80	-	mg Cl ₂ /L
10-Mar-25	2357227	TFR002	Franklin Final	Coliforms*	3	±15%	MPN/100mL
10-Mar-25	2357227	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml
10-Mar-25	2357226	TFR002	Franklin Final	Coll Time OS*	09:20	-	-
10-Mar-25	2357229	TFR002	Franklin Final	Colour	2.60	±6.5%	mg Pt-Co/L
10-Mar-25	2357230	TFR002	Franklin Final	Conductivity	10.6	±1.5%	mS/m
10-Mar-25	2357227	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
10-Mar-25	2357231	TFR002	Franklin Final	Fe (AE)	0.06	±5.4%	mg Fe/L
10-Mar-25	2357227	TFR002	Franklin Final	HPC 37*	1	±21%	cfu/mL
10-Mar-25	2357231	TFR002	Franklin Final	Mn (AE)	0.01	±6.2%	mg Mn/L
10-Mar-25	2357226	TFR002	Franklin Final	pH OS*	7.20	-	-
10-Mar-25	2357226	TFR002	Franklin Final	Temperature OS*	23.1	-	°C
10-Mar-25	2357229	TFR002	Franklin Final	Turbidity	1.1	±6.1%	NTU
10-Mar-25	2357232	TFR003	Franklin Police Station Retic	Batch No.*	6241	-	-
10-Mar-25	2357232	TFR003	Franklin Police Station Retic	Cl ₂ (F) OS*	0.57	-	mg Cl ₂ /L
10-Mar-25	2357232	TFR003	Franklin Police Station Retic	Cl ₂ (T) OS*	0.87	-	mg Cl ₂ /L
10-Mar-25	2357233	TFR003	Franklin Police Station Retic	Coliforms*	0	±15%	MPN/100mL
10-Mar-25	2357232	TFR003	Franklin Police Station Retic	Coll Time OS*	09:16	-	-
10-Mar-25	2357235	TFR003	Franklin Police Station Retic	Colour	2.20	±6.5%	mg Pt-Co/L
10-Mar-25	2357236	TFR003	Franklin Police Station Retic	Conductivity	10.8	±1.5%	mS/m
10-Mar-25	2357233	TFR003	Franklin Police Station Retic	E.coli*	0	±14%	MPN/100mL
10-Mar-25	2357233	TFR003	Franklin Police Station Retic	HPC 37*	0	±21%	cfu/mL
10-Mar-25	2357235	TFR003	Franklin Police Station Retic	Odour*	Nil	-	-
10-Mar-25	2357232	TFR003	Franklin Police Station Retic	pH OS*	7.00	-	-
10-Mar-25	2357232	TFR003	Franklin Police Station Retic	Temperature OS*	21.9	-	°C
10-Mar-25	2357235	TFR003	Franklin Police Station Retic	Turbidity	0.9	±6.1%	NTU
10-Mar-25	2357256	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
10-Mar-25	2357251	TKK002	Kokstad Final	Batch No.*	6244	-	-
10-Mar-25	2357251	TKK002	Kokstad Final	Cl ₂ (F) OS*	2.32	-	mg Cl ₂ /L
10-Mar-25	2357251	TKK002	Kokstad Final	Cl ₂ (T) OS*	2.47	-	mg Cl ₂ /L
10-Mar-25	2357252	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
10-Mar-25	2357252	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
10-Mar-25	2357251	TKK002	Kokstad Final	Coll Time OS*	10:00	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

10-Mar-25	2357254	TKK002	Kokstad Final	Colour	2.50	±6.5%	mg Pt-Co/L
10-Mar-25	2357255	TKK002	Kokstad Final	Conductivity	10.7	±1.5%	mS/m
10-Mar-25	2357252	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
10-Mar-25	2357252	TKK002	Kokstad Final	HPC 37*	4	±21%	cfu/mL
10-Mar-25	2357254	TKK002	Kokstad Final	Odour*	Nil	-	-
10-Mar-25	2357251	TKK002	Kokstad Final	pH OS*	7.50	-	-
10-Mar-25	2357254	TKK002	Kokstad Final	Taste*	Nil	-	-
10-Mar-25	2357251	TKK002	Kokstad Final	Temperature OS*	19.8	-	°C
10-Mar-25	2357254	TKK002	Kokstad Final	Turbidity	0.2	±6.1%	NTU
10-Mar-25	2357266	TKK006	Kokstad Bongweni Correctional Serv Retic	Batch No.*	6244	-	-
10-Mar-25	2357266	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl2 (F) OS*	<0.05	-	mg Cl2/L
10-Mar-25	2357266	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl2 (T) OS*	0.09	-	mg Cl2/L
10-Mar-25	2357267	TKK006	Kokstad Bongweni Correctional Serv Retic	Coliforms*	1	±15%	MPN/100mL
10-Mar-25	2357266	TKK006	Kokstad Bongweni Correctional Serv Retic	Coll Time OS*	09:35	-	-
10-Mar-25	2357269	TKK006	Kokstad Bongweni Correctional Serv Retic	Colour	1.90	±6.5%	mg Pt-Co/L
10-Mar-25	2357267	TKK006	Kokstad Bongweni Correctional Serv Retic	E.coli*	0	±14%	MPN/100mL
10-Mar-25	2357267	TKK006	Kokstad Bongweni Correctional Serv Retic	HPC 37*	0	±21%	cfu/mL
10-Mar-25	2357269	TKK006	Kokstad Bongweni Correctional Serv Retic	Odour*	Nil	-	-
10-Mar-25	2357266	TKK006	Kokstad Bongweni Correctional Serv Retic	pH OS*	7.40	-	-
10-Mar-25	2357266	TKK006	Kokstad Bongweni Correctional Serv Retic	Temperature OS*	20.0	-	°C
10-Mar-25	2357269	TKK006	Kokstad Bongweni Correctional Serv Retic	Turbidity	0.5	±6.1%	NTU
10-Mar-25	2357270	TKK007	Kokstad Shayamoya Reticulation	Batch No.*	6244	-	-
10-Mar-25	2357270	TKK007	Kokstad Shayamoya Reticulation	Cl2 (F) OS*	0.72	-	mg Cl2/L
10-Mar-25	2357270	TKK007	Kokstad Shayamoya Reticulation	Cl2 (T) OS*	0.99	-	mg Cl2/L
10-Mar-25	2357271	TKK007	Kokstad Shayamoya Reticulation	Coliforms*	0	±15%	MPN/100mL
10-Mar-25	2357270	TKK007	Kokstad Shayamoya Reticulation	Coll Time OS*	10:16	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

10-Mar-25	2357273	TKK007	Kokstad Shayamoya Reticulation	Colour	2.70	±6.5%	mg Pt-Co/L
10-Mar-25	2357271	TKK007	Kokstad Shayamoya Reticulation	E.coli*	0	±14%	MPN/100mL
10-Mar-25	2357271	TKK007	Kokstad Shayamoya Reticulation	HPC 37*	0	±21%	cfu/mL
10-Mar-25	2357273	TKK007	Kokstad Shayamoya Reticulation	Odour*	Nil	-	-
10-Mar-25	2357270	TKK007	Kokstad Shayamoya Reticulation	pH OS*	7.60	-	-
10-Mar-25	2357273	TKK007	Kokstad Shayamoya Reticulation	Taste*	Nil	-	-
10-Mar-25	2357270	TKK007	Kokstad Shayamoya Reticulation	Temperature OS*	20.3	-	°C
10-Mar-25	2357273	TKK007	Kokstad Shayamoya Reticulation	Turbidity	0.3	±6.1%	NTU
10-Mar-25	2357274	TKK009	Kokstad Farm Fresh Produce Market	Batch No.*	6241	-	-
10-Mar-25	2357274	TKK009	Kokstad Farm Fresh Produce Market	Cl ₂ (F) OS*	1.91	-	mg Cl ₂ /L
10-Mar-25	2357274	TKK009	Kokstad Farm Fresh Produce Market	Cl ₂ (T) OS*	2.02	-	mg Cl ₂ /L
10-Mar-25	2357275	TKK009	Kokstad Farm Fresh Produce Market	Coliforms*	0	±15%	MPN/100mL
10-Mar-25	2357274	TKK009	Kokstad Farm Fresh Produce Market	Coll Time OS*	10:30	-	-
10-Mar-25	2357277	TKK009	Kokstad Farm Fresh Produce Market	Colour	2.00	±6.5%	mg Pt-Co/L
10-Mar-25	2357275	TKK009	Kokstad Farm Fresh Produce Market	E.coli*	0	±14%	MPN/100mL
10-Mar-25	2357275	TKK009	Kokstad Farm Fresh Produce Market	HPC 37*	0	±21%	cfu/mL
10-Mar-25	2357277	TKK009	Kokstad Farm Fresh Produce Market	Odour*	Nil	-	-
10-Mar-25	2357274	TKK009	Kokstad Farm Fresh Produce Market	pH OS*	7.20	-	-
10-Mar-25	2357274	TKK009	Kokstad Farm Fresh Produce Market	Temperature OS*	20.1	-	°C
10-Mar-25	2357277	TKK009	Kokstad Farm Fresh Produce Market	Turbidity	0.9	±6.1%	NTU
10-Mar-25	2357278	TKK012	Kokstad FET College Reticulation	Batch No.*	6244	-	-
10-Mar-25	2357278	TKK012	Kokstad FET College Reticulation	Cl ₂ (F) OS*	0.87	-	mg Cl ₂ /L
10-Mar-25	2357278	TKK012	Kokstad FET College Reticulation	Cl ₂ (T) OS*	1.08	-	mg Cl ₂ /L
10-Mar-25	2357279	TKK012	Kokstad FET College Reticulation	Coliforms*	8	±15%	MPN/100mL
10-Mar-25	2357278	TKK012	Kokstad FET College Reticulation	Coll Time OS*	09:03	-	-
10-Mar-25	2357281	TKK012	Kokstad FET College Reticulation	Colour	2.10	±6.5%	mg Pt-Co/L
10-Mar-25	2357282	TKK012	Kokstad FET College Reticulation	Conductivity	10.8	±1.5%	mS/m

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

10-Mar-25	2357279	TKK012	Kokstad FET College Reticulation	E.coli*	0	±14%	MPN/100mL
10-Mar-25	2357279	TKK012	Kokstad FET College Reticulation	HPC 37*	0	±21%	cfu/mL
10-Mar-25	2357278	TKK012	Kokstad FET College Reticulation	pH OS*	7.30	-	-
10-Mar-25	2357278	TKK012	Kokstad FET College Reticulation	Temperature OS*	19.4	-	°C
10-Mar-25	2357281	TKK012	Kokstad FET College Reticulation	Turbidity	0.3	±6.1%	NTU
10-Mar-25	2357313	TNJU002	KwaNjunga Final	Al (AE)	40.4	±7.6%	µg Al/L
10-Mar-25	2357308	TNJU002	KwaNjunga Final	Batch No.*	6241	-	-
10-Mar-25	2357308	TNJU002	KwaNjunga Final	Cl2 (F) OS*	<0.05	-	mg Cl2/L
10-Mar-25	2357308	TNJU002	KwaNjunga Final	Cl2 (T) OS*	0.29	-	mg Cl2/L
10-Mar-25	2357309	TNJU002	KwaNjunga Final	Coliforms*	>201	±15%	MPN/100mL
10-Mar-25	2357308	TNJU002	KwaNjunga Final	Coll Time OS*	08:27	-	-
10-Mar-25	2357312	TNJU002	KwaNjunga Final	Conductivity	15.6	±1.5%	mS/m
10-Mar-25	2357309	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
10-Mar-25	2357309	TNJU002	KwaNjunga Final	HPC 37*	19	±21%	cfu/mL
10-Mar-25	2357308	TNJU002	KwaNjunga Final	pH OS*	7.20	-	-
10-Mar-25	2357308	TNJU002	KwaNjunga Final	Temperature OS*	18.6	-	°C
10-Mar-25	2357311	TNJU002	KwaNjunga Final	Turbidity	1.1	±6.1%	NTU
10-Mar-25	2357314	TNJU003	KwaNjunga Reticulation	Batch No.*	6241	-	-
10-Mar-25	2357314	TNJU003	KwaNjunga Reticulation	Cl2 (F) OS*	<0.05	-	mg Cl2/L
10-Mar-25	2357314	TNJU003	KwaNjunga Reticulation	Cl2 (T) OS*	0.11	-	mg Cl2/L
10-Mar-25	2357315	TNJU003	KwaNjunga Reticulation	Coliforms*	>201	±15%	MPN/100mL
10-Mar-25	2357314	TNJU003	KwaNjunga Reticulation	Coll Time OS*	08:02	-	-
10-Mar-25	2357317	TNJU003	KwaNjunga Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
10-Mar-25	2357318	TNJU003	KwaNjunga Reticulation	Conductivity	14.8	±1.5%	mS/m
10-Mar-25	2357315	TNJU003	KwaNjunga Reticulation	E.coli*	2	±14%	MPN/100mL
10-Mar-25	2357315	TNJU003	KwaNjunga Reticulation	HPC 37*	234	±21%	cfu/mL
10-Mar-25	2357317	TNJU003	KwaNjunga Reticulation	Odour*	Nil	-	-
10-Mar-25	2357314	TNJU003	KwaNjunga Reticulation	pH OS*	9.00	-	-
10-Mar-25	2357314	TNJU003	KwaNjunga Reticulation	Temperature OS*	20.5	-	°C
10-Mar-25	2357317	TNJU003	KwaNjunga Reticulation	Turbidity	1.0	±6.1%	NTU
11-Mar-25	2357951	TJO001	Jolivet RRT frn Vulamehlo	Batch No.*	6244	-	-
11-Mar-25	2357951	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (F) OS*	0.20	-	mg Cl2/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

11-Mar-25	2357951	TJO001	Jolivet RRT frn Vulamehlo	Cl ₂ (T) OS*	0.50	-	mg Cl ₂ /L
11-Mar-25	2357952	TJO001	Jolivet RRT frn Vulamehlo	Coliforms*	0	±15%	MPN/100mL
11-Mar-25	2357951	TJO001	Jolivet RRT frn Vulamehlo	Coll Time OS*	11h00	-	-
11-Mar-25	2357954	TJO001	Jolivet RRT frn Vulamehlo	Colour	2.50	±6.5%	mg Pt-Co/L
11-Mar-25	2357955	TJO001	Jolivet RRT frn Vulamehlo	Conductivity	17.2	±1.5%	mS/m
11-Mar-25	2357952	TJO001	Jolivet RRT frn Vulamehlo	E.coli*	0	±14%	MPN/100mL
11-Mar-25	2357952	TJO001	Jolivet RRT frn Vulamehlo	HPC 37*	1	±21%	cfu/mL
11-Mar-25	2357954	TJO001	Jolivet RRT frn Vulamehlo	Odour*	Nil	-	-
11-Mar-25	2357951	TJO001	Jolivet RRT frn Vulamehlo	pH OS*	7.60	-	-
11-Mar-25	2357951	TJO001	Jolivet RRT frn Vulamehlo	Temperature OS*	19.8	-	°C
11-Mar-25	2357954	TJO001	Jolivet RRT frn Vulamehlo	Turbidity	2.7	±6.1%	NTU
11-Mar-25	2358022	TQU002	Mnqumeni Final	Batch No.*	6241	-	-
11-Mar-25	2358022	TQU002	Mnqumeni Final	Cl ₂ (F) OS*	1.32	-	mg Cl ₂ /L
11-Mar-25	2358022	TQU002	Mnqumeni Final	Cl ₂ (T) OS*	1.47	-	mg Cl ₂ /L
11-Mar-25	2358023	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
11-Mar-25	2358022	TQU002	Mnqumeni Final	Coll Time OS*	06:20	-	-
11-Mar-25	2358026	TQU002	Mnqumeni Final	Conductivity	9.93	±1.5%	mS/m
11-Mar-25	2358023	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
11-Mar-25	2358023	TQU002	Mnqumeni Final	HPC 37*	6	±21%	cfu/mL
11-Mar-25	2358022	TQU002	Mnqumeni Final	pH OS*	7.30	-	-
11-Mar-25	2358022	TQU002	Mnqumeni Final	Temperature OS*	20.3	-	°C
11-Mar-25	2358025	TQU002	Mnqumeni Final	Turbidity	0.9	±6.1%	NTU
11-Mar-25	2358037	TSQ002	Esiqanduleni Final	Al (AE)	208	±7.6%	µg Al/L
11-Mar-25	2358032	TSQ002	Esiqanduleni Final	Batch No.*	6244	-	-
11-Mar-25	2358032	TSQ002	Esiqanduleni Final	Cl ₂ (F) OS*	1.40	-	mg Cl ₂ /L
11-Mar-25	2358032	TSQ002	Esiqanduleni Final	Cl ₂ (T) OS*	1.65	-	mg Cl ₂ /L
11-Mar-25	2358033	TSQ002	Esiqanduleni Final	Coliforms*	8	±15%	MPN/100mL
11-Mar-25	2358032	TSQ002	Esiqanduleni Final	Coll Time OS*	08:12	-	-
11-Mar-25	2358035	TSQ002	Esiqanduleni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
11-Mar-25	2358036	TSQ002	Esiqanduleni Final	Conductivity	8.81	±1.5%	mS/m
11-Mar-25	2358033	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
11-Mar-25	2358033	TSQ002	Esiqanduleni Final	HPC 37*	26	±21%	cfu/mL
11-Mar-25	2358035	TSQ002	Esiqanduleni Final	Odour*	Nil	-	-
11-Mar-25	2358032	TSQ002	Esiqanduleni Final	pH OS*	7.50	-	-
11-Mar-25	2358032	TSQ002	Esiqanduleni Final	Temperature OS*	21.3	-	°C
11-Mar-25	2358035	TSQ002	Esiqanduleni Final	Turbidity	7.7	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

11-Mar-25	2358038	TSQ003	Esiqanduleni Reticulation	Batch No.*	6244	-	-
11-Mar-25	2358038	TSQ003	Esiqanduleni Reticulation	Cl2 (F) OS*	1.11	-	mg Cl2/L
11-Mar-25	2358038	TSQ003	Esiqanduleni Reticulation	Cl2 (T) OS*	1.25	-	mg Cl2/L
11-Mar-25	2358039	TSQ003	Esiqanduleni Reticulation	Coliforms*	0	±15%	MPN/100mL
11-Mar-25	2358038	TSQ003	Esiqanduleni Reticulation	Coll Time OS*	08:30	-	-
11-Mar-25	2358041	TSQ003	Esiqanduleni Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
11-Mar-25	2358042	TSQ003	Esiqanduleni Reticulation	Conductivity	9.17	±1.5%	mS/m
11-Mar-25	2358039	TSQ003	Esiqanduleni Reticulation	E.coli*	0	±14%	MPN/100mL
11-Mar-25	2358039	TSQ003	Esiqanduleni Reticulation	HPC 37*	0	±21%	cfu/mL
11-Mar-25	2358041	TSQ003	Esiqanduleni Reticulation	Odour*	Nil	-	-
11-Mar-25	2358038	TSQ003	Esiqanduleni Reticulation	pH OS*	7.50	-	-
11-Mar-25	2358038	TSQ003	Esiqanduleni Reticulation	Temperature OS*	21.4	-	°C
11-Mar-25	2358041	TSQ003	Esiqanduleni Reticulation	Turbidity	9.8	±6.1%	NTU
12-Mar-25	2358599	TBU002	Bulwer Final	Batch No.*	6244	-	-
12-Mar-25	2358599	TBU002	Bulwer Final	Cl2 (F) OS*	0.14	-	mg Cl2/L
12-Mar-25	2358599	TBU002	Bulwer Final	Cl2 (T) OS*	0.27	-	mg Cl2/L
12-Mar-25	2358600	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
12-Mar-25	2358599	TBU002	Bulwer Final	Coll Time OS*	10:15	-	-
12-Mar-25	2358602	TBU002	Bulwer Final	Colour	<1.00	±6.5%	mg Pt-Co/L
12-Mar-25	2358603	TBU002	Bulwer Final	Conductivity	4.63	±1.5%	mS/m
12-Mar-25	2358600	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
12-Mar-25	2358600	TBU002	Bulwer Final	HPC 37*	12	±21%	cfu/mL
12-Mar-25	2358602	TBU002	Bulwer Final	Odour*	Nil	-	-
12-Mar-25	2358599	TBU002	Bulwer Final	pH OS*	7.40	-	-
12-Mar-25	2358599	TBU002	Bulwer Final	Temperature OS*	25.8	-	°C
12-Mar-25	2358602	TBU002	Bulwer Final	Turbidity	5.9	±6.1%	NTU
12-Mar-25	2358604	TBU005	Bulwer Mountain Park Hotel Retic	Batch No.*	6244	-	-
12-Mar-25	2358604	TBU005	Bulwer Mountain Park Hotel Retic	Cl2 (F) OS*	0.18	-	mg Cl2/L
12-Mar-25	2358604	TBU005	Bulwer Mountain Park Hotel Retic	Cl2 (T) OS*	0.30	-	mg Cl2/L
12-Mar-25	2358605	TBU005	Bulwer Mountain Park Hotel Retic	Coliforms*	0	±15%	MPN/100mL
12-Mar-25	2358604	TBU005	Bulwer Mountain Park Hotel Retic	Coll Time OS*	10:42	-	-
12-Mar-25	2358607	TBU005	Bulwer Mountain Park Hotel Retic	Colour	<1.00	±6.5%	mg Pt-Co/L
12-Mar-25	2358608	TBU005	Bulwer Mountain Park Hotel Retic	Conductivity	4.61	±1.5%	mS/m

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

12-Mar-25	2358605	TBU005	Bulwer Mountain Park Hotel Retic	E.coli*	0	±14%	MPN/100mL
12-Mar-25	2358605	TBU005	Bulwer Mountain Park Hotel Retic	HPC 37*	10	±21%	cfu/mL
12-Mar-25	2358604	TBU005	Bulwer Mountain Park Hotel Retic	pH OS*	7.30	-	-
12-Mar-25	2358604	TBU005	Bulwer Mountain Park Hotel Retic	Temperature OS*	25.6	-	°C
12-Mar-25	2358607	TBU005	Bulwer Mountain Park Hotel Retic	Turbidity	7.3	±6.1%	NTU
12-Mar-25	2358619	TCR002	Creighton Final	Al (AE)	128	±7.6%	µg Al/L
12-Mar-25	2358614	TCR002	Creighton Final	Batch No.*	6244	-	-
12-Mar-25	2358614	TCR002	Creighton Final	Cl ₂ (F) OS*	1.08	-	mg Cl ₂ /L
12-Mar-25	2358614	TCR002	Creighton Final	Cl ₂ (T) OS*	1.20	-	mg Cl ₂ /L
12-Mar-25	2358615	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
12-Mar-25	2358614	TCR002	Creighton Final	Coll Time OS*	08:20	-	-
12-Mar-25	2358618	TCR002	Creighton Final	Conductivity	23.6	±1.5%	mS/m
12-Mar-25	2358615	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
12-Mar-25	2358615	TCR002	Creighton Final	HPC 37*	2	±21%	cfu/mL
12-Mar-25	2358614	TCR002	Creighton Final	pH OS*	7.40	-	-
12-Mar-25	2358614	TCR002	Creighton Final	Temperature OS*	19.6	-	°C
12-Mar-25	2358617	TCR002	Creighton Final	Turbidity	2.0	±6.1%	NTU
12-Mar-25	2358620	TCR004	Creighton Madondo Cottages	Batch No.*	6244	-	-
12-Mar-25	2358620	TCR004	Creighton Madondo Cottages	Cl ₂ (F) OS*	0.65	-	mg Cl ₂ /L
12-Mar-25	2358620	TCR004	Creighton Madondo Cottages	Cl ₂ (T) OS*	0.73	-	mg Cl ₂ /L
12-Mar-25	2358621	TCR004	Creighton Madondo Cottages	Coliforms*	0	±15%	MPN/100mL
12-Mar-25	2358620	TCR004	Creighton Madondo Cottages	Coll Time OS*	08:06	-	-
12-Mar-25	2358623	TCR004	Creighton Madondo Cottages	Colour	<1.00	±6.5%	mg Pt-Co/L
12-Mar-25	2358624	TCR004	Creighton Madondo Cottages	Conductivity	18.9	±1.5%	mS/m
12-Mar-25	2358621	TCR004	Creighton Madondo Cottages	E.coli*	0	±14%	MPN/100mL
12-Mar-25	2358621	TCR004	Creighton Madondo Cottages	HPC 37*	0	±21%	cfu/mL
12-Mar-25	2358620	TCR004	Creighton Madondo Cottages	pH OS*	7.30	-	-
12-Mar-25	2358620	TCR004	Creighton Madondo Cottages	Temperature OS*	19.2	-	°C
12-Mar-25	2358623	TCR004	Creighton Madondo Cottages	Turbidity	0.8	±6.1%	NTU
12-Mar-25	2358634	THL002	Hlanganani Final	Batch No.*	6244	-	-
12-Mar-25	2358634	THL002	Hlanganani Final	Cl ₂ (F) OS*	1.09	-	mg Cl ₂ /L
12-Mar-25	2358634	THL002	Hlanganani Final	Cl ₂ (T) OS*	1.22	-	mg Cl ₂ /L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

12-Mar-25	2358635	THL002	Hlanganani Final	Coliforms*	0	±15%	MPN/100mL
12-Mar-25	2358634	THL002	Hlanganani Final	Coll Time OS*	11:08	-	-
12-Mar-25	2358637	THL002	Hlanganani Final	Colour	<1.00	±6.5%	mg Pt-Co/L
12-Mar-25	2358638	THL002	Hlanganani Final	Conductivity	7.84	±1.5%	mS/m
12-Mar-25	2358635	THL002	Hlanganani Final	E.coli*	0	±14%	MPN/100mL
12-Mar-25	2358635	THL002	Hlanganani Final	HPC 37*	2	±21%	cfu/mL
12-Mar-25	2358637	THL002	Hlanganani Final	Odour*	Mild Chlorinous	-	-
12-Mar-25	2358634	THL002	Hlanganani Final	pH OS*	7.40	-	-
12-Mar-25	2358637	THL002	Hlanganani Final	Taste*	Nil	-	-
12-Mar-25	2358634	THL002	Hlanganani Final	Temperature OS*	23.5	-	°C
12-Mar-25	2358637	THL002	Hlanganani Final	Turbidity	<0.2	±6.1%	NTU
12-Mar-25	2358639	THL003	Hlanganani Clinic Reticulation	Batch No.*	6244	-	-
12-Mar-25	2358639	THL003	Hlanganani Clinic Reticulation	Cl ₂ (F) OS*	0.40	-	mg Cl ₂ /L
12-Mar-25	2358639	THL003	Hlanganani Clinic Reticulation	Cl ₂ (T) OS*	0.52	-	mg Cl ₂ /L
12-Mar-25	2358640	THL003	Hlanganani Clinic Reticulation	Coliforms*	0	±15%	MPN/100mL
12-Mar-25	2358639	THL003	Hlanganani Clinic Reticulation	Coll Time OS*	11:18	-	-
12-Mar-25	2358642	THL003	Hlanganani Clinic Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
12-Mar-25	2358643	THL003	Hlanganani Clinic Reticulation	Conductivity	7.71	±1.5%	mS/m
12-Mar-25	2358640	THL003	Hlanganani Clinic Reticulation	E.coli*	0	±14%	MPN/100mL
12-Mar-25	2358640	THL003	Hlanganani Clinic Reticulation	HPC 37*	0	±21%	cfu/mL
12-Mar-25	2358639	THL003	Hlanganani Clinic Reticulation	pH OS*	7.20	-	-
12-Mar-25	2358639	THL003	Hlanganani Clinic Reticulation	Temperature OS*	23.1	-	°C
12-Mar-25	2358642	THL003	Hlanganani Clinic Reticulation	Turbidity	<0.2	±6.1%	NTU
12-Mar-25	2358668	TMQA002	Mqatsheni Final	Batch No.*	6244	-	-
12-Mar-25	2358668	TMQA002	Mqatsheni Final	Cl ₂ (F) OS*	1.24	-	mg Cl ₂ /L
12-Mar-25	2358668	TMQA002	Mqatsheni Final	Cl ₂ (T) OS*	1.51	-	mg Cl ₂ /L
12-Mar-25	2358669	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
12-Mar-25	2358668	TMQA002	Mqatsheni Final	Coll Time OS*	09:51	-	-
12-Mar-25	2358671	TMQA002	Mqatsheni Final	Colour	3.00	±6.5%	mg Pt-Co/L
12-Mar-25	2358672	TMQA002	Mqatsheni Final	Conductivity	27.2	±1.5%	mS/m
12-Mar-25	2358669	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
12-Mar-25	2358669	TMQA002	Mqatsheni Final	HPC 37*	23	±21%	cfu/mL
12-Mar-25	2358671	TMQA002	Mqatsheni Final	Odour*	Nil	-	-
12-Mar-25	2358668	TMQA002	Mqatsheni Final	pH OS*	9.00	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

12-Mar-25	2358668	TMQA002	Mqatsheni Final	Temperature OS*	21.4	-	°C
12-Mar-25	2358671	TMQA002	Mqatsheni Final	Turbidity	1.5	±6.1%	NTU
12-Mar-25	2358673	TMQA003	Mqatsheni Reticulation	Batch No.*	6244	-	-
12-Mar-25	2358673	TMQA003	Mqatsheni Reticulation	Cl2 (F) OS*	0.11	-	mg Cl2/L
12-Mar-25	2358673	TMQA003	Mqatsheni Reticulation	Cl2 (T) OS*	0.31	-	mg Cl2/L
12-Mar-25	2358674	TMQA003	Mqatsheni Reticulation	Coliforms*	0	±15%	MPN/100mL
12-Mar-25	2358673	TMQA003	Mqatsheni Reticulation	Coll Time OS*	10:17	-	-
12-Mar-25	2358676	TMQA003	Mqatsheni Reticulation	Colour	6.10	±6.5%	mg Pt-Co/L
12-Mar-25	2358677	TMQA003	Mqatsheni Reticulation	Conductivity	26.2	±1.5%	mS/m
12-Mar-25	2358674	TMQA003	Mqatsheni Reticulation	E.coli*	0	±14%	MPN/100mL
12-Mar-25	2358674	TMQA003	Mqatsheni Reticulation	HPC 37*	5	±21%	cfu/mL
12-Mar-25	2358673	TMQA003	Mqatsheni Reticulation	pH OS*	9.00	-	-
12-Mar-25	2358673	TMQA003	Mqatsheni Reticulation	Temperature OS*	21.8	-	°C
12-Mar-25	2358676	TMQA003	Mqatsheni Reticulation	Turbidity	3.3	±6.1%	NTU
12-Mar-25	2358688	TRV002	Riverside Final	Al (AE)	67.8	±7.6%	µg Al/L
12-Mar-25	2358683	TRV002	Riverside Final	Batch No.*	6244	-	-
12-Mar-25	2358683	TRV002	Riverside Final	Cl2 (F) OS*	2.50	-	mg Cl2/L
12-Mar-25	2358683	TRV002	Riverside Final	Cl2 (T) OS*	3.50	-	mg Cl2/L
12-Mar-25	2358684	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
12-Mar-25	2358684	TRV002	Riverside Final	Coliphages*	0	±8%	PFU/10ml
12-Mar-25	2358683	TRV002	Riverside Final	Coll Time OS*	08:52	-	-
12-Mar-25	2358686	TRV002	Riverside Final	Colour	<1.00	±6.5%	mg Pt-Co/L
12-Mar-25	2358687	TRV002	Riverside Final	Conductivity	30.4	±1.5%	mS/m
12-Mar-25	2358684	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
12-Mar-25	2358684	TRV002	Riverside Final	HPC 37*	1	±21%	cfu/mL
12-Mar-25	2358686	TRV002	Riverside Final	Odour*	Mild Chlorinous	-	-
12-Mar-25	2358683	TRV002	Riverside Final	pH OS*	7.50	-	-
12-Mar-25	2358686	TRV002	Riverside Final	Taste*	Nil	-	-
12-Mar-25	2358683	TRV002	Riverside Final	Temperature OS*	22.8	-	°C
12-Mar-25	2358686	TRV002	Riverside Final	Turbidity	0.4	±6.1%	NTU
12-Mar-25	2358689	TRV003	Riverside Reticulation	Batch No.*	6244	-	-
12-Mar-25	2358689	TRV003	Riverside Reticulation	Cl2 (F) OS*	2.10	-	mg Cl2/L
12-Mar-25	2358689	TRV003	Riverside Reticulation	Cl2 (T) OS*	2.40	-	mg Cl2/L
12-Mar-25	2358690	TRV003	Riverside Reticulation	Coliforms*	0	±15%	MPN/100mL
12-Mar-25	2358689	TRV003	Riverside Reticulation	Coll Time OS*	08:40	-	-
12-Mar-25	2358692	TRV003	Riverside Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

12-Mar-25	2358690	TRV003	Riverside Reticulation	E.coli*	0	±14%	MPN/100mL
12-Mar-25	2358690	TRV003	Riverside Reticulation	HPC 37*	0	±21%	cfu/mL
12-Mar-25	2358692	TRV003	Riverside Reticulation	Odour*	Mild Chlorinous	-	-
12-Mar-25	2358689	TRV003	Riverside Reticulation	pH OS*	7.20	-	-
12-Mar-25	2358689	TRV003	Riverside Reticulation	Temperature OS*	22.2	-	°C
12-Mar-25	2358692	TRV003	Riverside Reticulation	Turbidity	1.0	±6.1%	NTU
12-Mar-25	2358703	TST002	St Appollinaris Final	Al (AE)	968	±7.6%	µg Al/L
12-Mar-25	2358698	TST002	St Appollinaris Final	Batch No.*	6244	-	-
12-Mar-25	2358698	TST002	St Appollinaris Final	Cl ₂ (F) OS*	0.35	-	mg Cl ₂ /L
12-Mar-25	2358698	TST002	St Appollinaris Final	Cl ₂ (T) OS*	0.43	-	mg Cl ₂ /L
12-Mar-25	2358699	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
12-Mar-25	2358698	TST002	St Appollinaris Final	Coll Time OS*	09:45	-	-
12-Mar-25	2358701	TST002	St Appollinaris Final	Colour	<1.00	±6.5%	mg Pt-Co/L
12-Mar-25	2358702	TST002	St Appollinaris Final	Conductivity	7.83	±1.5%	mS/m
12-Mar-25	2358699	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
12-Mar-25	2358699	TST002	St Appollinaris Final	HPC 37*	0	±21%	cfu/mL
12-Mar-25	2358701	TST002	St Appollinaris Final	Odour*	Nil	-	-
12-Mar-25	2358698	TST002	St Appollinaris Final	pH OS*	7.50	-	-
12-Mar-25	2358698	TST002	St Appollinaris Final	Temperature OS*	23.4	-	°C
12-Mar-25	2358701	TST002	St Appollinaris Final	Turbidity	3.8	±6.1%	NTU
12-Mar-25	2358714	TUN002	Underberg Final	Al (AE)	121	±7.6%	µg Al/L
12-Mar-25	2358709	TUN002	Underberg Final	Batch No.*	6244	-	-
12-Mar-25	2358709	TUN002	Underberg Final	Cl ₂ (F) OS*	0.69	-	mg Cl ₂ /L
12-Mar-25	2358709	TUN002	Underberg Final	Cl ₂ (T) OS*	0.71	-	mg Cl ₂ /L
12-Mar-25	2358710	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
12-Mar-25	2358709	TUN002	Underberg Final	Coll Time OS*	08:15	-	-
12-Mar-25	2358712	TUN002	Underberg Final	Colour	<1.00	±6.5%	mg Pt-Co/L
12-Mar-25	2358713	TUN002	Underberg Final	Conductivity	3.60	±1.5%	mS/m
12-Mar-25	2358710	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
12-Mar-25	2358710	TUN002	Underberg Final	HPC 37*	1	±21%	cfu/mL
12-Mar-25	2358712	TUN002	Underberg Final	Odour*	Nil	-	-
12-Mar-25	2358709	TUN002	Underberg Final	pH OS*	7.50	-	-
12-Mar-25	2358709	TUN002	Underberg Final	Temperature OS*	17.3	-	°C
12-Mar-25	2358712	TUN002	Underberg Final	Turbidity	1.1	±6.1%	NTU
13-Mar-25	2359467	TMZ002	Umzimkhulu Final	Al (AE)	349	±7.6%	µg Al/L
13-Mar-25	2359462	TMZ002	Umzimkhulu Final	Batch No.*	6244	-	-
13-Mar-25	2359462	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	1.36	-	mg Cl ₂ /L
13-Mar-25	2359462	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	1.46	-	mg Cl ₂ /L
13-Mar-25	2359463	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
13-Mar-25	2359463	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10ml
13-Mar-25	2359462	TMZ002	Umzimkhulu Final	Coll Time OS*	08:00	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

13-Mar-25	2359465	TMZ002	Umzimkhulu Final	Colour	1.90	±6.5%	mg Pt-Co/L
13-Mar-25	2359466	TMZ002	Umzimkhulu Final	Conductivity	6.36	±1.5%	mS/m
13-Mar-25	2359463	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
13-Mar-25	2359467	TMZ002	Umzimkhulu Final	Fe (AE)	0.16	±5.4%	mg Fe/L
13-Mar-25	2359463	TMZ002	Umzimkhulu Final	HPC 37*	1	±21%	cfu/mL
13-Mar-25	2359465	TMZ002	Umzimkhulu Final	Odour*	Nil	-	-
13-Mar-25	2359462	TMZ002	Umzimkhulu Final	pH OS*	7.10	-	-
13-Mar-25	2359462	TMZ002	Umzimkhulu Final	Temperature OS*	21.6	-	°C
13-Mar-25	2359465	TMZ002	Umzimkhulu Final	Turbidity	4.0	±6.1%	NTU
13-Mar-25	2359468	TMZ004	Umzikhulu Informal Settlement Retic	Batch No.*	6244	-	-
13-Mar-25	2359468	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (F) OS*	1.30	-	mg Cl ₂ /L
13-Mar-25	2359468	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (T) OS*	1.60	-	mg Cl ₂ /L
13-Mar-25	2359469	TMZ004	Umzikhulu Informal Settlement Retic	Coliforms*	0	±15%	MPN/100mL
13-Mar-25	2359468	TMZ004	Umzikhulu Informal Settlement Retic	Coll Time OS*	09:18	-	-
13-Mar-25	2359469	TMZ004	Umzikhulu Informal Settlement Retic	E.coli*	0	±14%	MPN/100mL
13-Mar-25	2359469	TMZ004	Umzikhulu Informal Settlement Retic	HPC 37*	0	±21%	cfu/mL
13-Mar-25	2359468	TMZ004	Umzikhulu Informal Settlement Retic	pH OS*	7.50	-	-
13-Mar-25	2359468	TMZ004	Umzikhulu Informal Settlement Retic	Temperature OS*	23.8	-	°C
13-Mar-25	2359471	TMZ004	Umzikhulu Informal Settlement Retic	Turbidity	3.8	±6.1%	NTU
13-Mar-25	2359472	TMZ005	Umzimkhulu Local Municipality Offices	Batch No.*	6244	-	-
13-Mar-25	2359472	TMZ005	Umzimkhulu Local Municipality Offices	Cl ₂ (F) OS*	1.09	-	mg Cl ₂ /L
13-Mar-25	2359472	TMZ005	Umzimkhulu Local Municipality Offices	Cl ₂ (T) OS*	1.55	-	mg Cl ₂ /L
13-Mar-25	2359473	TMZ005	Umzimkhulu Local Municipality Offices	Coliforms*	0	±15%	MPN/100mL
13-Mar-25	2359472	TMZ005	Umzimkhulu Local Municipality Offices	Coll Time OS*	08:34	-	-
13-Mar-25	2359473	TMZ005	Umzimkhulu Local Municipality Offices	E.coli*	0	±14%	MPN/100mL
13-Mar-25	2359473	TMZ005	Umzimkhulu Local Municipality Offices	HPC 37*	3	±21%	cfu/mL
13-Mar-25	2359472	TMZ005	Umzimkhulu Local Municipality Offices	pH OS*	7.30	-	-
13-Mar-25	2359472	TMZ005	Umzimkhulu Local Municipality Offices	Temperature OS*	23.1	-	°C
13-Mar-25	2359475	TMZ005	Umzimkhulu Local Municipality Offices	Turbidity	15.6	±6.1%	NTU
13-Mar-25	2359476	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Batch No.*	6244	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

13-Mar-25	2359476	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl ₂ (F) OS*	0.24	-	mg Cl ₂ /L
13-Mar-25	2359476	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl ₂ (T) OS*	0.26	-	mg Cl ₂ /L
13-Mar-25	2359477	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coliforms*	12	±15%	MPN/100mL
13-Mar-25	2359476	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coll Time OS*	08:25	-	-
13-Mar-25	2359477	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	E.coli*	1	±14%	MPN/100mL
13-Mar-25	2359477	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	HPC 37*	3	±21%	cfu/mL
13-Mar-25	2359476	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	pH OS*	7.20	-	-
13-Mar-25	2359476	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Temperature OS*	22.7	-	°C
13-Mar-25	2359479	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Turbidity	15.8	±6.1%	NTU
13-Mar-25	2359480	TMZ007	Umzimkhulu Local FET College	Batch No.*	6244	-	-
13-Mar-25	2359480	TMZ007	Umzimkhulu Local FET College	Cl ₂ (F) OS*	0.36	-	mg Cl ₂ /L
13-Mar-25	2359480	TMZ007	Umzimkhulu Local FET College	Cl ₂ (T) OS*	0.74	-	mg Cl ₂ /L
13-Mar-25	2359481	TMZ007	Umzimkhulu Local FET College	Coliforms*	0	±15%	MPN/100mL
13-Mar-25	2359480	TMZ007	Umzimkhulu Local FET College	Coll Time OS*	08:15	-	-
13-Mar-25	2359481	TMZ007	Umzimkhulu Local FET College	E.coli*	0	±14%	MPN/100mL
13-Mar-25	2359481	TMZ007	Umzimkhulu Local FET College	HPC 37*	10	±21%	cfu/mL
13-Mar-25	2359480	TMZ007	Umzimkhulu Local FET College	pH OS*	7.00	-	-
13-Mar-25	2359480	TMZ007	Umzimkhulu Local FET College	Temperature OS*	23.7	-	°C
13-Mar-25	2359483	TMZ007	Umzimkhulu Local FET College	Turbidity	5.0	±6.1%	NTU
13-Mar-25	2359494	TNO002	Nokweja Final	Al (AE)	1538	±7.6%	µg Al/L
13-Mar-25	2359489	TNO002	Nokweja Final	Batch No.*	6244	-	-
13-Mar-25	2359489	TNO002	Nokweja Final	Cl ₂ (F) OS*	0.79	-	mg Cl ₂ /L
13-Mar-25	2359489	TNO002	Nokweja Final	Cl ₂ (T) OS*	0.90	-	mg Cl ₂ /L
13-Mar-25	2359490	TNO002	Nokweja Final	Coliforms*	0	±15%	MPN/100mL
13-Mar-25	2359490	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10ml
13-Mar-25	2359489	TNO002	Nokweja Final	Coll Time OS*	08:47	-	-
13-Mar-25	2359492	TNO002	Nokweja Final	Colour	1.00	±6.5%	mg Pt-Co/L
13-Mar-25	2359493	TNO002	Nokweja Final	Conductivity	7.17	±1.5%	mS/m
13-Mar-25	2359490	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
13-Mar-25	2359490	TNO002	Nokweja Final	HPC 37*	42	±21%	cfu/mL
13-Mar-25	2359492	TNO002	Nokweja Final	Odour*	Nil	-	-
13-Mar-25	2359489	TNO002	Nokweja Final	pH OS*	7.40	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

13-Mar-25	2359489	TNO002	Nokweja Final	Temperature OS*	20.2	-	°C
13-Mar-25	2359492	TNO002	Nokweja Final	Turbidity	21.1	±6.1%	NTU
13-Mar-25	2359513	TWA002	Washbank Final	Al (AE)	4032	±7.6%	µg Al/L
13-Mar-25	2359508	TWA002	Washbank Final	Batch No.*	6244	-	-
13-Mar-25	2359508	TWA002	Washbank Final	Cl2 (F) OS*	1.42	-	mg Cl2/L
13-Mar-25	2359508	TWA002	Washbank Final	Cl2 (T) OS*	1.45	-	mg Cl2/L
13-Mar-25	2359509	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
13-Mar-25	2359508	TWA002	Washbank Final	Coll Time OS*	07:22	-	-
13-Mar-25	2359511	TWA002	Washbank Final	Colour	10.6	±6.5%	mg Pt-Co/L
13-Mar-25	2359512	TWA002	Washbank Final	Conductivity	9.74	±1.5%	mS/m
13-Mar-25	2359509	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
13-Mar-25	2359509	TWA002	Washbank Final	HPC 37*	1	±21%	cfu/mL
13-Mar-25	2359511	TWA002	Washbank Final	Odour*	Nil	-	-
13-Mar-25	2359508	TWA002	Washbank Final	pH OS*	7.20	-	-
13-Mar-25	2359508	TWA002	Washbank Final	Temperature OS*	20.2	-	°C
13-Mar-25	2359511	TWA002	Washbank Final	Turbidity	16.9	±6.1%	NTU
14-Mar-25	2359810	TIB002	Ibisi Final	Al (AE)	29.5	±7.6%	µg Al/L
14-Mar-25	2359805	TIB002	Ibisi Final	Batch No.*	6244	-	-
14-Mar-25	2359805	TIB002	Ibisi Final	Cl2 (F) OS*	1.58	-	mg Cl2/L
14-Mar-25	2359805	TIB002	Ibisi Final	Cl2 (T) OS*	1.74	-	mg Cl2/L
14-Mar-25	2359806	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
14-Mar-25	2359806	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
14-Mar-25	2359805	TIB002	Ibisi Final	Coll Time OS*	07:01	-	-
14-Mar-25	2359808	TIB002	Ibisi Final	Colour	<1.00	±6.5%	mg Pt-Co/L
14-Mar-25	2359809	TIB002	Ibisi Final	Conductivity	8.59	±1.5%	mS/m
14-Mar-25	2359806	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
14-Mar-25	2359810	TIB002	Ibisi Final	Fe (AE)	0.07	±5.4%	mg Fe/L
14-Mar-25	2359806	TIB002	Ibisi Final	HPC 37*	0	±21%	cfu/mL
14-Mar-25	2359808	TIB002	Ibisi Final	Odour*	Nil	-	-
14-Mar-25	2359805	TIB002	Ibisi Final	pH OS*	7.10	-	-
14-Mar-25	2359805	TIB002	Ibisi Final	Temperature OS*	21.0	-	°C
14-Mar-25	2359808	TIB002	Ibisi Final	Turbidity	0.7	±6.1%	NTU
14-Mar-25	2359811	TIB003	Ibisi Police Station Reticulation	Batch No.*	6244	-	-
14-Mar-25	2359811	TIB003	Ibisi Police Station Reticulation	Cl2 (F) OS*	0.42	-	mg Cl2/L
14-Mar-25	2359811	TIB003	Ibisi Police Station Reticulation	Cl2 (T) OS*	0.88	-	mg Cl2/L
14-Mar-25	2359812	TIB003	Ibisi Police Station Reticulation	Coliforms*	1	±15%	MPN/100mL
14-Mar-25	2359811	TIB003	Ibisi Police Station Reticulation	Coll Time OS*	06:41	-	-
14-Mar-25	2359812	TIB003	Ibisi Police Station Reticulation	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

14-Mar-25	2359812	TIB003	Ibisi Police Station Reticulation	HPC 37*	0	±21%	cfu/mL
14-Mar-25	2359811	TIB003	Ibisi Police Station Reticulation	pH OS*	7.40	-	-
14-Mar-25	2359811	TIB003	Ibisi Police Station Reticulation	Temperature OS*	20.6	-	°C
14-Mar-25	2359814	TIB003	Ibisi Police Station Reticulation	Turbidity	1.7	±6.1%	NTU
17-Mar-25	2360872	TFR002	Franklin Final	Al (AE)	428	±7.6%	µg Al/L
17-Mar-25	2360867	TFR002	Franklin Final	Batch No.*	6244	-	-
17-Mar-25	2360867	TFR002	Franklin Final	Cl2 (F) OS*	1.15	-	mg Cl2/L
17-Mar-25	2360867	TFR002	Franklin Final	Cl2 (T) OS*	1.33	-	mg Cl2/L
17-Mar-25	2360868	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
17-Mar-25	2360868	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml
17-Mar-25	2360867	TFR002	Franklin Final	Coll Time OS*	07:35	-	-
17-Mar-25	2360871	TFR002	Franklin Final	Conductivity	14.8	±1.5%	mS/m
17-Mar-25	2360868	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
17-Mar-25	2360868	TFR002	Franklin Final	HPC 37*	8	±21%	cfu/mL
17-Mar-25	2360870	TFR002	Franklin Final	Odour*	Mild Chlorinous	-	-
17-Mar-25	2360867	TFR002	Franklin Final	pH OS*	7.30	-	-
17-Mar-25	2360867	TFR002	Franklin Final	Temperature OS*	17.9	-	°C
17-Mar-25	2360870	TFR002	Franklin Final	Turbidity	4.3	±6.1%	NTU
17-Mar-25	2360892	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
17-Mar-25	2360887	TKK002	Kokstad Final	Batch No.*	6244	-	-
17-Mar-25	2360887	TKK002	Kokstad Final	Cl2 (F) OS*	0.42	-	mg Cl2/L
17-Mar-25	2360887	TKK002	Kokstad Final	Cl2 (T) OS*	0.45	-	mg Cl2/L
17-Mar-25	2360888	TKK002	Kokstad Final	Coliforms*	2	±15%	MPN/100mL
17-Mar-25	2360888	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
17-Mar-25	2360887	TKK002	Kokstad Final	Coll Time OS*	08:46	-	-
17-Mar-25	2360891	TKK002	Kokstad Final	Conductivity	9.83	±1.5%	mS/m
17-Mar-25	2360888	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
17-Mar-25	2360888	TKK002	Kokstad Final	HPC 37*	1	±21%	cfu/mL
17-Mar-25	2360887	TKK002	Kokstad Final	pH OS*	7.20	-	-
17-Mar-25	2360887	TKK002	Kokstad Final	Temperature OS*	18.2	-	°C
17-Mar-25	2360890	TKK002	Kokstad Final	Turbidity	0.3	±6.1%	NTU
17-Mar-25	2360935	TNJU002	KwaNjunga Final	Al (AE)	58.4	±7.6%	µg Al/L
17-Mar-25	2360930	TNJU002	KwaNjunga Final	Batch No.*	6244	-	-
17-Mar-25	2360930	TNJU002	KwaNjunga Final	Cl2 (F) OS*	1.07	-	mg Cl2/L
17-Mar-25	2360930	TNJU002	KwaNjunga Final	Cl2 (T) OS*	1.57	-	mg Cl2/L
17-Mar-25	2360931	TNJU002	KwaNjunga Final	Coliforms*	0	±15%	MPN/100mL
17-Mar-25	2360930	TNJU002	KwaNjunga Final	Coll Time OS*	06:49	-	-
17-Mar-25	2360934	TNJU002	KwaNjunga Final	Conductivity	13.5	±1.5%	mS/m
17-Mar-25	2360931	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

17-Mar-25	2360931	TNJU002	KwaNjunga Final	HPC 37*	0	±21%	cfu/mL
17-Mar-25	2360930	TNJU002	KwaNjunga Final	pH OS*	8.90	-	-
17-Mar-25	2360930	TNJU002	KwaNjunga Final	Temperature OS*	18.2	-	°C
17-Mar-25	2360933	TNJU002	KwaNjunga Final	Turbidity	1.0	±6.1%	NTU
18-Mar-25	2361637	TQU002	Mnqumeni Final	Batch No.*	6244	-	-
18-Mar-25	2361637	TQU002	Mnqumeni Final	Cl2 (F) OS*	0.54	-	mg Cl2/L
18-Mar-25	2361637	TQU002	Mnqumeni Final	Cl2 (T) OS*	0.55	-	mg Cl2/L
18-Mar-25	2361638	TQU002	Mnqumeni Final	Coliforms*	0	±15%	MPN/100mL
18-Mar-25	2361637	TQU002	Mnqumeni Final	Coll Time OS*	7:29	-	-
18-Mar-25	2361641	TQU002	Mnqumeni Final	Conductivity	10.6	±1.5%	mS/m
18-Mar-25	2361638	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
18-Mar-25	2361638	TQU002	Mnqumeni Final	HPC 37*	2	±21%	cfu/mL
18-Mar-25	2361637	TQU002	Mnqumeni Final	pH OS*	9.40	-	-
18-Mar-25	2361637	TQU002	Mnqumeni Final	Temperature OS*	20.1	-	°C
18-Mar-25	2361640	TQU002	Mnqumeni Final	Turbidity	3.5	±6.1%	NTU
18-Mar-25	2361652	TSQ002	Esiqanduleni Final	Al (AE)	168	±7.6%	µg Al/L
18-Mar-25	2361647	TSQ002	Esiqanduleni Final	Batch No.*	6240	-	-
18-Mar-25	2361647	TSQ002	Esiqanduleni Final	Cl2 (F) OS*	1.35	-	mg Cl2/L
18-Mar-25	2361647	TSQ002	Esiqanduleni Final	Cl2 (T) OS*	1.47	-	mg Cl2/L
18-Mar-25	2361648	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL
18-Mar-25	2361647	TSQ002	Esiqanduleni Final	Coll Time OS*	7:12	-	-
18-Mar-25	2361651	TSQ002	Esiqanduleni Final	Conductivity	10.8	±1.5%	mS/m
18-Mar-25	2361648	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
18-Mar-25	2361648	TSQ002	Esiqanduleni Final	HPC 37*	17	±21%	cfu/mL
18-Mar-25	2361647	TSQ002	Esiqanduleni Final	pH OS*	7.50	-	-
18-Mar-25	2361647	TSQ002	Esiqanduleni Final	Temperature OS*	20.1	-	°C
18-Mar-25	2361650	TSQ002	Esiqanduleni Final	Turbidity	4.5	±6.1%	NTU
19-Mar-25	2362106	TBU002	Bulwer Final	Batch No.*	6240	-	-
19-Mar-25	2362106	TBU002	Bulwer Final	Cl2 (F) OS*	1.05	-	mg Cl2/L
19-Mar-25	2362106	TBU002	Bulwer Final	Cl2 (T) OS*	1.18	-	mg Cl2/L
19-Mar-25	2362107	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
19-Mar-25	2362106	TBU002	Bulwer Final	Coll Time OS*	10:30	-	-
19-Mar-25	2362110	TBU002	Bulwer Final	Conductivity	4.11	±1.5%	mS/m
19-Mar-25	2362107	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
19-Mar-25	2362107	TBU002	Bulwer Final	HPC 37*	23	±21%	cfu/mL
19-Mar-25	2362106	TBU002	Bulwer Final	pH OS*	7.40	-	-
19-Mar-25	2362106	TBU002	Bulwer Final	Temperature OS*	25.4	-	°C
19-Mar-25	2362109	TBU002	Bulwer Final	Turbidity	8.5	±6.1%	NTU
19-Mar-25	2362126	THL002	Hlanganani Final	Batch No.*	6246	-	-
19-Mar-25	2362126	THL002	Hlanganani Final	Cl2 (F) OS*	0.60	-	mg Cl2/L
19-Mar-25	2362126	THL002	Hlanganani Final	Cl2 (T) OS*	0.88	-	mg Cl2/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

19-Mar-25	2362127	THL002	Hlanganani Final	Coliforms*	0	±15%	MPN/100mL
19-Mar-25	2362126	THL002	Hlanganani Final	Coll Time OS*	11:15	-	-
19-Mar-25	2362130	THL002	Hlanganani Final	Conductivity	6.89	±1.5%	mS/m
19-Mar-25	2362127	THL002	Hlanganani Final	E.coli*	0	±14%	MPN/100mL
19-Mar-25	2362127	THL002	Hlanganani Final	HPC 37*	0	±21%	cfu/mL
19-Mar-25	2362126	THL002	Hlanganani Final	pH OS*	7.50	-	-
19-Mar-25	2362126	THL002	Hlanganani Final	Temperature OS*	26.9	-	°C
19-Mar-25	2362129	THL002	Hlanganani Final	Turbidity	<0.2	±6.1%	NTU
19-Mar-25	2362149	TMQA002	Mqatsheni Final	Batch No.*	6244	-	-
19-Mar-25	2362149	TMQA002	Mqatsheni Final	Cl ₂ (F) OS*	1.27	-	mg Cl ₂ /L
19-Mar-25	2362149	TMQA002	Mqatsheni Final	Cl ₂ (T) OS*	1.74	-	mg Cl ₂ /L
19-Mar-25	2362150	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
19-Mar-25	2362149	TMQA002	Mqatsheni Final	Coll Time OS*	09:15	-	-
19-Mar-25	2362153	TMQA002	Mqatsheni Final	Conductivity	26.5	±1.5%	mS/m
19-Mar-25	2362150	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
19-Mar-25	2362150	TMQA002	Mqatsheni Final	HPC 37*	111	±21%	cfu/mL
19-Mar-25	2362149	TMQA002	Mqatsheni Final	pH OS*	8.90	-	-
19-Mar-25	2362149	TMQA002	Mqatsheni Final	Temperature OS*	20.3	-	°C
19-Mar-25	2362152	TMQA002	Mqatsheni Final	Turbidity	6.8	±6.1%	NTU
19-Mar-25	2362164	TRV002	Riverside Final	Al (AE)	66.7	±7.6%	µg Al/L
19-Mar-25	2362159	TRV002	Riverside Final	Batch No.*	6240	-	-
19-Mar-25	2362159	TRV002	Riverside Final	Cl ₂ (F) OS*	2.20	-	mg Cl ₂ /L
19-Mar-25	2362159	TRV002	Riverside Final	Cl ₂ (T) OS*	2.44	-	mg Cl ₂ /L
19-Mar-25	2362160	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
19-Mar-25	2362160	TRV002	Riverside Final	Coliphages*	0	±8%	PFU/10ml
19-Mar-25	2362159	TRV002	Riverside Final	Coll Time OS*	08:30	-	-
19-Mar-25	2362163	TRV002	Riverside Final	Conductivity	16.6	±1.5%	mS/m
19-Mar-25	2362160	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
19-Mar-25	2362160	TRV002	Riverside Final	HPC 37*	0	±21%	cfu/mL
19-Mar-25	2362159	TRV002	Riverside Final	pH OS*	7.30	-	-
19-Mar-25	2362159	TRV002	Riverside Final	Temperature OS*	19.8	-	°C
19-Mar-25	2362162	TRV002	Riverside Final	Turbidity	1.0	±6.1%	NTU
19-Mar-25	2362175	TST002	St Appollinaris Final	Al (AE)	156	±7.6%	µg Al/L
19-Mar-25	2362170	TST002	St Appollinaris Final	Batch No.*	6240	-	-
19-Mar-25	2362170	TST002	St Appollinaris Final	Cl ₂ (F) OS*	0.38	-	mg Cl ₂ /L
19-Mar-25	2362170	TST002	St Appollinaris Final	Cl ₂ (T) OS*	0.55	-	mg Cl ₂ /L
19-Mar-25	2362171	TST002	St Appollinaris Final	Coliforms*	0	±15%	MPN/100mL
19-Mar-25	2362170	TST002	St Appollinaris Final	Coll Time OS*	09:30	-	-
19-Mar-25	2362174	TST002	St Appollinaris Final	Conductivity	6.82	±1.5%	mS/m
19-Mar-25	2362171	TST002	St Appollinaris Final	E.coli*	0	±14%	MPN/100mL
19-Mar-25	2362171	TST002	St Appollinaris Final	HPC 37*	0	±21%	cfu/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

19-Mar-25	2362170	TST002	St Appollinaris Final	pH OS*	7.60	-	-
19-Mar-25	2362170	TST002	St Appollinaris Final	Temperature OS*	20.1	-	°C
19-Mar-25	2362173	TST002	St Appollinaris Final	Turbidity	1.2	±6.1%	NTU
19-Mar-25	2362186	TUN002	Underberg Final	Al (AE)	38.6	±7.6%	µg Al/L
19-Mar-25	2362181	TUN002	Underberg Final	Batch No.*	6244	-	-
19-Mar-25	2362181	TUN002	Underberg Final	Cl ₂ (F) OS*	1.42	-	mg Cl ₂ /L
19-Mar-25	2362181	TUN002	Underberg Final	Cl ₂ (T) OS*	1.55	-	mg Cl ₂ /L
19-Mar-25	2362182	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
19-Mar-25	2362181	TUN002	Underberg Final	Coll Time OS*	08:31	-	-
19-Mar-25	2362185	TUN002	Underberg Final	Conductivity	3.78	±1.5%	mS/m
19-Mar-25	2362182	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
19-Mar-25	2362182	TUN002	Underberg Final	HPC 37*	1	±21%	cfu/mL
19-Mar-25	2362181	TUN002	Underberg Final	pH OS*	9.70	-	-
19-Mar-25	2362181	TUN002	Underberg Final	Temperature OS*	17.6	-	°C
19-Mar-25	2362184	TUN002	Underberg Final	Turbidity	1.1	±6.1%	NTU
20-Mar-25	2363063	TIB002	Ibisi Final	Al (AE)	478	±7.6%	µg Al/L
20-Mar-25	2363058	TIB002	Ibisi Final	Batch No.*	6240	-	-
20-Mar-25	2363058	TIB002	Ibisi Final	Cl ₂ (F) OS*	1.16	-	mg Cl ₂ /L
20-Mar-25	2363058	TIB002	Ibisi Final	Cl ₂ (T) OS*	1.82	-	mg Cl ₂ /L
20-Mar-25	2363059	TIB002	Ibisi Final	Coliforms*	0	±15%	MPN/100mL
20-Mar-25	2363059	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
20-Mar-25	2363058	TIB002	Ibisi Final	Coll Time OS*	07:10	-	-
20-Mar-25	2363062	TIB002	Ibisi Final	Conductivity	7.83	±1.5%	mS/m
20-Mar-25	2363059	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
20-Mar-25	2363059	TIB002	Ibisi Final	HPC 37*	15	±21%	cfu/mL
20-Mar-25	2363058	TIB002	Ibisi Final	pH OS*	7.60	-	-
20-Mar-25	2363058	TIB002	Ibisi Final	Temperature OS*	21.0	-	°C
20-Mar-25	2363061	TIB002	Ibisi Final	Turbidity	9.1	±6.1%	NTU
20-Mar-25	2362901	TMZ002	Umzimkhulu Final	Al (AE)	172	±7.6%	µg Al/L
20-Mar-25	2362896	TMZ002	Umzimkhulu Final	Batch No.*	6240	-	-
20-Mar-25	2362896	TMZ002	Umzimkhulu Final	Cl ₂ (F) OS*	0.98	-	mg Cl ₂ /L
20-Mar-25	2362896	TMZ002	Umzimkhulu Final	Cl ₂ (T) OS*	1.21	-	mg Cl ₂ /L
20-Mar-25	2362897	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
20-Mar-25	2362897	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10ml
20-Mar-25	2362896	TMZ002	Umzimkhulu Final	Coll Time OS*	08:37	-	-
20-Mar-25	2362900	TMZ002	Umzimkhulu Final	Conductivity	6.02	±1.5%	mS/m
20-Mar-25	2362897	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
20-Mar-25	2362897	TMZ002	Umzimkhulu Final	HPC 37*	1	±21%	cfu/mL
20-Mar-25	2362896	TMZ002	Umzimkhulu Final	pH OS*	7.20	-	-
20-Mar-25	2362896	TMZ002	Umzimkhulu Final	Temperature OS*	22.2	-	°C
20-Mar-25	2362899	TMZ002	Umzimkhulu Final	Turbidity	5.0	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

20-Mar-25	2362912	TNO002	Nokweja Final	Al (AE)	571	±7.6%	µg Al/L
20-Mar-25	2362907	TNO002	Nokweja Final	Batch No.*	6240	-	-
20-Mar-25	2362907	TNO002	Nokweja Final	Cl2 (F) OS*	0.55	-	mg Cl2/L
20-Mar-25	2362907	TNO002	Nokweja Final	Cl2 (T) OS*	0.95	-	mg Cl2/L
20-Mar-25	2362908	TNO002	Nokweja Final	Coliforms*	2	±15%	MPN/100mL
20-Mar-25	2362908	TNO002	Nokweja Final	Coliphages*	0	±8%	PFU/10ml
20-Mar-25	2362907	TNO002	Nokweja Final	Coll Time OS*	09:34	-	-
20-Mar-25	2362911	TNO002	Nokweja Final	Conductivity	7.14	±1.5%	mS/m
20-Mar-25	2362908	TNO002	Nokweja Final	E.coli*	0	±14%	MPN/100mL
20-Mar-25	2362908	TNO002	Nokweja Final	HPC 37*	26	±21%	cfu/mL
20-Mar-25	2362907	TNO002	Nokweja Final	pH OS*	7.40	-	-
20-Mar-25	2362907	TNO002	Nokweja Final	Temperature OS*	24.6	-	°C
20-Mar-25	2362910	TNO002	Nokweja Final	Turbidity	11.4	±6.1%	NTU
20-Mar-25	2362923	TWA002	Washbank Final	Al (AE)	728	±7.6%	µg Al/L
20-Mar-25	2362918	TWA002	Washbank Final	Batch No.*	6240	-	-
20-Mar-25	2362918	TWA002	Washbank Final	Cl2 (F) OS*	1.68	-	mg Cl2/L
20-Mar-25	2362918	TWA002	Washbank Final	Cl2 (T) OS*	1.72	-	mg Cl2/L
20-Mar-25	2362919	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
20-Mar-25	2362918	TWA002	Washbank Final	Coll Time OS*	08:05	-	-
20-Mar-25	2362922	TWA002	Washbank Final	Conductivity	8.44	±1.5%	mS/m
20-Mar-25	2362919	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
20-Mar-25	2362919	TWA002	Washbank Final	HPC 37*	95	±21%	cfu/mL
20-Mar-25	2362918	TWA002	Washbank Final	pH OS*	7.20	-	-
20-Mar-25	2362918	TWA002	Washbank Final	Temperature OS*	19.8	-	°C
20-Mar-25	2362921	TWA002	Washbank Final	Turbidity	2.1	±6.1%	NTU
24-Mar-25	2364410	TFR002	Franklin Final	Al (AE)	288	±7.6%	µg Al/L
24-Mar-25	2364405	TFR002	Franklin Final	Batch No.*	6244	-	-
24-Mar-25	2364405	TFR002	Franklin Final	Cl2 (F) OS*	0.94	-	mg Cl2/L
24-Mar-25	2364405	TFR002	Franklin Final	Cl2 (T) OS*	1.17	-	mg Cl2/L
24-Mar-25	2364406	TFR002	Franklin Final	Coliforms*	0	±15%	MPN/100mL
24-Mar-25	2364406	TFR002	Franklin Final	Coliphages*	0	±8%	PFU/10ml
24-Mar-25	2364405	TFR002	Franklin Final	Coll Time OS*	08:04	-	-
24-Mar-25	2364408	TFR002	Franklin Final	Colour	4.30	±6.5%	mg Pt-Co/L
24-Mar-25	2364409	TFR002	Franklin Final	Conductivity	14.4	±1.5%	mS/m
24-Mar-25	2364406	TFR002	Franklin Final	E.coli*	0	±14%	MPN/100mL
24-Mar-25	2364410	TFR002	Franklin Final	Fe (AE)	0.18	±5.4%	mg Fe/L
24-Mar-25	2364406	TFR002	Franklin Final	HPC 37*	3	±21%	cfu/mL
24-Mar-25	2364410	TFR002	Franklin Final	Mn (AE)	0.01	±6.2%	mg Mn/L
24-Mar-25	2364405	TFR002	Franklin Final	pH OS*	7.60	-	-
24-Mar-25	2364405	TFR002	Franklin Final	Temperature OS*	21.0	-	°C
24-Mar-25	2364408	TFR002	Franklin Final	Turbidity	2.2	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

24-Mar-25	2364411	TFR003	Franklin Police Station Retic	Batch No.*	6244	-	-
24-Mar-25	2364411	TFR003	Franklin Police Station Retic	Cl ₂ (F) OS*	1.23	-	mg Cl ₂ /L
24-Mar-25	2364411	TFR003	Franklin Police Station Retic	Cl ₂ (T) OS*	1.28	-	mg Cl ₂ /L
24-Mar-25	2364412	TFR003	Franklin Police Station Retic	Coliforms*	0	±15%	MPN/100mL
24-Mar-25	2364411	TFR003	Franklin Police Station Retic	Coll Time OS*	08:23	-	-
24-Mar-25	2364412	TFR003	Franklin Police Station Retic	E.coli*	0	±14%	MPN/100mL
24-Mar-25	2364412	TFR003	Franklin Police Station Retic	HPC 37*	0	±21%	cfu/mL
24-Mar-25	2364411	TFR003	Franklin Police Station Retic	pH OS*	7.40	-	-
24-Mar-25	2364411	TFR003	Franklin Police Station Retic	Temperature OS*	21.0	-	°C
24-Mar-25	2364414	TFR003	Franklin Police Station Retic	Turbidity	1.9	±6.1%	NTU
24-Mar-25	2364434	TKK002	Kokstad Final	Al (AE)	<25.0	±7.6%	µg Al/L
24-Mar-25	2364429	TKK002	Kokstad Final	Batch No.*	6244	-	-
24-Mar-25	2364429	TKK002	Kokstad Final	Cl ₂ (F) OS*	1.20	-	mg Cl ₂ /L
24-Mar-25	2364429	TKK002	Kokstad Final	Cl ₂ (T) OS*	1.47	-	mg Cl ₂ /L
24-Mar-25	2364430	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
24-Mar-25	2364430	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
24-Mar-25	2364429	TKK002	Kokstad Final	Coll Time OS*	08:20	-	-
24-Mar-25	2364432	TKK002	Kokstad Final	Colour	2.00	±6.5%	mg Pt-Co/L
24-Mar-25	2364433	TKK002	Kokstad Final	Conductivity	7.55	±1.5%	mS/m
24-Mar-25	2364430	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
24-Mar-25	2364430	TKK002	Kokstad Final	HPC 37*	0	±21%	cfu/mL
24-Mar-25	2364432	TKK002	Kokstad Final	Odour*	Nil	-	-
24-Mar-25	2364429	TKK002	Kokstad Final	pH OS*	7.50	-	-
24-Mar-25	2364432	TKK002	Kokstad Final	Taste*	Nil	-	-
24-Mar-25	2364429	TKK002	Kokstad Final	Temperature OS*	21.3	-	°C
24-Mar-25	2364432	TKK002	Kokstad Final	Turbidity	<0.2	±6.1%	NTU
24-Mar-25	2364440	TKK005	Kokstad Khanyiselani Rectification	Batch No.*	6244	-	-
24-Mar-25	2364440	TKK005	Kokstad Khanyiselani Rectification	Cl ₂ (F) OS*	0.84	-	mg Cl ₂ /L
24-Mar-25	2364440	TKK005	Kokstad Khanyiselani Rectification	Cl ₂ (T) OS*	0.99	-	mg Cl ₂ /L
24-Mar-25	2364441	TKK005	Kokstad Khanyiselani Rectification	Coliforms*	>201	±15%	MPN/100mL
24-Mar-25	2364440	TKK005	Kokstad Khanyiselani Rectification	Coll Time OS*	09:51	-	-
24-Mar-25	2364441	TKK005	Kokstad Khanyiselani Rectification	E.coli*	1	±14%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

24-Mar-25	2364441	TKK005	Kokstad Khanyiselani Reticulation	HPC 37*	>1000	±21%	cfu/mL
24-Mar-25	2364440	TKK005	Kokstad Khanyiselani Reticulation	pH OS*	7.50	-	-
24-Mar-25	2364440	TKK005	Kokstad Khanyiselani Reticulation	Temperature OS*	19.4	-	°C
24-Mar-25	2364443	TKK005	Kokstad Khanyiselani Reticulation	Turbidity	0.4	±6.1%	NTU
24-Mar-25	2364444	TKK006	Kokstad Bongweni Correctional Serv Retic	Batch No.*	6244	-	-
24-Mar-25	2364444	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl2 (F) OS*	1.05	-	mg Cl2/L
24-Mar-25	2364444	TKK006	Kokstad Bongweni Correctional Serv Retic	Cl2 (T) OS*	1.17	-	mg Cl2/L
24-Mar-25	2364445	TKK006	Kokstad Bongweni Correctional Serv Retic	Coliforms*	0	±15%	MPN/100mL
24-Mar-25	2364444	TKK006	Kokstad Bongweni Correctional Serv Retic	Coll Time OS*	08:27	-	-
24-Mar-25	2364445	TKK006	Kokstad Bongweni Correctional Serv Retic	E.coli*	0	±14%	MPN/100mL
24-Mar-25	2364445	TKK006	Kokstad Bongweni Correctional Serv Retic	HPC 37*	2	±21%	cfu/mL
24-Mar-25	2364444	TKK006	Kokstad Bongweni Correctional Serv Retic	pH OS*	7.60	-	-
24-Mar-25	2364444	TKK006	Kokstad Bongweni Correctional Serv Retic	Temperature OS*	21.3	-	°C
24-Mar-25	2364447	TKK006	Kokstad Bongweni Correctional Serv Retic	Turbidity	0.4	±6.1%	NTU
24-Mar-25	2364448	TKK007	Kokstad Shayamoya Reticulation	Batch No.*	6244	-	-
24-Mar-25	2364448	TKK007	Kokstad Shayamoya Reticulation	Cl2 (F) OS*	1.32	-	mg Cl2/L
24-Mar-25	2364448	TKK007	Kokstad Shayamoya Reticulation	Cl2 (T) OS*	1.40	-	mg Cl2/L
24-Mar-25	2364449	TKK007	Kokstad Shayamoya Reticulation	Coliforms*	0	±15%	MPN/100mL
24-Mar-25	2364448	TKK007	Kokstad Shayamoya Reticulation	Coll Time OS*	09:40	-	-
24-Mar-25	2364449	TKK007	Kokstad Shayamoya Reticulation	E.coli*	0	±14%	MPN/100mL
24-Mar-25	2364449	TKK007	Kokstad Shayamoya Reticulation	HPC 37*	0	±21%	cfu/mL
24-Mar-25	2364448	TKK007	Kokstad Shayamoya Reticulation	pH OS*	7.50	-	-
24-Mar-25	2364448	TKK007	Kokstad Shayamoya Reticulation	Temperature OS*	20.2	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

24-Mar-25	2364451	TKK007	Kokstad Shayamoya Reticulation	Turbidity	0.3	±6.1%	NTU
24-Mar-25	2364452	TKK009	Kokstad Farm Fresh Produce Market	Batch No.*	6240	-	-
24-Mar-25	2364452	TKK009	Kokstad Farm Fresh Produce Market	Cl2 (F) OS*	0.19	-	mg Cl2/L
24-Mar-25	2364452	TKK009	Kokstad Farm Fresh Produce Market	Cl2 (T) OS*	0.33	-	mg Cl2/L
24-Mar-25	2364453	TKK009	Kokstad Farm Fresh Produce Market	Coliforms*	0	±15%	MPN/100mL
24-Mar-25	2364452	TKK009	Kokstad Farm Fresh Produce Market	Coll Time OS*	09:12	-	-
24-Mar-25	2364453	TKK009	Kokstad Farm Fresh Produce Market	E.coli*	0	±14%	MPN/100mL
24-Mar-25	2364453	TKK009	Kokstad Farm Fresh Produce Market	HPC 37*	0	±21%	cfu/mL
24-Mar-25	2364452	TKK009	Kokstad Farm Fresh Produce Market	pH OS*	7.30	-	-
24-Mar-25	2364452	TKK009	Kokstad Farm Fresh Produce Market	Temperature OS*	24.8	-	°C
24-Mar-25	2364455	TKK009	Kokstad Farm Fresh Produce Market	Turbidity	0.3	±6.1%	NTU
24-Mar-25	2364456	TKK012	Kokstad FET College Reticulation	Batch No.*	6244	-	-
24-Mar-25	2364456	TKK012	Kokstad FET College Reticulation	Cl2 (F) OS*	0.76	-	mg Cl2/L
24-Mar-25	2364456	TKK012	Kokstad FET College Reticulation	Cl2 (T) OS*	0.87	-	mg Cl2/L
24-Mar-25	2364457	TKK012	Kokstad FET College Reticulation	Coliforms*	0	±15%	MPN/100mL
24-Mar-25	2364456	TKK012	Kokstad FET College Reticulation	Coll Time OS*	08:00	-	-
24-Mar-25	2364457	TKK012	Kokstad FET College Reticulation	E.coli*	0	±14%	MPN/100mL
24-Mar-25	2364457	TKK012	Kokstad FET College Reticulation	HPC 37*	0	±21%	cfu/mL
24-Mar-25	2364456	TKK012	Kokstad FET College Reticulation	pH OS*	7.40	-	-
24-Mar-25	2364456	TKK012	Kokstad FET College Reticulation	Temperature OS*	20.1	-	°C
24-Mar-25	2364459	TKK012	Kokstad FET College Reticulation	Turbidity	0.4	±6.1%	NTU
24-Mar-25	2364487	TNJU002	KwaNjunga Final	Al (AE)	35.9	±7.6%	µg Al/L
24-Mar-25	2364482	TNJU002	KwaNjunga Final	Batch No.*	6244	-	-
24-Mar-25	2364482	TNJU002	KwaNjunga Final	Cl2 (F) OS*	1.33	-	mg Cl2/L
24-Mar-25	2364482	TNJU002	KwaNjunga Final	Cl2 (T) OS*	1.92	-	mg Cl2/L
24-Mar-25	2364483	TNJU002	KwaNjunga Final	Coliforms*	0	±15%	MPN/100mL
24-Mar-25	2364482	TNJU002	KwaNjunga Final	Coll Time OS*	06:58	-	-
24-Mar-25	2364486	TNJU002	KwaNjunga Final	Conductivity	15.9	±1.5%	mS/m
24-Mar-25	2364483	TNJU002	KwaNjunga Final	E.coli*	0	±14%	MPN/100mL
24-Mar-25	2364483	TNJU002	KwaNjunga Final	HPC 37*	0	±21%	cfu/mL
24-Mar-25	2364482	TNJU002	KwaNjunga Final	pH OS*	7.60	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

24-Mar-25	2364482	TNJU002	KwaNjunga Final	Temperature OS*	18.1	-	°C
24-Mar-25	2364485	TNJU002	KwaNjunga Final	Turbidity	0.9	±6.1%	NTU
25-Mar-25	2365104	TJO001	Jolivet RRT frn Vulamehlo	Batch No.*	6244	-	-
25-Mar-25	2365104	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (F) OS*	0.76	-	mg Cl2/L
25-Mar-25	2365104	TJO001	Jolivet RRT frn Vulamehlo	Cl2 (T) OS*	0.94	-	mg Cl2/L
25-Mar-25	2365105	TJO001	Jolivet RRT frn Vulamehlo	Coliforms*	0	±15%	MPN/100mL
25-Mar-25	2365104	TJO001	Jolivet RRT frn Vulamehlo	Coll Time OS*	09:12	-	-
25-Mar-25	2365105	TJO001	Jolivet RRT frn Vulamehlo	E.coli*	0	±14%	MPN/100mL
25-Mar-25	2365105	TJO001	Jolivet RRT frn Vulamehlo	HPC 37*	23	±21%	cfu/mL
25-Mar-25	2365104	TJO001	Jolivet RRT frn Vulamehlo	pH OS*	7.40	-	-
25-Mar-25	2365104	TJO001	Jolivet RRT frn Vulamehlo	Temperature OS*	20.2	-	°C
25-Mar-25	2365107	TJO001	Jolivet RRT frn Vulamehlo	Turbidity	1.0	±6.1%	NTU
25-Mar-25	2365171	TQU002	Mnqumeni Final	Batch No.*	6240	-	-
25-Mar-25	2365171	TQU002	Mnqumeni Final	Cl2 (F) OS*	1.47	-	mg Cl2/L
25-Mar-25	2365171	TQU002	Mnqumeni Final	Cl2 (T) OS*	1.50	-	mg Cl2/L
25-Mar-25	2365172	TQU002	Mnqumeni Final	Coliforms*	3	±15%	MPN/100mL
25-Mar-25	2365171	TQU002	Mnqumeni Final	Coll Time OS*	06:45	-	-
25-Mar-25	2365175	TQU002	Mnqumeni Final	Conductivity	9.90	±1.5%	mS/m
25-Mar-25	2365172	TQU002	Mnqumeni Final	E.coli*	0	±14%	MPN/100mL
25-Mar-25	2365172	TQU002	Mnqumeni Final	HPC 37*	0	±21%	cfu/mL
25-Mar-25	2365171	TQU002	Mnqumeni Final	pH OS*	7.10	-	-
25-Mar-25	2365171	TQU002	Mnqumeni Final	Temperature OS*	27.1	-	°C
25-Mar-25	2365174	TQU002	Mnqumeni Final	Turbidity	0.3	±6.1%	NTU
25-Mar-25	2365186	TSQ002	Esiqanduleni Final	Al (AE)	332	±7.6%	µg Al/L
25-Mar-25	2365181	TSQ002	Esiqanduleni Final	Batch No.*	6244	-	-
25-Mar-25	2365181	TSQ002	Esiqanduleni Final	Cl2 (F) OS*	2.50	-	mg Cl2/L
25-Mar-25	2365181	TSQ002	Esiqanduleni Final	Cl2 (T) OS*	3.50	-	mg Cl2/L
25-Mar-25	2365182	TSQ002	Esiqanduleni Final	Coliforms*	0	±15%	MPN/100mL
25-Mar-25	2365181	TSQ002	Esiqanduleni Final	Coll Time OS*	07:50	-	-
25-Mar-25	2365184	TSQ002	Esiqanduleni Final	Colour	<1.00	±6.5%	mg Pt-Co/L
25-Mar-25	2365185	TSQ002	Esiqanduleni Final	Conductivity	55.9	±1.5%	mS/m
25-Mar-25	2365182	TSQ002	Esiqanduleni Final	E.coli*	0	±14%	MPN/100mL
25-Mar-25	2365182	TSQ002	Esiqanduleni Final	HPC 37*	0	±21%	cfu/mL
25-Mar-25	2365184	TSQ002	Esiqanduleni Final	Odour*	Mild Chlorinous	-	-
25-Mar-25	2365181	TSQ002	Esiqanduleni Final	pH OS*	7.50	-	-
25-Mar-25	2365181	TSQ002	Esiqanduleni Final	Temperature OS*	24.3	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

25-Mar-25	2365184	TSQ002	Esiqanduleni Final	Turbidity	8.1	±6.1%	NTU
26-Mar-25	2366771	TIB002	Ibisi Final	Al (AE)	978	±7.6%	µg Al/L
26-Mar-25	2366766	TIB002	Ibisi Final	Batch No.*	6246	-	-
26-Mar-25	2366766	TIB002	Ibisi Final	Cl2 (F) OS*	1.64	-	mg Cl2/L
26-Mar-25	2366766	TIB002	Ibisi Final	Cl2 (T) OS*	1.79	-	mg Cl2/L
26-Mar-25	2366767	TIB002	Ibisi Final	Coliforms*	14	±15%	MPN/100mL
26-Mar-25	2366767	TIB002	Ibisi Final	Coliphages*	0	±8%	PFU/10ml
26-Mar-25	2366766	TIB002	Ibisi Final	Coll Time OS*	08.39	-	-
26-Mar-25	2366769	TIB002	Ibisi Final	Colour	<1.00	±6.5%	mg Pt-Co/L
26-Mar-25	2366770	TIB002	Ibisi Final	Conductivity	7.70	±1.5%	mS/m
26-Mar-25	2366767	TIB002	Ibisi Final	E.coli*	0	±14%	MPN/100mL
26-Mar-25	2366767	TIB002	Ibisi Final	HPC 37*	56	±21%	cfu/mL
26-Mar-25	2366769	TIB002	Ibisi Final	Odour*	Nil	-	-
26-Mar-25	2366766	TIB002	Ibisi Final	pH OS*	7.70	-	-
26-Mar-25	2366766	TIB002	Ibisi Final	Temperature OS*	16.3	-	°C
26-Mar-25	2366769	TIB002	Ibisi Final	Turbidity	12.9	±6.1%	NTU
26-Mar-25	2366772	TIB003	Ibisi Police Station Reticulation	Batch No.*	6246	-	-
26-Mar-25	2366772	TIB003	Ibisi Police Station Reticulation	Cl2 (F) OS*	1.09	-	mg Cl2/L
26-Mar-25	2366772	TIB003	Ibisi Police Station Reticulation	Cl2 (T) OS*	1.15	-	mg Cl2/L
26-Mar-25	2366773	TIB003	Ibisi Police Station Reticulation	Coliforms*	0	±15%	MPN/100mL
26-Mar-25	2366772	TIB003	Ibisi Police Station Reticulation	Coll Time OS*	08.45	-	-
26-Mar-25	2366775	TIB003	Ibisi Police Station Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
26-Mar-25	2366776	TIB003	Ibisi Police Station Reticulation	Conductivity	7.99	±1.5%	mS/m
26-Mar-25	2366773	TIB003	Ibisi Police Station Reticulation	E.coli*	0	±14%	MPN/100mL
26-Mar-25	2366773	TIB003	Ibisi Police Station Reticulation	HPC 37*	0	±21%	cfu/mL
26-Mar-25	2366772	TIB003	Ibisi Police Station Reticulation	pH OS*	7.40	-	-
26-Mar-25	2366772	TIB003	Ibisi Police Station Reticulation	Temperature OS*	16.9	-	°C
26-Mar-25	2366775	TIB003	Ibisi Police Station Reticulation	Turbidity	11.8	±6.1%	NTU
26-Mar-25	2366493	TMZ002	Umzimkhulu Final	Al (AE)	91.6	±7.6%	µg Al/L
26-Mar-25	2366488	TMZ002	Umzimkhulu Final	Batch No.*	6246	-	-
26-Mar-25	2366488	TMZ002	Umzimkhulu Final	Cl2 (F) OS*	0.99	-	mg Cl2/L
26-Mar-25	2366488	TMZ002	Umzimkhulu Final	Cl2 (T) OS*	1.13	-	mg Cl2/L
26-Mar-25	2366489	TMZ002	Umzimkhulu Final	Coliforms*	0	±15%	MPN/100mL
26-Mar-25	2366489	TMZ002	Umzimkhulu Final	Coliphages*	0	±8%	PFU/10ml
26-Mar-25	2366488	TMZ002	Umzimkhulu Final	Coll Time OS*	09.22	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

26-Mar-25	2366491	TMZ002	Umzimkhulu Final	Colour	<1.00	±6.5%	mg Pt-Co/L
26-Mar-25	2366492	TMZ002	Umzimkhulu Final	Conductivity	5.80	±1.5%	mS/m
26-Mar-25	2366489	TMZ002	Umzimkhulu Final	E.coli*	0	±14%	MPN/100mL
26-Mar-25	2366489	TMZ002	Umzimkhulu Final	HPC 37*	0	±21%	cfu/mL
26-Mar-25	2366491	TMZ002	Umzimkhulu Final	Odour*	Nil	-	-
26-Mar-25	2366488	TMZ002	Umzimkhulu Final	pH OS*	7.80	-	-
26-Mar-25	2366488	TMZ002	Umzimkhulu Final	Temperature OS*	16.4	-	°C
26-Mar-25	2366491	TMZ002	Umzimkhulu Final	Turbidity	1.5	±6.1%	NTU
26-Mar-25	2366494	TMZ004	Umzikhulu Informal Settlement Retic	Batch No.*	6246	-	-
26-Mar-25	2366494	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (F) OS*	0.82	-	mg Cl ₂ /L
26-Mar-25	2366494	TMZ004	Umzikhulu Informal Settlement Retic	Cl ₂ (T) OS*	0.97	-	mg Cl ₂ /L
26-Mar-25	2366495	TMZ004	Umzikhulu Informal Settlement Retic	Coliforms*	0	±15%	MPN/100mL
26-Mar-25	2366494	TMZ004	Umzikhulu Informal Settlement Retic	Coll Time OS*	09.20	-	-
26-Mar-25	2366497	TMZ004	Umzikhulu Informal Settlement Retic	Colour	<1.00	±6.5%	mg Pt-Co/L
26-Mar-25	2366498	TMZ004	Umzikhulu Informal Settlement Retic	Conductivity	5.86	±1.5%	mS/m
26-Mar-25	2366495	TMZ004	Umzikhulu Informal Settlement Retic	E.coli*	0	±14%	MPN/100mL
26-Mar-25	2366495	TMZ004	Umzikhulu Informal Settlement Retic	HPC 37*	1	±21%	cfu/mL
26-Mar-25	2366497	TMZ004	Umzikhulu Informal Settlement Retic	Odour*	Nil	-	-
26-Mar-25	2366494	TMZ004	Umzikhulu Informal Settlement Retic	pH OS*	7.70	-	-
26-Mar-25	2366494	TMZ004	Umzikhulu Informal Settlement Retic	Temperature OS*	17.3	-	°C
26-Mar-25	2366497	TMZ004	Umzikhulu Informal Settlement Retic	Turbidity	9.7	±6.1%	NTU
26-Mar-25	2366499	TMZ005	Umzimkhulu Local Municipality Offices	Batch No.*	6246	-	-
26-Mar-25	2366499	TMZ005	Umzimkhulu Local Municipality Offices	Cl ₂ (F) OS*	0.44	-	mg Cl ₂ /L
26-Mar-25	2366499	TMZ005	Umzimkhulu Local Municipality Offices	Cl ₂ (T) OS*	0.59	-	mg Cl ₂ /L
26-Mar-25	2366500	TMZ005	Umzimkhulu Local Municipality Offices	Coliforms*	0	±15%	MPN/100mL
26-Mar-25	2366499	TMZ005	Umzimkhulu Local Municipality Offices	Coll Time OS*	10.20	-	-
26-Mar-25	2366502	TMZ005	Umzimkhulu Local Municipality Offices	Colour	<1.00	±6.5%	mg Pt-Co/L
26-Mar-25	2366503	TMZ005	Umzimkhulu Local Municipality Offices	Conductivity	5.89	±1.5%	mS/m
26-Mar-25	2366500	TMZ005	Umzimkhulu Local Municipality Offices	E.coli*	0	±14%	MPN/100mL
26-Mar-25	2366500	TMZ005	Umzimkhulu Local Municipality Offices	HPC 37*	0	±21%	cfu/mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

26-Mar-25	2366499	TMZ005	Umzimkhulu Local Municipality Offices	pH OS*	7.60	-	-
26-Mar-25	2366499	TMZ005	Umzimkhulu Local Municipality Offices	Temperature OS*	16.9	-	°C
26-Mar-25	2366502	TMZ005	Umzimkhulu Local Municipality Offices	Turbidity	1.1	±6.1%	NTU
26-Mar-25	2366504	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Batch No.*	6246	-	-
26-Mar-25	2366504	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl ₂ (F) OS*	0.11	-	mg Cl ₂ /L
26-Mar-25	2366504	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Cl ₂ (T) OS*	0.15	-	mg Cl ₂ /L
26-Mar-25	2366505	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coliforms*	0	±15%	MPN/100mL
26-Mar-25	2366504	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Coll Time OS*	10.10	-	-
26-Mar-25	2366507	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Colour	<1.00	±6.5%	mg Pt-Co/L
26-Mar-25	2366508	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Conductivity	6.81	±1.5%	mS/m
26-Mar-25	2366505	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	E.coli*	0	±14%	MPN/100mL
26-Mar-25	2366505	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	HPC 37*	0	±21%	cfu/mL
26-Mar-25	2366504	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	pH OS*	7.50	-	-
26-Mar-25	2366504	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Temperature OS*	17.0	-	°C
26-Mar-25	2366507	TMZ006	Umzimkhulu Mbizweni Hospital Reticulation	Turbidity	5.6	±6.1%	NTU
26-Mar-25	2366509	TMZ007	Umzimkhulu Local FET College	Batch No.*	6246	-	-
26-Mar-25	2366509	TMZ007	Umzimkhulu Local FET College	Cl ₂ (F) OS*	0.15	-	mg Cl ₂ /L
26-Mar-25	2366509	TMZ007	Umzimkhulu Local FET College	Cl ₂ (T) OS*	0.22	-	mg Cl ₂ /L
26-Mar-25	2366510	TMZ007	Umzimkhulu Local FET College	Coliforms*	2	±15%	MPN/100mL
26-Mar-25	2366509	TMZ007	Umzimkhulu Local FET College	Coll Time OS*	10.00	-	-
26-Mar-25	2366512	TMZ007	Umzimkhulu Local FET College	Colour	<1.00	±6.5%	mg Pt-Co/L
26-Mar-25	2366513	TMZ007	Umzimkhulu Local FET College	Conductivity	6.94	±1.5%	mS/m
26-Mar-25	2366510	TMZ007	Umzimkhulu Local FET College	E.coli*	0	±14%	MPN/100mL
26-Mar-25	2366510	TMZ007	Umzimkhulu Local FET College	HPC 37*	12	±21%	cfu/mL
26-Mar-25	2366509	TMZ007	Umzimkhulu Local FET College	pH OS*	7.40	-	-
26-Mar-25	2366509	TMZ007	Umzimkhulu Local FET College	Temperature OS*	17.0	-	°C
26-Mar-25	2366512	TMZ007	Umzimkhulu Local FET College	Turbidity	14.8	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

26-Mar-25	2366545	TWA002	Washbank Final	Al (AE)	6204	±7.6%	µg Al/L
26-Mar-25	2366540	TWA002	Washbank Final	Batch No.*	6246	-	-
26-Mar-25	2366540	TWA002	Washbank Final	Cl2 (F) OS*	0.45	-	mg Cl2/L
26-Mar-25	2366540	TWA002	Washbank Final	Cl2 (T) OS*	0.69	-	mg Cl2/L
26-Mar-25	2366541	TWA002	Washbank Final	Coliforms*	0	±15%	MPN/100mL
26-Mar-25	2366540	TWA002	Washbank Final	Coll Time OS*	08.51	-	-
26-Mar-25	2366543	TWA002	Washbank Final	Colour	8.50	±6.5%	mg Pt-Co/L
26-Mar-25	2366544	TWA002	Washbank Final	Conductivity	11.4	±1.5%	mS/m
26-Mar-25	2366541	TWA002	Washbank Final	E.coli*	0	±14%	MPN/100mL
26-Mar-25	2366541	TWA002	Washbank Final	HPC 37*	0	±21%	cfu/mL
26-Mar-25	2366543	TWA002	Washbank Final	Odour*	Mild Chlorinous	-	-
26-Mar-25	2366540	TWA002	Washbank Final	pH OS*	7.70	-	-
26-Mar-25	2366540	TWA002	Washbank Final	Temperature OS*	17.0	-	°C
26-Mar-25	2366543	TWA002	Washbank Final	Turbidity	12.7	±6.1%	NTU
27-Mar-25	2365692	TBU002	Bulwer Final	Batch No.*	6246	-	-
27-Mar-25	2365692	TBU002	Bulwer Final	Cl2 (F) OS*	0.98	-	mg Cl2/L
27-Mar-25	2365692	TBU002	Bulwer Final	Cl2 (T) OS*	1.20	-	mg Cl2/L
27-Mar-25	2365693	TBU002	Bulwer Final	Coliforms*	0	±15%	MPN/100mL
27-Mar-25	2365692	TBU002	Bulwer Final	Coll Time OS*	11:40	-	-
27-Mar-25	2365695	TBU002	Bulwer Final	Colour	2.60	±6.5%	mg Pt-Co/L
27-Mar-25	2365696	TBU002	Bulwer Final	Conductivity	4.19	±1.5%	mS/m
27-Mar-25	2365693	TBU002	Bulwer Final	E.coli*	0	±14%	MPN/100mL
27-Mar-25	2365693	TBU002	Bulwer Final	HPC 37*	19	±21%	cfu/mL
27-Mar-25	2365695	TBU002	Bulwer Final	Odour*	Nil	-	-
27-Mar-25	2365692	TBU002	Bulwer Final	pH OS*	7.80	-	-
27-Mar-25	2365692	TBU002	Bulwer Final	Temperature OS*	16.8	-	°C
27-Mar-25	2365695	TBU002	Bulwer Final	Turbidity	9.0	±6.1%	NTU
27-Mar-25	2365697	TBU005	Bulwer Mountain Park Hotel Retic	Batch No.*	6246	-	-
27-Mar-25	2365697	TBU005	Bulwer Mountain Park Hotel Retic	Cl2 (F) OS*	0.68	-	mg Cl2/L
27-Mar-25	2365697	TBU005	Bulwer Mountain Park Hotel Retic	Cl2 (T) OS*	0.94	-	mg Cl2/L
27-Mar-25	2365698	TBU005	Bulwer Mountain Park Hotel Retic	Coliforms*	0	±15%	MPN/100mL
27-Mar-25	2365697	TBU005	Bulwer Mountain Park Hotel Retic	Coll Time OS*	12:15	-	-
27-Mar-25	2365698	TBU005	Bulwer Mountain Park Hotel Retic	E.coli*	0	±14%	MPN/100mL
27-Mar-25	2365698	TBU005	Bulwer Mountain Park Hotel Retic	HPC 37*	1	±21%	cfu/mL
27-Mar-25	2365697	TBU005	Bulwer Mountain Park Hotel Retic	pH OS*	7.60	-	-
27-Mar-25	2365697	TBU005	Bulwer Mountain Park Hotel Retic	Temperature OS*	16.1	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

27-Mar-25	2365700	TBU005	Bulwer Mountain Park Hotel Retic	Turbidity	2.4	±6.1%	NTU
27-Mar-25	2365711	TCR002	Creighton Final	Al (AE)	722	±7.6%	µg Al/L
27-Mar-25	2365706	TCR002	Creighton Final	Batch No.*	6246	-	-
27-Mar-25	2365706	TCR002	Creighton Final	Cl ₂ (F) OS*	0.41	-	mg Cl ₂ /L
27-Mar-25	2365706	TCR002	Creighton Final	Cl ₂ (T) OS*	0.73	-	mg Cl ₂ /L
27-Mar-25	2365707	TCR002	Creighton Final	Coliforms*	0	±15%	MPN/100mL
27-Mar-25	2365706	TCR002	Creighton Final	Coll Time OS*	12:49	-	-
27-Mar-25	2365710	TCR002	Creighton Final	Conductivity	9.78	±1.5%	mS/m
27-Mar-25	2365707	TCR002	Creighton Final	E.coli*	0	±14%	MPN/100mL
27-Mar-25	2365707	TCR002	Creighton Final	HPC 37*	11	±21%	cfu/mL
27-Mar-25	2365706	TCR002	Creighton Final	pH OS*	7.70	-	-
27-Mar-25	2365706	TCR002	Creighton Final	Temperature OS*	17.0	-	°C
27-Mar-25	2365709	TCR002	Creighton Final	Turbidity	13.9	±6.1%	NTU
27-Mar-25	2365712	TCR004	Creighton Madondo Cottages	Batch No.*	6246	-	-
27-Mar-25	2365712	TCR004	Creighton Madondo Cottages	Cl ₂ (F) OS*	0.28	-	mg Cl ₂ /L
27-Mar-25	2365712	TCR004	Creighton Madondo Cottages	Cl ₂ (T) OS*	0.54	-	mg Cl ₂ /L
27-Mar-25	2365713	TCR004	Creighton Madondo Cottages	Coliforms*	0	±15%	MPN/100mL
27-Mar-25	2365712	TCR004	Creighton Madondo Cottages	Coll Time OS*	07:50	-	-
27-Mar-25	2365713	TCR004	Creighton Madondo Cottages	E.coli*	0	±14%	MPN/100mL
27-Mar-25	2365713	TCR004	Creighton Madondo Cottages	HPC 37*	1	±21%	cfu/mL
27-Mar-25	2365712	TCR004	Creighton Madondo Cottages	pH OS*	7.70	-	-
27-Mar-25	2365712	TCR004	Creighton Madondo Cottages	Temperature OS*	16.3	-	°C
27-Mar-25	2365715	TCR004	Creighton Madondo Cottages	Turbidity	7.0	±6.1%	NTU
27-Mar-25	2365725	THL002	Hlanganani Final	Batch No.*	6246	-	-
27-Mar-25	2365725	THL002	Hlanganani Final	Cl ₂ (F) OS*	1.05	-	mg Cl ₂ /L
27-Mar-25	2365725	THL002	Hlanganani Final	Cl ₂ (T) OS*	1.11	-	mg Cl ₂ /L
27-Mar-25	2365726	THL002	Hlanganani Final	Coliforms*	0	±15%	MPN/100mL
27-Mar-25	2365725	THL002	Hlanganani Final	Coll Time OS*	13:03	-	-
27-Mar-25	2365728	THL002	Hlanganani Final	Colour	2.20	±6.5%	mg Pt-Co/L
27-Mar-25	2365729	THL002	Hlanganani Final	Conductivity	6.91	±1.5%	mS/m
27-Mar-25	2365726	THL002	Hlanganani Final	E.coli*	0	±14%	MPN/100mL
27-Mar-25	2365726	THL002	Hlanganani Final	HPC 37*	0	±21%	cfu/mL
27-Mar-25	2365728	THL002	Hlanganani Final	Odour*	Nil	-	-
27-Mar-25	2365725	THL002	Hlanganani Final	pH OS*	7.50	-	-
27-Mar-25	2365728	THL002	Hlanganani Final	Taste*	Nil	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)

27-Mar-25	2365725	THL002	Hlanganani Final	Temperature OS*	17.0	-	°C
27-Mar-25	2365728	THL002	Hlanganani Final	Turbidity	<0.2	±6.1%	NTU
27-Mar-25	2365730	THL003	Hlanganani Clinic Reticulation	Batch No.*	6246	-	-
27-Mar-25	2365730	THL003	Hlanganani Clinic Reticulation	Cl2 (F) OS*	0.41	-	mg Cl2/L
27-Mar-25	2365730	THL003	Hlanganani Clinic Reticulation	Cl2 (T) OS*	0.73	-	mg Cl2/L
27-Mar-25	2365731	THL003	Hlanganani Clinic Reticulation	Coliforms*	0	±15%	MPN/100mL
27-Mar-25	2365730	THL003	Hlanganani Clinic Reticulation	Coll Time OS*	12:49	-	-
27-Mar-25	2365731	THL003	Hlanganani Clinic Reticulation	E.coli*	0	±14%	MPN/100mL
27-Mar-25	2365731	THL003	Hlanganani Clinic Reticulation	HPC 37*	6	±21%	cfu/mL
27-Mar-25	2365730	THL003	Hlanganani Clinic Reticulation	pH OS*	7.70	-	-
27-Mar-25	2365730	THL003	Hlanganani Clinic Reticulation	Temperature OS*	17.0	-	°C
27-Mar-25	2365733	THL003	Hlanganani Clinic Reticulation	Turbidity	<0.2	±6.1%	NTU
27-Mar-25	2365756	TMQA002	Mqatsheni Final	Batch No.*	6246	-	-
27-Mar-25	2365756	TMQA002	Mqatsheni Final	Cl2 (F) OS*	0.41	-	mg Cl2/L
27-Mar-25	2365756	TMQA002	Mqatsheni Final	Cl2 (T) OS*	0.68	-	mg Cl2/L
27-Mar-25	2365757	TMQA002	Mqatsheni Final	Coliforms*	0	±15%	MPN/100mL
27-Mar-25	2365756	TMQA002	Mqatsheni Final	Coll Time OS*	10:30	-	-
27-Mar-25	2365759	TMQA002	Mqatsheni Final	Colour	1.90	±6.5%	mg Pt-Co/L
27-Mar-25	2365760	TMQA002	Mqatsheni Final	Conductivity	27.1	±1.5%	mS/m
27-Mar-25	2365757	TMQA002	Mqatsheni Final	E.coli*	0	±14%	MPN/100mL
27-Mar-25	2365757	TMQA002	Mqatsheni Final	HPC 37*	44	±21%	cfu/mL
27-Mar-25	2365759	TMQA002	Mqatsheni Final	Odour*	Nil	-	-
27-Mar-25	2365756	TMQA002	Mqatsheni Final	pH OS*	7.70	-	-
27-Mar-25	2365756	TMQA002	Mqatsheni Final	Temperature OS*	16.3	-	°C
27-Mar-25	2365759	TMQA002	Mqatsheni Final	Turbidity	1.8	±6.1%	NTU
27-Mar-25	2365761	TMQA003	Mqatsheni Reticulation	Batch No.*	6246	-	-
27-Mar-25	2365761	TMQA003	Mqatsheni Reticulation	Cl2 (F) OS*	0.15	-	mg Cl2/L
27-Mar-25	2365761	TMQA003	Mqatsheni Reticulation	Cl2 (T) OS*	0.37	-	mg Cl2/L
27-Mar-25	2365762	TMQA003	Mqatsheni Reticulation	Coliforms*	0	±15%	MPN/100mL
27-Mar-25	2365761	TMQA003	Mqatsheni Reticulation	Coll Time OS*	10:24	-	-
27-Mar-25	2365762	TMQA003	Mqatsheni Reticulation	E.coli*	0	±14%	MPN/100mL
27-Mar-25	2365762	TMQA003	Mqatsheni Reticulation	HPC 37*	1	±21%	cfu/mL
27-Mar-25	2365761	TMQA003	Mqatsheni Reticulation	pH OS*	7.70	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

27-Mar-25	2365761	TMQA003	Mqatsheni Reticulation	Temperature OS*	16.6	-	°C
27-Mar-25	2365764	TMQA003	Mqatsheni Reticulation	Turbidity	0.8	±6.1%	NTU
27-Mar-25	2365775	TRV002	Riverside Final	Al (AE)	<25.0	±7.6%	µg Al/L
27-Mar-25	2365770	TRV002	Riverside Final	Batch No.*	6246	-	-
27-Mar-25	2365770	TRV002	Riverside Final	Cl ₂ (F) OS*	2.50	-	mg Cl ₂ /L
27-Mar-25	2365770	TRV002	Riverside Final	Cl ₂ (T) OS*	3.50	-	mg Cl ₂ /L
27-Mar-25	2365771	TRV002	Riverside Final	Coliforms*	0	±15%	MPN/100mL
27-Mar-25	2365771	TRV002	Riverside Final	Coliphages*	0	±8%	PFU/10ml
27-Mar-25	2365770	TRV002	Riverside Final	Coll Time OS*	09:01	-	-
27-Mar-25	2365773	TRV002	Riverside Final	Colour	1.70	±6.5%	mg Pt-Co/L
27-Mar-25	2365774	TRV002	Riverside Final	Conductivity	15.6	±1.5%	mS/m
27-Mar-25	2365771	TRV002	Riverside Final	E.coli*	0	±14%	MPN/100mL
27-Mar-25	2365771	TRV002	Riverside Final	HPC 37*	265	±21%	cfu/mL
27-Mar-25	2365773	TRV002	Riverside Final	Odour*	Nil	-	-
27-Mar-25	2365770	TRV002	Riverside Final	pH OS*	7.90	-	-
27-Mar-25	2365773	TRV002	Riverside Final	Taste*	Nil	-	-
27-Mar-25	2365770	TRV002	Riverside Final	Temperature OS*	17.0	-	°C
27-Mar-25	2365773	TRV002	Riverside Final	Turbidity	0.5	±6.1%	NTU
27-Mar-25	2365776	TRV003	Riverside Reticulation	Batch No.*	6246	-	-
27-Mar-25	2365776	TRV003	Riverside Reticulation	Cl ₂ (F) OS*	1.47	-	mg Cl ₂ /L
27-Mar-25	2365776	TRV003	Riverside Reticulation	Cl ₂ (T) OS*	1.76	-	mg Cl ₂ /L
27-Mar-25	2365777	TRV003	Riverside Reticulation	Coliforms*	0	±15%	MPN/100mL
27-Mar-25	2365776	TRV003	Riverside Reticulation	Coll Time OS*	09:11	-	-
27-Mar-25	2365777	TRV003	Riverside Reticulation	E.coli*	0	±14%	MPN/100mL
27-Mar-25	2365777	TRV003	Riverside Reticulation	HPC 37*	0	±21%	cfu/mL
27-Mar-25	2365776	TRV003	Riverside Reticulation	pH OS*	7.80	-	-
27-Mar-25	2365776	TRV003	Riverside Reticulation	Temperature OS*	17.0	-	°C
27-Mar-25	2365779	TRV003	Riverside Reticulation	Turbidity	7.3	±6.1%	NTU
27-Mar-25	2365801	TUN002	Underberg Final	Al (AE)	143	±7.6%	µg Al/L
27-Mar-25	2365796	TUN002	Underberg Final	Batch No.*	6246	-	-
27-Mar-25	2365796	TUN002	Underberg Final	Cl ₂ (F) OS*	0.44	-	mg Cl ₂ /L
27-Mar-25	2365796	TUN002	Underberg Final	Cl ₂ (T) OS*	0.65	-	mg Cl ₂ /L
27-Mar-25	2365797	TUN002	Underberg Final	Coliforms*	0	±15%	MPN/100mL
27-Mar-25	2365796	TUN002	Underberg Final	Coll Time OS*	11:24	-	-
27-Mar-25	2365799	TUN002	Underberg Final	Colour	<1.00	±6.5%	mg Pt-Co/L
27-Mar-25	2365800	TUN002	Underberg Final	Conductivity	4.62	±1.5%	mS/m
27-Mar-25	2365797	TUN002	Underberg Final	E.coli*	0	±14%	MPN/100mL
27-Mar-25	2365797	TUN002	Underberg Final	HPC 37*	2	±21%	cfu/mL
27-Mar-25	2365799	TUN002	Underberg Final	Odour*	Nil	-	-
27-Mar-25	2365796	TUN002	Underberg Final	pH OS*	7.60	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzok | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

27-Mar-25	2365796	TUN002	Underberg Final	Temperature OS*	16.7	-	°C
27-Mar-25	2365799	TUN002	Underberg Final	Turbidity	1.7	±6.1%	NTU
31-Mar-25	2367676	TKK002	Kokstad Final	Al (AE)	29.7	±7.6%	µg Al/L
31-Mar-25	2367671	TKK002	Kokstad Final	Batch No.*	6246	-	-
31-Mar-25	2367671	TKK002	Kokstad Final	Cl ₂ (F) OS*	1.35	-	mg Cl ₂ /L
31-Mar-25	2367671	TKK002	Kokstad Final	Cl ₂ (T) OS*	1.47	-	mg Cl ₂ /L
31-Mar-25	2367672	TKK002	Kokstad Final	Coliforms*	0	±15%	MPN/100mL
31-Mar-25	2367672	TKK002	Kokstad Final	Coliphages*	0	±8%	PFU/10ml
31-Mar-25	2367671	TKK002	Kokstad Final	Coll Time OS*	08:12	-	-
31-Mar-25	2367675	TKK002	Kokstad Final	Conductivity	11.7	±1.5%	mS/m
31-Mar-25	2367672	TKK002	Kokstad Final	E.coli*	0	±14%	MPN/100mL
31-Mar-25	2367672	TKK002	Kokstad Final	HPC 37*	2	±21%	cfu/mL
31-Mar-25	2367671	TKK002	Kokstad Final	pH OS*	7.50	-	-
31-Mar-25	2367671	TKK002	Kokstad Final	Temperature OS*	21.3	-	°C
31-Mar-25	2367674	TKK002	Kokstad Final	Turbidity	0.2	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)