

Date: 08 April 2025

The Executive Director: Water Services Department

Harry Gwala District Municipality

40 Main Street

Ixopo

3276

Attention: Basetsana Khathalib and Bheki Nene

MARCH 2025 UNTREATED WATER (RAW) RESULTS

Please find March 2025 Untreated Water (Raw) results tabulated below for samples received during March 2025. Determinands marked with an asterisk are unaccredited and are not included in uMngeni-uThukela Water's schedule of accreditation.

Please contact us immediately should you have any queries.

Yours' Sincerely

Mr M Sewcharan

Client Services Manager

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Sample Date	Sample Number	Sampling Point	Description	Determinand	Result	UOM	Unit
03-Mar-25	2353910	TFR001	Franklin Raw	Al (AE)	581	±7.6%	µg Al/L
03-Mar-25	2353907	TFR001	Franklin Raw	Coliforms*	>2420	±22%	MPN/100mL
03-Mar-25	2353907	TFR001	Franklin Raw	Coliphages*	120	±8%	PFU/10ml
03-Mar-25	2353906	TFR001	Franklin Raw	Coll Time OS*	07:33	-	-
03-Mar-25	2353909	TFR001	Franklin Raw	Conductivity	8.80	±1.5%	mS/m
03-Mar-25	2353907	TFR001	Franklin Raw	E.coli*	1986	±21%	MPN/100mL
03-Mar-25	2353906	TFR001	Franklin Raw	pH OS*	7.20	-	-
03-Mar-25	2353906	TFR001	Franklin Raw	Temperature OS*	18.7	-	°C
03-Mar-25	2353908	TFR001	Franklin Raw	Turbidity	72.5	±6.1%	NTU
04-Mar-25	2356415	TQU001	Mnqumeni Raw	Coliforms*	47	±22%	MPN/100mL
04-Mar-25	2356414	TQU001	Mnqumeni Raw	Coll Time OS*	07:20	-	-
04-Mar-25	2356416	TQU001	Mnqumeni Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
04-Mar-25	2356417	TQU001	Mnqumeni Raw	Conductivity	10.2	±1.5%	mS/m
04-Mar-25	2356415	TQU001	Mnqumeni Raw	E.coli*	0	±21%	MPN/100mL
04-Mar-25	2356416	TQU001	Mnqumeni Raw	Odour*	Nil	-	-
04-Mar-25	2356414	TQU001	Mnqumeni Raw	pH OS*	7.00	-	-
04-Mar-25	2356414	TQU001	Mnqumeni Raw	Temperature OS*	23.9	-	°C
04-Mar-25	2356416	TQU001	Mnqumeni Raw	Turbidity	3.9	±6.1%	NTU
04-Mar-25	2356428	TSQ001	Esiqanduleni Raw	Al (AE)	601	±7.6%	µg Al/L
04-Mar-25	2356425	TSQ001	Esiqanduleni Raw	Coliforms*	>2420	±22%	MPN/100mL
04-Mar-25	2356425	TSQ001	Esiqanduleni Raw	Coliphages*	131	±8%	PFU/10ml
04-Mar-25	2356424	TSQ001	Esiqanduleni Raw	Coll Time OS*	08:00	-	-
04-Mar-25	2356427	TSQ001	Esiqanduleni Raw	Conductivity	7.49	±1.5%	mS/m
04-Mar-25	2356425	TSQ001	Esiqanduleni Raw	E.coli*	770	±21%	MPN/100mL
04-Mar-25	2356424	TSQ001	Esiqanduleni Raw	pH OS*	7.50	-	-
04-Mar-25	2356424	TSQ001	Esiqanduleni Raw	Temperature OS*	20.2	-	°C
04-Mar-25	2356426	TSQ001	Esiqanduleni Raw	Turbidity	78.8	±6.1%	NTU
05-Mar-25	2354523	TBU001	Bulwer Raw	Al (AE)	3597	±7.6%	µg Al/L
05-Mar-25	2354520	TBU001	Bulwer Raw	Coliforms*	>2420	±22%	MPN/100mL
05-Mar-25	2354519	TBU001	Bulwer Raw	Coll Time OS*	09:58	-	-
05-Mar-25	2354521	TBU001	Bulwer Raw	Colour	18.7	±6.5%	mg Pt-Co/L
05-Mar-25	2354522	TBU001	Bulwer Raw	Conductivity	4.01	±1.5%	mS/m
05-Mar-25	2354520	TBU001	Bulwer Raw	E.coli*	770	±21%	MPN/100mL
05-Mar-25	2354523	TBU001	Bulwer Raw	Fe (AE)	2.12	±5.4%	mg Fe/L
05-Mar-25	2354519	TBU001	Bulwer Raw	pH OS*	7.60	-	-
05-Mar-25	2354519	TBU001	Bulwer Raw	Temperature OS*	22.3	-	°C
05-Mar-25	2354521	TBU001	Bulwer Raw	Turbidity	47.1	±6.1%	NTU
05-Mar-25	2354534	TCR001	Creighton Raw	Al (AE)	1002	±7.6%	µg Al/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

05-Mar-25	2354531	TCR001	Creighton Raw	Coliforms*	>2420	±22%	MPN/100mL
05-Mar-25	2354530	TCR001	Creighton Raw	Coll Time OS*	07:58	-	-
05-Mar-25	2354532	TCR001	Creighton Raw	Colour	16.6	±6.5%	mg Pt-Co/L
05-Mar-25	2354533	TCR001	Creighton Raw	Conductivity	5.09	±1.5%	mS/m
05-Mar-25	2354531	TCR001	Creighton Raw	E.coli*	2420	±21%	MPN/100mL
05-Mar-25	2354534	TCR001	Creighton Raw	Fe (AE)	1.49	±5.4%	mg Fe/L
05-Mar-25	2354534	TCR001	Creighton Raw	Mn (AE)	0.07	±6.2%	mg Mn/L
05-Mar-25	2354532	TCR001	Creighton Raw	Odour*	Nil	-	-
05-Mar-25	2354530	TCR001	Creighton Raw	pH OS*	7.50	-	-
05-Mar-25	2354530	TCR001	Creighton Raw	Temperature OS*	21.2	-	°C
05-Mar-25	2354532	TCR001	Creighton Raw	Turbidity	202.0	±6.1%	NTU
05-Mar-25	2354542	THL001	Hlanganani Raw	Coliforms*	>2420	±22%	MPN/100mL
05-Mar-25	2354541	THL001	Hlanganani Raw	Coll Time OS*	10:30	-	-
05-Mar-25	2354543	THL001	Hlanganani Raw	Colour	9.60	±6.5%	mg Pt-Co/L
05-Mar-25	2354544	THL001	Hlanganani Raw	Conductivity	5.40	±1.5%	mS/m
05-Mar-25	2354542	THL001	Hlanganani Raw	E.coli*	435	±21%	MPN/100mL
05-Mar-25	2354543	THL001	Hlanganani Raw	Odour*	Nil	-	-
05-Mar-25	2354541	THL001	Hlanganani Raw	pH OS*	7.30	-	-
05-Mar-25	2354541	THL001	Hlanganani Raw	Temperature OS*	26.4	-	°C
05-Mar-25	2354543	THL001	Hlanganani Raw	Turbidity	40.7	±6.1%	NTU
05-Mar-25	2354570	TMQA001	Mqatsheni Raw	Al (AE)	109	±7.6%	µg Al/L
05-Mar-25	2354567	TMQA001	Mqatsheni Raw	Coliforms*	0	±22%	MPN/100mL
05-Mar-25	2354566	TMQA001	Mqatsheni Raw	Coll Time OS*	08:09	-	-
05-Mar-25	2354568	TMQA001	Mqatsheni Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
05-Mar-25	2354569	TMQA001	Mqatsheni Raw	Conductivity	25.6	±1.5%	mS/m
05-Mar-25	2354567	TMQA001	Mqatsheni Raw	E.coli*	0	±21%	MPN/100mL
05-Mar-25	2354570	TMQA001	Mqatsheni Raw	Fe (AE)	0.04	±5.4%	mg Fe/L
05-Mar-25	2354566	TMQA001	Mqatsheni Raw	pH OS*	9.10	-	-
05-Mar-25	2354566	TMQA001	Mqatsheni Raw	Temperature OS*	20.1	-	°C
05-Mar-25	2354568	TMQA001	Mqatsheni Raw	Turbidity	2.8	±6.1%	NTU
05-Mar-25	2354581	TRV001	Riversside Raw	Al (AE)	1377	±7.6%	µg Al/L
05-Mar-25	2354578	TRV001	Riversside Raw	Coliforms*	365	±22%	MPN/100mL
05-Mar-25	2354577	TRV001	Riversside Raw	Coll Time OS*	08:40	-	-
05-Mar-25	2354579	TRV001	Riversside Raw	Colour	2.70	±6.5%	mg Pt-Co/L
05-Mar-25	2354580	TRV001	Riversside Raw	Conductivity	5.58	±1.5%	mS/m
05-Mar-25	2354578	TRV001	Riversside Raw	E.coli*	29	±21%	MPN/100mL
05-Mar-25	2354581	TRV001	Riversside Raw	Fe (AE)	0.29	±5.4%	mg Fe/L
05-Mar-25	2354579	TRV001	Riversside Raw	Odour*	Nil	-	-
05-Mar-25	2354577	TRV001	Riversside Raw	pH OS*	7.60	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

05-Mar-25	2354577	TRV001	Riversside Raw	Temperature OS*	22.2	-	°C
05-Mar-25	2354579	TRV001	Riversside Raw	Turbidity	17.5	±6.1%	NTU
05-Mar-25	2354603	TUN001	Underberg Raw	Al (AE)	672	±7.6%	µg Al/L
05-Mar-25	2354600	TUN001	Underberg Raw	Coliforms*	>2420	±22%	MPN/100mL
05-Mar-25	2354600	TUN001	Underberg Raw	Coliphages*	80	±8%	PFU/10ml
05-Mar-25	2354599	TUN001	Underberg Raw	Coll Time OS*	09:31	-	-
05-Mar-25	2354601	TUN001	Underberg Raw	Colour	7.00	±6.5%	mg Pt-Co/L
05-Mar-25	2354602	TUN001	Underberg Raw	Conductivity	4.85	±1.5%	mS/m
05-Mar-25	2354600	TUN001	Underberg Raw	E.coli*	517	±21%	MPN/100mL
05-Mar-25	2354603	TUN001	Underberg Raw	Fe (AE)	0.75	±5.4%	mg Fe/L
05-Mar-25	2354601	TUN001	Underberg Raw	Odour*	Nil	-	-
05-Mar-25	2354599	TUN001	Underberg Raw	pH OS*	7.30	-	-
05-Mar-25	2354599	TUN001	Underberg Raw	Temperature OS*	19.8	-	°C
05-Mar-25	2354601	TUN001	Underberg Raw	Turbidity	18.8	±6.1%	NTU
06-Mar-25	2355323	TMZ001	Umzimkhulu Raw	Al (AE)	953	±7.6%	µg Al/L
06-Mar-25	2355320	TMZ001	Umzimkhulu Raw	Coliforms*	>2420	±22%	MPN/100mL
06-Mar-25	2355320	TMZ001	Umzimkhulu Raw	Coliphages*	268	±8%	PFU/10ml
06-Mar-25	2355319	TMZ001	Umzimkhulu Raw	Coll Time OS*	07:08	-	-
06-Mar-25	2355322	TMZ001	Umzimkhulu Raw	Conductivity	5.87	±1.5%	mS/m
06-Mar-25	2355320	TMZ001	Umzimkhulu Raw	E.coli*	1203	±21%	MPN/100mL
06-Mar-25	2355319	TMZ001	Umzimkhulu Raw	pH OS*	7.40	-	-
06-Mar-25	2355319	TMZ001	Umzimkhulu Raw	Temperature OS*	23.5	-	°C
06-Mar-25	2355321	TMZ001	Umzimkhulu Raw	Turbidity	218.0	±6.1%	NTU
06-Mar-25	2355334	TNO001	Nokweja Raw	Al (AE)	4075	±7.6%	µg Al/L
06-Mar-25	2355331	TNO001	Nokweja Raw	Coliforms*	>2420	±22%	MPN/100mL
06-Mar-25	2355331	TNO001	Nokweja Raw	Coliphages*	36	±8%	PFU/10ml
06-Mar-25	2355330	TNO001	Nokweja Raw	Coll Time OS*	07:52	-	-
06-Mar-25	2355333	TNO001	Nokweja Raw	Conductivity	6.64	±1.5%	mS/m
06-Mar-25	2355331	TNO001	Nokweja Raw	E.coli*	1986	±21%	MPN/100mL
06-Mar-25	2355330	TNO001	Nokweja Raw	pH OS*	7.40	-	-
06-Mar-25	2355330	TNO001	Nokweja Raw	Temperature OS*	23.1	-	°C
06-Mar-25	2355332	TNO001	Nokweja Raw	Turbidity	118.0	±6.1%	NTU
07-Mar-25	2355573	TIB001	Ibisi Raw	Al (AE)	763	±7.6%	µg Al/L
07-Mar-25	2355570	TIB001	Ibisi Raw	Coliforms*	>2420	±22%	MPN/100mL
07-Mar-25	2355570	TIB001	Ibisi Raw	Coliphages*	68	±8%	PFU/10ml
07-Mar-25	2355569	TIB001	Ibisi Raw	Coll Time OS*	07:07	-	-
07-Mar-25	2355572	TIB001	Ibisi Raw	Conductivity	5.87	±1.5%	mS/m
07-Mar-25	2355570	TIB001	Ibisi Raw	E.coli*	488	±21%	MPN/100mL
07-Mar-25	2355569	TIB001	Ibisi Raw	pH OS*	7.30	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

07-Mar-25	2355569	TIB001	Ibisi Raw	Temperature OS*	24.0	-	°C
07-Mar-25	2355571	TIB001	Ibisi Raw	Turbidity	58.7	±6.1%	NTU
10-Mar-25	2357225	TFR001	Franklin Raw	AI (AE)	427	±7.6%	µg AI/L
10-Mar-25	2357222	TFR001	Franklin Raw	Coliforms*	>2420	±22%	MPN/100mL
10-Mar-25	2357222	TFR001	Franklin Raw	Coliphages*	29	±8%	PFU/10ml
10-Mar-25	2357221	TFR001	Franklin Raw	Coll Time OS*	09:23	-	-
10-Mar-25	2357224	TFR001	Franklin Raw	Conductivity	7.39	±1.5%	mS/m
10-Mar-25	2357222	TFR001	Franklin Raw	E.coli*	231	±21%	MPN/100mL
10-Mar-25	2357221	TFR001	Franklin Raw	pH OS*	7.00	-	-
10-Mar-25	2357221	TFR001	Franklin Raw	Temperature OS*	22.8	-	°C
10-Mar-25	2357223	TFR001	Franklin Raw	Turbidity	31.4	±6.1%	NTU
10-Mar-25	2357250	TKK001	Kokstad River Raw	AI (AE)	230	±7.6%	µg AI/L
10-Mar-25	2357247	TKK001	Kokstad River Raw	Coliforms*	>2420	±22%	MPN/100mL
10-Mar-25	2357247	TKK001	Kokstad River Raw	Coliphages*	113	±8%	PFU/10ml
10-Mar-25	2357246	TKK001	Kokstad River Raw	Coll Time OS*	09:58	-	-
10-Mar-25	2357249	TKK001	Kokstad River Raw	Conductivity	10.2	±1.5%	mS/m
10-Mar-25	2357247	TKK001	Kokstad River Raw	E.coli*	133	±21%	MPN/100mL
10-Mar-25	2357246	TKK001	Kokstad River Raw	pH OS*	7.30	-	-
10-Mar-25	2357246	TKK001	Kokstad River Raw	Temperature OS*	19.7	-	°C
10-Mar-25	2357248	TKK001	Kokstad River Raw	Turbidity	32.7	±6.1%	NTU
10-Mar-25	2357261	TKK003	Kokstad Crystal Spring Raw	AI (AE)	396	±7.6%	µg AI/L
10-Mar-25	2357258	TKK003	Kokstad Crystal Spring Raw	Coliforms*	>2420	±22%	MPN/100mL
10-Mar-25	2357258	TKK003	Kokstad Crystal Spring Raw	Coliphages*	56	±8%	PFU/10ml
10-Mar-25	2357257	TKK003	Kokstad Crystal Spring Raw	Coll Time OS*	10:05	-	-
10-Mar-25	2357260	TKK003	Kokstad Crystal Spring Raw	Conductivity	9.82	±1.5%	mS/m
10-Mar-25	2357258	TKK003	Kokstad Crystal Spring Raw	E.coli*	53	±21%	MPN/100mL
10-Mar-25	2357257	TKK003	Kokstad Crystal Spring Raw	pH OS*	7.40	-	-
10-Mar-25	2357257	TKK003	Kokstad Crystal Spring Raw	Temperature OS*	19.2	-	°C
10-Mar-25	2357259	TKK003	Kokstad Crystal Spring Raw	Turbidity	21.6	±6.1%	NTU
11-Mar-25	2358019	TQU001	Mnqumeni Raw	Coliforms*	>2420	±22%	MPN/100mL
11-Mar-25	2358018	TQU001	Mnqumeni Raw	Coll Time OS*	06:25	-	-
11-Mar-25	2358021	TQU001	Mnqumeni Raw	Conductivity	8.34	±1.5%	mS/m
11-Mar-25	2358019	TQU001	Mnqumeni Raw	E.coli*	194	±21%	MPN/100mL
11-Mar-25	2358018	TQU001	Mnqumeni Raw	pH OS*	7.30	-	-
11-Mar-25	2358018	TQU001	Mnqumeni Raw	Temperature OS*	20.1	-	°C
11-Mar-25	2358020	TQU001	Mnqumeni Raw	Turbidity	33.3	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

11-Mar-25	2358031	TSQ001	Esiqanduleni Raw	AI (AE)	511	±7.6%	µg AI/L
11-Mar-25	2358028	TSQ001	Esiqanduleni Raw	Coliforms*	>2420	±22%	MPN/100mL
11-Mar-25	2358028	TSQ001	Esiqanduleni Raw	Coliphages*	6	±8%	PFU/10ml
11-Mar-25	2358027	TSQ001	Esiqanduleni Raw	Coll Time OS*	08:21	-	-
11-Mar-25	2358030	TSQ001	Esiqanduleni Raw	Conductivity	7.62	±1.5%	mS/m
11-Mar-25	2358028	TSQ001	Esiqanduleni Raw	E.coli*	199	±21%	MPN/100mL
11-Mar-25	2358027	TSQ001	Esiqanduleni Raw	pH OS*	7.40	-	-
11-Mar-25	2358027	TSQ001	Esiqanduleni Raw	Temperature OS*	20.2	-	°C
11-Mar-25	2358029	TSQ001	Esiqanduleni Raw	Turbidity	42.7	±6.1%	NTU
12-Mar-25	2358598	TBU001	Bulwer Raw	AI (AE)	459	±7.6%	µg AI/L
12-Mar-25	2358595	TBU001	Bulwer Raw	Coliforms*	2420	±22%	MPN/100mL
12-Mar-25	2358594	TBU001	Bulwer Raw	Coll Time OS*	10:25	-	-
12-Mar-25	2358596	TBU001	Bulwer Raw	Colour	7.40	±6.5%	mg Pt-Co/L
12-Mar-25	2358597	TBU001	Bulwer Raw	Conductivity	4.62	±1.5%	mS/m
12-Mar-25	2358595	TBU001	Bulwer Raw	E.coli*	75	±21%	MPN/100mL
12-Mar-25	2358596	TBU001	Bulwer Raw	Odour*	Nil	-	-
12-Mar-25	2358594	TBU001	Bulwer Raw	pH OS*	7.20	-	-
12-Mar-25	2358594	TBU001	Bulwer Raw	Temperature OS*	25.1	-	°C
12-Mar-25	2358596	TBU001	Bulwer Raw	Turbidity	12.9	±6.1%	NTU
12-Mar-25	2358613	TCR001	Creighton Raw	AI (AE)	3305772	±7.6%	µg AI/L
12-Mar-25	2358610	TCR001	Creighton Raw	Coliforms*	0	±22%	MPN/100mL
12-Mar-25	2358609	TCR001	Creighton Raw	Coll Time OS*	08:25	-	-
12-Mar-25	2358611	TCR001	Creighton Raw	Colour	45.3	±6.5%	mg Pt-Co/L
12-Mar-25	2358612	TCR001	Creighton Raw	Conductivity	477	±1.5%	mS/m
12-Mar-25	2358610	TCR001	Creighton Raw	E.coli*	0	±21%	MPN/100mL
12-Mar-25	2358609	TCR001	Creighton Raw	pH OS*	7.60	-	-
12-Mar-25	2358609	TCR001	Creighton Raw	Temperature OS*	19.0	-	°C
12-Mar-25	2358611	TCR001	Creighton Raw	Turbidity	18.4	±6.1%	NTU
12-Mar-25	2358631	THL001	Hlanganani Raw	Coliforms*	>2420	±22%	MPN/100mL
12-Mar-25	2358630	THL001	Hlanganani Raw	Coll Time OS*	11:10	-	-
12-Mar-25	2358633	THL001	Hlanganani Raw	Conductivity	6.89	±1.5%	mS/m
12-Mar-25	2358631	THL001	Hlanganani Raw	E.coli*	196	±21%	MPN/100mL
12-Mar-25	2358630	THL001	Hlanganani Raw	pH OS*	7.50	-	-
12-Mar-25	2358630	THL001	Hlanganani Raw	Temperature OS*	23.9	-	°C
12-Mar-25	2358632	THL001	Hlanganani Raw	Turbidity	16.1	±6.1%	NTU
12-Mar-25	2358665	TMQA001	Mqatsheni Raw	Coliforms*	291	±22%	MPN/100mL
12-Mar-25	2358664	TMQA001	Mqatsheni Raw	Coll Time OS*	09:52	-	-
12-Mar-25	2358666	TMQA001	Mqatsheni Raw	Colour	2.30	±6.5%	mg Pt-Co/L
12-Mar-25	2358667	TMQA001	Mqatsheni Raw	Conductivity	24.8	±1.5%	mS/m

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

12-Mar-25	2358665	TMQA001	Mqatsheni Raw	E.coli*	4	±21%	MPN/100mL
12-Mar-25	2358666	TMQA001	Mqatsheni Raw	Odour*	Nil	-	-
12-Mar-25	2358664	TMQA001	Mqatsheni Raw	pH OS*	9.00	-	-
12-Mar-25	2358664	TMQA001	Mqatsheni Raw	Temperature OS*	21.3	-	°C
12-Mar-25	2358666	TMQA001	Mqatsheni Raw	Turbidity	1.3	±6.1%	NTU
12-Mar-25	2358682	TRV001	Riversside Raw	Al (AE)	1310	±7.6%	µg Al/L
12-Mar-25	2358679	TRV001	Riversside Raw	Coliforms*	921	±22%	MPN/100mL
12-Mar-25	2358678	TRV001	Riversside Raw	Coll Time OS*	08:58	-	-
12-Mar-25	2358680	TRV001	Riversside Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
12-Mar-25	2358681	TRV001	Riversside Raw	Conductivity	5.81	±1.5%	mS/m
12-Mar-25	2358679	TRV001	Riversside Raw	E.coli*	17	±21%	MPN/100mL
12-Mar-25	2358678	TRV001	Riversside Raw	pH OS*	7.10	-	-
12-Mar-25	2358678	TRV001	Riversside Raw	Temperature OS*	22.5	-	°C
12-Mar-25	2358680	TRV001	Riversside Raw	Turbidity	6.2	±6.1%	NTU
12-Mar-25	2358697	TST001	St Appollinaris Raw	Al (AE)	382	±7.6%	µg Al/L
12-Mar-25	2358694	TST001	St Appollinaris Raw	Coliforms*	>2420	±22%	MPN/100mL
12-Mar-25	2358693	TST001	St Appollinaris Raw	Coll Time OS*	09:56	-	-
12-Mar-25	2358696	TST001	St Appollinaris Raw	Conductivity	4.26	±1.5%	mS/m
12-Mar-25	2358694	TST001	St Appollinaris Raw	E.coli*	179	±21%	MPN/100mL
12-Mar-25	2358693	TST001	St Appollinaris Raw	pH OS*	7.30	-	-
12-Mar-25	2358693	TST001	St Appollinaris Raw	Temperature OS*	23.7	-	°C
12-Mar-25	2358695	TST001	St Appollinaris Raw	Turbidity	17.1	±6.1%	NTU
12-Mar-25	2358708	TUN001	Underberg Raw	Al (AE)	609	±7.6%	µg Al/L
12-Mar-25	2358705	TUN001	Underberg Raw	Coliforms*	1300	±22%	MPN/100mL
12-Mar-25	2358705	TUN001	Underberg Raw	Coliphages*	0	±8%	PFU/10ml
12-Mar-25	2358704	TUN001	Underberg Raw	Coll Time OS*	08:16	-	-
12-Mar-25	2358707	TUN001	Underberg Raw	Conductivity	3.38	±1.5%	mS/m
12-Mar-25	2358705	TUN001	Underberg Raw	E.coli*	62	±21%	MPN/100mL
12-Mar-25	2358704	TUN001	Underberg Raw	pH OS*	7.40	-	-
12-Mar-25	2358704	TUN001	Underberg Raw	Temperature OS*	17.2	-	°C
12-Mar-25	2358706	TUN001	Underberg Raw	Turbidity	5.5	±6.1%	NTU
13-Mar-25	2359461	TMZ001	Umzimkhulu Raw	Al (AE)	736	±7.6%	µg Al/L
13-Mar-25	2359458	TMZ001	Umzimkhulu Raw	Coliforms*	>2420	±22%	MPN/100mL
13-Mar-25	2359458	TMZ001	Umzimkhulu Raw	Coliphages*	38	±8%	PFU/10ml
13-Mar-25	2359457	TMZ001	Umzimkhulu Raw	Coll Time OS*	08:02	-	-
13-Mar-25	2359459	TMZ001	Umzimkhulu Raw	Colour	9.20	±6.5%	mg Pt-Co/L
13-Mar-25	2359460	TMZ001	Umzimkhulu Raw	Conductivity	5.19	±1.5%	mS/m
13-Mar-25	2359458	TMZ001	Umzimkhulu Raw	E.coli*	179	±21%	MPN/100mL
13-Mar-25	2359461	TMZ001	Umzimkhulu Raw	Fe (AE)	0.64	±5.4%	mg Fe/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

13-Mar-25	2359459	TMZ001	Umzimkhulu Raw	Odour*	Nil	-	-
13-Mar-25	2359457	TMZ001	Umzimkhulu Raw	pH OS*	7.00	-	-
13-Mar-25	2359457	TMZ001	Umzimkhulu Raw	Temperature OS*	21.3	-	°C
13-Mar-25	2359459	TMZ001	Umzimkhulu Raw	Turbidity	39.4	±6.1%	NTU
13-Mar-25	2359488	TNO001	Nokweja Raw	Al (AE)	1024	±7.6%	µg Al/L
13-Mar-25	2359485	TNO001	Nokweja Raw	Coliforms*	>2420	±22%	MPN/100mL
13-Mar-25	2359485	TNO001	Nokweja Raw	Coliphages*	39	±8%	PFU/10ml
13-Mar-25	2359484	TNO001	Nokweja Raw	Coll Time OS*	08:02	-	-
13-Mar-25	2359486	TNO001	Nokweja Raw	Colour	13.2	±6.5%	mg Pt-Co/L
13-Mar-25	2359487	TNO001	Nokweja Raw	Conductivity	5.88	±1.5%	mS/m
13-Mar-25	2359485	TNO001	Nokweja Raw	E.coli*	921	±21%	MPN/100mL
13-Mar-25	2359488	TNO001	Nokweja Raw	Fe (AE)	1.05	±5.4%	mg Fe/L
13-Mar-25	2359486	TNO001	Nokweja Raw	Odour*	Nil	-	-
13-Mar-25	2359484	TNO001	Nokweja Raw	pH OS*	7.60	-	-
13-Mar-25	2359484	TNO001	Nokweja Raw	Temperature OS*	21.4	-	°C
13-Mar-25	2359486	TNO001	Nokweja Raw	Turbidity	39.4	±6.1%	NTU
13-Mar-25	2359507	TWA001	Washbank Raw	Al (AE)	123077	±7.6%	µg Al/L
13-Mar-25	2359504	TWA001	Washbank Raw	Coliforms*	517	±22%	MPN/100mL
13-Mar-25	2359503	TWA001	Washbank Raw	Coll Time OS*	07:25	-	-
13-Mar-25	2359506	TWA001	Washbank Raw	Conductivity	52.8	±1.5%	mS/m
13-Mar-25	2359504	TWA001	Washbank Raw	E.coli*	14	±21%	MPN/100mL
13-Mar-25	2359503	TWA001	Washbank Raw	pH OS*	7.00	-	-
13-Mar-25	2359503	TWA001	Washbank Raw	Temperature OS*	21.4	-	°C
13-Mar-25	2359505	TWA001	Washbank Raw	Turbidity	15.9	±6.1%	NTU
14-Mar-25	2359804	TIB001	Ibisi Raw	Al (AE)	3992	±7.6%	µg Al/L
14-Mar-25	2359801	TIB001	Ibisi Raw	Coliforms*	>2420	±22%	MPN/100mL
14-Mar-25	2359801	TIB001	Ibisi Raw	Coliphages*	0	±8%	PFU/10ml
14-Mar-25	2359800	TIB001	Ibisi Raw	Coll Time OS*	06:51	-	-
14-Mar-25	2359802	TIB001	Ibisi Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
14-Mar-25	2359803	TIB001	Ibisi Raw	Conductivity	8.69	±1.5%	mS/m
14-Mar-25	2359801	TIB001	Ibisi Raw	E.coli*	13	±21%	MPN/100mL
14-Mar-25	2359804	TIB001	Ibisi Raw	Fe (AE)	0.63	±5.4%	mg Fe/L
14-Mar-25	2359802	TIB001	Ibisi Raw	Odour*	Nil	-	-
14-Mar-25	2359800	TIB001	Ibisi Raw	pH OS*	7.40	-	-
14-Mar-25	2359800	TIB001	Ibisi Raw	Temperature OS*	22.1	-	°C
14-Mar-25	2359802	TIB001	Ibisi Raw	Turbidity	15.0	±6.1%	NTU
17-Mar-25	2360866	TFR001	Franklin Raw	Al (AE)	524	±7.6%	µg Al/L
17-Mar-25	2360863	TFR001	Franklin Raw	Coliforms*	1011	±22%	MPN/100mL
17-Mar-25	2360863	TFR001	Franklin Raw	Coliphages*	359	±8%	PFU/10ml

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

17-Mar-25	2360862	TFR001	Franklin Raw	Coll Time OS*	07:37	-	-
17-Mar-25	2360864	TFR001	Franklin Raw	Colour	63.9	±6.5%	mg Pt-Co/L
17-Mar-25	2360865	TFR001	Franklin Raw	Conductivity	9.14	±1.5%	mS/m
17-Mar-25	2360863	TFR001	Franklin Raw	E.coli*	291	±21%	MPN/100mL
17-Mar-25	2360866	TFR001	Franklin Raw	Fe (AE)	1.64	±5.4%	mg Fe/L
17-Mar-25	2360866	TFR001	Franklin Raw	Mn (AE)	0.04	±6.2%	mg Mn/L
17-Mar-25	2360864	TFR001	Franklin Raw	Odour*	Nil	-	-
17-Mar-25	2360862	TFR001	Franklin Raw	pH OS*	7.00	-	-
17-Mar-25	2360862	TFR001	Franklin Raw	Temperature OS*	18.1	-	°C
17-Mar-25	2360864	TFR001	Franklin Raw	Turbidity	29.4	±6.1%	NTU
17-Mar-25	2360886	TKK001	Kokstad River Raw	Al (AE)	447	±7.6%	µg Al/L
17-Mar-25	2360883	TKK001	Kokstad River Raw	Coliforms*	>2420	±22%	MPN/100mL
17-Mar-25	2360883	TKK001	Kokstad River Raw	Coliphages*	181	±8%	PFU/10ml
17-Mar-25	2360882	TKK001	Kokstad River Raw	Coll Time OS*	08:49	-	-
17-Mar-25	2360885	TKK001	Kokstad River Raw	Conductivity	9.19	±1.5%	mS/m
17-Mar-25	2360883	TKK001	Kokstad River Raw	E.coli*	214	±21%	MPN/100mL
17-Mar-25	2360882	TKK001	Kokstad River Raw	pH OS*	7.30	-	-
17-Mar-25	2360882	TKK001	Kokstad River Raw	Temperature OS*	18.5	-	°C
17-Mar-25	2360884	TKK001	Kokstad River Raw	Turbidity	43.1	±6.1%	NTU
17-Mar-25	2360897	TKK003	Kokstad Crystal Spring Raw	Al (AE)	865	±7.6%	µg Al/L
17-Mar-25	2360894	TKK003	Kokstad Crystal Spring Raw	Coliforms*	>2420	±22%	MPN/100mL
17-Mar-25	2360894	TKK003	Kokstad Crystal Spring Raw	Coliphages*	225	±8%	PFU/10ml
17-Mar-25	2360893	TKK003	Kokstad Crystal Spring Raw	Coll Time OS*	08:54	-	-
17-Mar-25	2360896	TKK003	Kokstad Crystal Spring Raw	Conductivity	8.88	±1.5%	mS/m
17-Mar-25	2360894	TKK003	Kokstad Crystal Spring Raw	E.coli*	69	±21%	MPN/100mL
17-Mar-25	2360893	TKK003	Kokstad Crystal Spring Raw	pH OS*	7.10	-	-
17-Mar-25	2360893	TKK003	Kokstad Crystal Spring Raw	Temperature OS*	20.0	-	°C
17-Mar-25	2360895	TKK003	Kokstad Crystal Spring Raw	Turbidity	36.1	±6.1%	NTU
18-Mar-25	2361634	TQU001	Mnqumeni Raw	Coliforms*	>2420	±22%	MPN/100mL
18-Mar-25	2361633	TQU001	Mnqumeni Raw	Coll Time OS*	7:31	-	-
18-Mar-25	2361636	TQU001	Mnqumeni Raw	Conductivity	8.21	±1.5%	mS/m
18-Mar-25	2361634	TQU001	Mnqumeni Raw	E.coli*	248	±21%	MPN/100mL
18-Mar-25	2361633	TQU001	Mnqumeni Raw	pH OS*	8.10	-	-
18-Mar-25	2361633	TQU001	Mnqumeni Raw	Temperature OS*	21.7	-	°C
18-Mar-25	2361635	TQU001	Mnqumeni Raw	Turbidity	66.4	±6.1%	NTU
18-Mar-25	2361646	TSQ001	Esiqanduleni Raw	Al (AE)	724	±7.6%	µg Al/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

18-Mar-25	2361643	TSQ001	Esiqanduleni Raw	Coliforms*	>2420	±22%	MPN/100mL
18-Mar-25	2361643	TSQ001	Esiqanduleni Raw	Coliphages*	30	±8%	PFU/10ml
18-Mar-25	2361642	TSQ001	Esiqanduleni Raw	Coll Time OS*	7:00	-	-
18-Mar-25	2361644	TSQ001	Esiqanduleni Raw	Colour	11.6	±6.5%	mg Pt-Co/L
18-Mar-25	2361645	TSQ001	Esiqanduleni Raw	Conductivity	7.51	±1.5%	mS/m
18-Mar-25	2361643	TSQ001	Esiqanduleni Raw	E.coli*	548	±21%	MPN/100mL
18-Mar-25	2361646	TSQ001	Esiqanduleni Raw	Fe (AE)	1.20	±5.4%	mg Fe/L
18-Mar-25	2361646	TSQ001	Esiqanduleni Raw	Mn (AE)	0.08	±6.2%	mg Mn/L
18-Mar-25	2361644	TSQ001	Esiqanduleni Raw	Odour*	Nil	-	-
18-Mar-25	2361642	TSQ001	Esiqanduleni Raw	pH OS*	7.40	-	-
18-Mar-25	2361642	TSQ001	Esiqanduleni Raw	Temperature OS*	19.4	-	°C
18-Mar-25	2361644	TSQ001	Esiqanduleni Raw	Turbidity	77.2	±6.1%	NTU
19-Mar-25	2362105	TBU001	Bulwer Raw	Al (AE)	566	±7.6%	µg Al/L
19-Mar-25	2362102	TBU001	Bulwer Raw	Coliforms*	>2420	±22%	MPN/100mL
19-Mar-25	2362101	TBU001	Bulwer Raw	Coll Time OS*	10:40	-	-
19-Mar-25	2362103	TBU001	Bulwer Raw	Colour	14.5	±6.5%	mg Pt-Co/L
19-Mar-25	2362104	TBU001	Bulwer Raw	Conductivity	4.41	±1.5%	mS/m
19-Mar-25	2362102	TBU001	Bulwer Raw	E.coli*	387	±21%	MPN/100mL
19-Mar-25	2362101	TBU001	Bulwer Raw	pH OS*	7.30	-	-
19-Mar-25	2362101	TBU001	Bulwer Raw	Temperature OS*	24.5	-	°C
19-Mar-25	2362103	TBU001	Bulwer Raw	Turbidity	30.4	±6.1%	NTU
19-Mar-25	2362123	THL001	Hlanganani Raw	Coliforms*	>2420	±22%	MPN/100mL
19-Mar-25	2362122	THL001	Hlanganani Raw	Coll Time OS*	11:10	-	-
19-Mar-25	2362125	THL001	Hlanganani Raw	Conductivity	6.43	±1.5%	mS/m
19-Mar-25	2362123	THL001	Hlanganani Raw	E.coli*	517	±21%	MPN/100mL
19-Mar-25	2362122	THL001	Hlanganani Raw	pH OS*	7.50	-	-
19-Mar-25	2362122	THL001	Hlanganani Raw	Temperature OS*	26.7	-	°C
19-Mar-25	2362124	THL001	Hlanganani Raw	Turbidity	53.2	±6.1%	NTU
19-Mar-25	2362146	TMQA001	Mqatsheni Raw	Coliforms*	>2420	±22%	MPN/100mL
19-Mar-25	2362145	TMQA001	Mqatsheni Raw	Coll Time OS*	09:16	-	-
19-Mar-25	2362147	TMQA001	Mqatsheni Raw	Colour	7.80	±6.5%	mg Pt-Co/L
19-Mar-25	2362148	TMQA001	Mqatsheni Raw	Conductivity	23.7	±1.5%	mS/m
19-Mar-25	2362146	TMQA001	Mqatsheni Raw	E.coli*	61	±21%	MPN/100mL
19-Mar-25	2362145	TMQA001	Mqatsheni Raw	pH OS*	8.90	-	-
19-Mar-25	2362145	TMQA001	Mqatsheni Raw	Temperature OS*	21.0	-	°C
19-Mar-25	2362147	TMQA001	Mqatsheni Raw	Turbidity	6.1	±6.1%	NTU
19-Mar-25	2362158	TRV001	Riversside Raw	Al (AE)	1923	±7.6%	µg Al/L
19-Mar-25	2362155	TRV001	Riversside Raw	Coliforms*	727	±22%	MPN/100mL
19-Mar-25	2362154	TRV001	Riversside Raw	Coll Time OS*	08:25	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

19-Mar-25	2362156	TRV001	Riversside Raw	Colour	4.00	±6.5%	mg Pt-Co/L
19-Mar-25	2362157	TRV001	Riversside Raw	Conductivity	4.71	±1.5%	mS/m
19-Mar-25	2362155	TRV001	Riversside Raw	E.coli*	61	±21%	MPN/100mL
19-Mar-25	2362154	TRV001	Riversside Raw	pH OS*	7.20	-	-
19-Mar-25	2362154	TRV001	Riversside Raw	Temperature OS*	19.3	-	°C
19-Mar-25	2362156	TRV001	Riversside Raw	Turbidity	7.1	±6.1%	NTU
19-Mar-25	2362169	TST001	St Appollinaris Raw	Al (AE)	617	±7.6%	µg Al/L
19-Mar-25	2362166	TST001	St Appollinaris Raw	Coliforms*	>2420	±22%	MPN/100mL
19-Mar-25	2362165	TST001	St Appollinaris Raw	Coll Time OS*	09:25	-	-
19-Mar-25	2362168	TST001	St Appollinaris Raw	Conductivity	4.29	±1.5%	mS/m
19-Mar-25	2362166	TST001	St Appollinaris Raw	E.coli*	613	±21%	MPN/100mL
19-Mar-25	2362165	TST001	St Appollinaris Raw	pH OS*	7.50	-	-
19-Mar-25	2362165	TST001	St Appollinaris Raw	Temperature OS*	20.6	-	°C
19-Mar-25	2362167	TST001	St Appollinaris Raw	Turbidity	31.9	±6.1%	NTU
19-Mar-25	2362180	TUN001	Underberg Raw	Al (AE)	295	±7.6%	µg Al/L
19-Mar-25	2362177	TUN001	Underberg Raw	Coliforms*	>2420	±22%	MPN/100mL
19-Mar-25	2362177	TUN001	Underberg Raw	Coliphages*	43	±8%	PFU/10ml
19-Mar-25	2362176	TUN001	Underberg Raw	Coll Time OS*	08:32	-	-
19-Mar-25	2362179	TUN001	Underberg Raw	Conductivity	3.34	±1.5%	mS/m
19-Mar-25	2362177	TUN001	Underberg Raw	E.coli*	161	±21%	MPN/100mL
19-Mar-25	2362176	TUN001	Underberg Raw	pH OS*	7.70	-	-
19-Mar-25	2362176	TUN001	Underberg Raw	Temperature OS*	16.7	-	°C
19-Mar-25	2362178	TUN001	Underberg Raw	Turbidity	9.3	±6.1%	NTU
20-Mar-25	2363057	TIB001	Ibisi Raw	Al (AE)	407	±7.6%	µg Al/L
20-Mar-25	2363054	TIB001	Ibisi Raw	Coliforms*	>2420	±22%	MPN/100mL
20-Mar-25	2363054	TIB001	Ibisi Raw	Coliphages*	17	±8%	PFU/10ml
20-Mar-25	2363053	TIB001	Ibisi Raw	Coll Time OS*	07:12	-	-
20-Mar-25	2363056	TIB001	Ibisi Raw	Conductivity	6.51	±1.5%	mS/m
20-Mar-25	2363054	TIB001	Ibisi Raw	E.coli*	179	±21%	MPN/100mL
20-Mar-25	2363053	TIB001	Ibisi Raw	pH OS*	7.50	-	-
20-Mar-25	2363053	TIB001	Ibisi Raw	Temperature OS*	20.5	-	°C
20-Mar-25	2363055	TIB001	Ibisi Raw	Turbidity	88.4	±6.1%	NTU
20-Mar-25	2362895	TMZ001	Umzimkhulu Raw	Al (AE)	687	±7.6%	µg Al/L
20-Mar-25	2362892	TMZ001	Umzimkhulu Raw	Coliforms*	>2420	±22%	MPN/100mL
20-Mar-25	2362892	TMZ001	Umzimkhulu Raw	Coliphages*	53	±8%	PFU/10ml
20-Mar-25	2362891	TMZ001	Umzimkhulu Raw	Coll Time OS*	08:37	-	-
20-Mar-25	2362894	TMZ001	Umzimkhulu Raw	Conductivity	4.91	±1.5%	mS/m
20-Mar-25	2362892	TMZ001	Umzimkhulu Raw	E.coli*	387	±21%	MPN/100mL
20-Mar-25	2362891	TMZ001	Umzimkhulu Raw	pH OS*	7.10	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

20-Mar-25	2362891	TMZ001	Umzimkhulu Raw	Temperature OS*	21.4	-	°C
20-Mar-25	2362893	TMZ001	Umzimkhulu Raw	Turbidity	77.9	±6.1%	NTU
20-Mar-25	2362906	TNO001	Nokweja Raw	Al (AE)	586	±7.6%	µg Al/L
20-Mar-25	2362903	TNO001	Nokweja Raw	Coliforms*	>2420	±22%	MPN/100mL
20-Mar-25	2362903	TNO001	Nokweja Raw	Coliphages*	56	±8%	PFU/10ml
20-Mar-25	2362902	TNO001	Nokweja Raw	Coll Time OS*	09:40	-	-
20-Mar-25	2362905	TNO001	Nokweja Raw	Conductivity	5.18	±1.5%	mS/m
20-Mar-25	2362903	TNO001	Nokweja Raw	E.coli*	816	±21%	MPN/100mL
20-Mar-25	2362902	TNO001	Nokweja Raw	pH OS*	7.00	-	-
20-Mar-25	2362902	TNO001	Nokweja Raw	Temperature OS*	24.0	-	°C
20-Mar-25	2362904	TNO001	Nokweja Raw	Turbidity	77.2	±6.1%	NTU
20-Mar-25	2362917	TWA001	Washbank Raw	Al (AE)	5160	±7.6%	µg Al/L
20-Mar-25	2362914	TWA001	Washbank Raw	Coliforms*	>2420	±22%	MPN/100mL
20-Mar-25	2362913	TWA001	Washbank Raw	Coll Time OS*	08:01	-	-
20-Mar-25	2362916	TWA001	Washbank Raw	Conductivity	7.31	±1.5%	mS/m
20-Mar-25	2362914	TWA001	Washbank Raw	E.coli*	461	±21%	MPN/100mL
20-Mar-25	2362913	TWA001	Washbank Raw	pH OS*	7.30	-	-
20-Mar-25	2362913	TWA001	Washbank Raw	Temperature OS*	19.2	-	°C
20-Mar-25	2362915	TWA001	Washbank Raw	Turbidity	15.0	±6.1%	NTU
24-Mar-25	2364404	TFR001	Franklin Raw	Al (AE)	792	±7.6%	µg Al/L
24-Mar-25	2364401	TFR001	Franklin Raw	Coliforms*	>2420	±22%	MPN/100mL
24-Mar-25	2364401	TFR001	Franklin Raw	Coliphages*	7	±8%	PFU/10ml
24-Mar-25	2364400	TFR001	Franklin Raw	Coll Time OS*	08:06	-	-
24-Mar-25	2364403	TFR001	Franklin Raw	Conductivity	10.7	±1.5%	mS/m
24-Mar-25	2364401	TFR001	Franklin Raw	E.coli*	365	±21%	MPN/100mL
24-Mar-25	2364400	TFR001	Franklin Raw	pH OS*	7.00	-	-
24-Mar-25	2364400	TFR001	Franklin Raw	Temperature OS*	20.9	-	°C
24-Mar-25	2364402	TFR001	Franklin Raw	Turbidity	20.1	±6.1%	NTU
24-Mar-25	2364428	TKK001	Kokstad River Raw	Al (AE)	381	±7.6%	µg Al/L
24-Mar-25	2364425	TKK001	Kokstad River Raw	Coliforms*	>2420	±22%	MPN/100mL
24-Mar-25	2364425	TKK001	Kokstad River Raw	Coliphages*	5	±8%	PFU/10ml
24-Mar-25	2364424	TKK001	Kokstad River Raw	Coll Time OS*	08:41	-	-
24-Mar-25	2364427	TKK001	Kokstad River Raw	Conductivity	9.87	±1.5%	mS/m
24-Mar-25	2364425	TKK001	Kokstad River Raw	E.coli*	108	±21%	MPN/100mL
24-Mar-25	2364424	TKK001	Kokstad River Raw	pH OS*	7.30	-	-
24-Mar-25	2364424	TKK001	Kokstad River Raw	Temperature OS*	19.1	-	°C
24-Mar-25	2364426	TKK001	Kokstad River Raw	Turbidity	23.6	±6.1%	NTU
24-Mar-25	2364439	TKK003	Kokstad Crystal Spring Raw	Al (AE)	3912	±7.6%	µg Al/L

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

24-Mar-25	2364436	TKK003	Kokstad Crystal Spring Raw	Coliforms*	>2420	±22%	MPN/100mL
24-Mar-25	2364436	TKK003	Kokstad Crystal Spring Raw	Coliphages*	259	±8%	PFU/10ml
24-Mar-25	2364435	TKK003	Kokstad Crystal Spring Raw	Coll Time OS*	08:30	-	-
24-Mar-25	2364438	TKK003	Kokstad Crystal Spring Raw	Conductivity	6.51	±1.5%	mS/m
24-Mar-25	2364436	TKK003	Kokstad Crystal Spring Raw	E.coli*	2420	±21%	MPN/100mL
24-Mar-25	2364435	TKK003	Kokstad Crystal Spring Raw	pH OS*	7.40	-	-
24-Mar-25	2364435	TKK003	Kokstad Crystal Spring Raw	Temperature OS*	19.3	-	°C
24-Mar-25	2364437	TKK003	Kokstad Crystal Spring Raw	Turbidity	222.0	±6.1%	NTU
25-Mar-25	2365168	TQU001	Mnqumeni Raw	Coliforms*	>2420	±22%	MPN/100mL
25-Mar-25	2365167	TQU001	Mnqumeni Raw	Coll Time OS*	06:47	-	-
25-Mar-25	2365170	TQU001	Mnqumeni Raw	Conductivity	49.7	±1.5%	mS/m
25-Mar-25	2365168	TQU001	Mnqumeni Raw	E.coli*	59	±21%	MPN/100mL
25-Mar-25	2365167	TQU001	Mnqumeni Raw	pH OS*	7.00	-	-
25-Mar-25	2365167	TQU001	Mnqumeni Raw	Temperature OS*	26.3	-	°C
25-Mar-25	2365169	TQU001	Mnqumeni Raw	Turbidity	144.0	±6.1%	NTU
25-Mar-25	2365180	TSQ001	Esiqanduleni Raw	Al (AE)	1705	±7.6%	µg Al/L
25-Mar-25	2365177	TSQ001	Esiqanduleni Raw	Coliforms*	>2420	±22%	MPN/100mL
25-Mar-25	2365177	TSQ001	Esiqanduleni Raw	Coliphages*	>500	±8%	PFU/10ml
25-Mar-25	2365176	TSQ001	Esiqanduleni Raw	Coll Time OS*	08:00	-	-
25-Mar-25	2365179	TSQ001	Esiqanduleni Raw	Conductivity	6.08	±1.5%	mS/m
25-Mar-25	2365177	TSQ001	Esiqanduleni Raw	E.coli*	>2420	±21%	MPN/100mL
25-Mar-25	2365176	TSQ001	Esiqanduleni Raw	pH OS*	7.60	-	-
25-Mar-25	2365176	TSQ001	Esiqanduleni Raw	Temperature OS*	24.2	-	°C
25-Mar-25	2365178	TSQ001	Esiqanduleni Raw	Turbidity	428.0	±6.1%	NTU
26-Mar-25	2366765	TIB001	Ibisi Raw	Al (AE)	536	±7.6%	µg Al/L
26-Mar-25	2366762	TIB001	Ibisi Raw	Coliforms*	>2420	±22%	MPN/100mL
26-Mar-25	2366762	TIB001	Ibisi Raw	Coliphages*	41	±8%	PFU/10ml
26-Mar-25	2366761	TIB001	Ibisi Raw	Coll Time OS*	08.41	-	-
26-Mar-25	2366764	TIB001	Ibisi Raw	Conductivity	7.00	±1.5%	mS/m
26-Mar-25	2366762	TIB001	Ibisi Raw	E.coli*	411	±21%	MPN/100mL
26-Mar-25	2366761	TIB001	Ibisi Raw	pH OS*	7.50	-	-
26-Mar-25	2366761	TIB001	Ibisi Raw	Temperature OS*	16.7	-	°C
26-Mar-25	2366763	TIB001	Ibisi Raw	Turbidity	47.3	±6.1%	NTU
26-Mar-25	2366487	TMZ001	Umzimkhulu Raw	Al (AE)	1581	±7.6%	µg Al/L
26-Mar-25	2366484	TMZ001	Umzimkhulu Raw	Coliforms*	>2420	±22%	MPN/100mL
26-Mar-25	2366484	TMZ001	Umzimkhulu Raw	Coliphages*	179	±8%	PFU/10ml
26-Mar-25	2366483	TMZ001	Umzimkhulu Raw	Coll Time OS*	09.00	-	-

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

26-Mar-25	2366486	TMZ001	Umzimkhulu Raw	Conductivity	4.99	±1.5%	mS/m
26-Mar-25	2366484	TMZ001	Umzimkhulu Raw	E.coli*	770	±21%	MPN/100mL
26-Mar-25	2366483	TMZ001	Umzimkhulu Raw	pH OS*	7.80	-	-
26-Mar-25	2366483	TMZ001	Umzimkhulu Raw	Temperature OS*	16.7	-	°C
26-Mar-25	2366485	TMZ001	Umzimkhulu Raw	Turbidity	121.0	±6.1%	NTU
26-Mar-25	2366539	TWA001	Washbank Raw	Al (AE)	5627	±7.6%	µg Al/L
26-Mar-25	2366536	TWA001	Washbank Raw	Coliforms*	1046	±22%	MPN/100mL
26-Mar-25	2366535	TWA001	Washbank Raw	Coll Time OS*	09.02	-	-
26-Mar-25	2366537	TWA001	Washbank Raw	Colour	13.1	±6.5%	mg Pt-Co/L
26-Mar-25	2366538	TWA001	Washbank Raw	Conductivity	7.97	±1.5%	mS/m
26-Mar-25	2366536	TWA001	Washbank Raw	E.coli*	248	±21%	MPN/100mL
26-Mar-25	2366535	TWA001	Washbank Raw	pH OS*	7.40	-	-
26-Mar-25	2366535	TWA001	Washbank Raw	Temperature OS*	16.9	-	°C
26-Mar-25	2366537	TWA001	Washbank Raw	Turbidity	12.0	±6.1%	NTU
27-Mar-25	2365691	TBU001	Bulwer Raw	Al (AE)	540	±7.6%	µg Al/L
27-Mar-25	2365688	TBU001	Bulwer Raw	Coliforms*	>2420	±22%	MPN/100mL
27-Mar-25	2365687	TBU001	Bulwer Raw	Coll Time OS*	11:20	-	-
27-Mar-25	2365689	TBU001	Bulwer Raw	Colour	10.0	±6.5%	mg Pt-Co/L
27-Mar-25	2365690	TBU001	Bulwer Raw	Conductivity	4.31	±1.5%	mS/m
27-Mar-25	2365688	TBU001	Bulwer Raw	E.coli*	162	±21%	MPN/100mL
27-Mar-25	2365689	TBU001	Bulwer Raw	Odour*	Nil	-	-
27-Mar-25	2365687	TBU001	Bulwer Raw	pH OS*	7.70	-	-
27-Mar-25	2365687	TBU001	Bulwer Raw	Temperature OS*	17.3	-	°C
27-Mar-25	2365689	TBU001	Bulwer Raw	Turbidity	25.1	±6.1%	NTU
27-Mar-25	2365705	TCR001	Creighton Raw	Al (AE)	526	±7.6%	µg Al/L
27-Mar-25	2365702	TCR001	Creighton Raw	Coliforms*	>2420	±22%	MPN/100mL
27-Mar-25	2365701	TCR001	Creighton Raw	Coll Time OS*	08:00	-	-
27-Mar-25	2365703	TCR001	Creighton Raw	Colour	5.10	±6.5%	mg Pt-Co/L
27-Mar-25	2365704	TCR001	Creighton Raw	Conductivity	6.09	±1.5%	mS/m
27-Mar-25	2365702	TCR001	Creighton Raw	E.coli*	228	±21%	MPN/100mL
27-Mar-25	2365701	TCR001	Creighton Raw	pH OS*	7.60	-	-
27-Mar-25	2365701	TCR001	Creighton Raw	Temperature OS*	16.1	-	°C
27-Mar-25	2365703	TCR001	Creighton Raw	Turbidity	56.2	±6.1%	NTU
27-Mar-25	2365722	THL001	Hlanganani Raw	Coliforms*	>2420	±22%	MPN/100mL
27-Mar-25	2365721	THL001	Hlanganani Raw	Coll Time OS*	12:50	-	-
27-Mar-25	2365724	THL001	Hlanganani Raw	Conductivity	6.26	±1.5%	mS/m
27-Mar-25	2365722	THL001	Hlanganani Raw	E.coli*	816	±21%	MPN/100mL
27-Mar-25	2365721	THL001	Hlanganani Raw	pH OS*	7.80	-	-
27-Mar-25	2365721	THL001	Hlanganani Raw	Temperature OS*	17.3	-	°C

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

27-Mar-25	2365723	THL001	Hlanganani Raw	Turbidity	53.7	±6.1%	NTU
27-Mar-25	2365753	TMQA001	Mqatsheni Raw	Coliforms*	17	±22%	MPN/100mL
27-Mar-25	2365752	TMQA001	Mqatsheni Raw	Coll Time OS*	10:37	-	-
27-Mar-25	2365754	TMQA001	Mqatsheni Raw	Colour	2.70	±6.5%	mg Pt-Co/L
27-Mar-25	2365755	TMQA001	Mqatsheni Raw	Conductivity	28.9	±1.5%	mS/m
27-Mar-25	2365753	TMQA001	Mqatsheni Raw	E.coli*	0	±21%	MPN/100mL
27-Mar-25	2365754	TMQA001	Mqatsheni Raw	Odour*	Nil	-	-
27-Mar-25	2365752	TMQA001	Mqatsheni Raw	pH OS*	7.80	-	-
27-Mar-25	2365752	TMQA001	Mqatsheni Raw	Temperature OS*	16.3	-	°C
27-Mar-25	2365754	TMQA001	Mqatsheni Raw	Turbidity	1.9	±6.1%	NTU
27-Mar-25	2365769	TRV001	Riversside Raw	Al (AE)	6868	±7.6%	µg Al/L
27-Mar-25	2365766	TRV001	Riversside Raw	Coliforms*	>2420	±22%	MPN/100mL
27-Mar-25	2365765	TRV001	Riversside Raw	Coll Time OS*	09:08	-	-
27-Mar-25	2365767	TRV001	Riversside Raw	Colour	<1.00	±6.5%	mg Pt-Co/L
27-Mar-25	2365768	TRV001	Riversside Raw	Conductivity	5.57	±1.5%	mS/m
27-Mar-25	2365766	TRV001	Riversside Raw	E.coli*	51	±21%	MPN/100mL
27-Mar-25	2365765	TRV001	Riversside Raw	pH OS*	7.80	-	-
27-Mar-25	2365765	TRV001	Riversside Raw	Temperature OS*	16.8	-	°C
27-Mar-25	2365767	TRV001	Riversside Raw	Turbidity	58.2	±6.1%	NTU
27-Mar-25	2365795	TUN001	Underberg Raw	Al (AE)	314	±7.6%	µg Al/L
27-Mar-25	2365792	TUN001	Underberg Raw	Coliforms*	>2420	±22%	MPN/100mL
27-Mar-25	2365792	TUN001	Underberg Raw	Coliphages*	142	±8%	PFU/10ml
27-Mar-25	2365791	TUN001	Underberg Raw	Coll Time OS*	11:11	-	-
27-Mar-25	2365794	TUN001	Underberg Raw	Conductivity	4.76	±1.5%	mS/m
27-Mar-25	2365792	TUN001	Underberg Raw	E.coli*	461	±21%	MPN/100mL
27-Mar-25	2365791	TUN001	Underberg Raw	pH OS*	7.70	-	-
27-Mar-25	2365791	TUN001	Underberg Raw	Temperature OS*	16.8	-	°C
27-Mar-25	2365793	TUN001	Underberg Raw	Turbidity	9.9	±6.1%	NTU
31-Mar-25	2367670	TKK001	Kokstad River Raw	Al (AE)	2050	±7.6%	µg Al/L
31-Mar-25	2367667	TKK001	Kokstad River Raw	Coliforms*	613	±22%	MPN/100mL
31-Mar-25	2367667	TKK001	Kokstad River Raw	Coliphages*	18	±8%	PFU/10ml
31-Mar-25	2367666	TKK001	Kokstad River Raw	Coll Time OS*	08:20	-	-
31-Mar-25	2367669	TKK001	Kokstad River Raw	Conductivity	9.71	±1.5%	mS/m
31-Mar-25	2367667	TKK001	Kokstad River Raw	E.coli*	6	±21%	MPN/100mL
31-Mar-25	2367666	TKK001	Kokstad River Raw	pH OS*	7.40	-	-
31-Mar-25	2367666	TKK001	Kokstad River Raw	Temperature OS*	20.2	-	°C
31-Mar-25	2367668	TKK001	Kokstad River Raw	Turbidity	23.9	±6.1%	NTU
31-Mar-25	2367681	TKK003	Kokstad Crystal Spring Raw	Al (AE)	955	±7.6%	µg Al/L
31-Mar-25	2367678	TKK003	Kokstad Crystal Spring Raw	Coliforms*	>2420	±22%	MPN/100mL

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuck | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (Chief Executive) | Mr. TS Mkhwanazi (Chief Financial Officer)

31-Mar-25	2367678	TKK003	Kokstad Crystal Spring Raw	Coliphages*	13	±8%	PFU/10ml
31-Mar-25	2367677	TKK003	Kokstad Crystal Spring Raw	Coll Time OS*	07:40	-	-
31-Mar-25	2367680	TKK003	Kokstad Crystal Spring Raw	Conductivity	11.2	±1.5%	mS/m
31-Mar-25	2367678	TKK003	Kokstad Crystal Spring Raw	E.coli*	93	±21%	MPN/100mL
31-Mar-25	2367677	TKK003	Kokstad Crystal Spring Raw	pH OS*	7.40	-	-
31-Mar-25	2367677	TKK003	Kokstad Crystal Spring Raw	Temperature OS*	20.1	-	°C
31-Mar-25	2367679	TKK003	Kokstad Crystal Spring Raw	Turbidity	27.9	±6.1%	NTU

uMngeni-uThukela Water

HEAD OFFICE

P. O. Box 9 • Pietermaritzburg 3200, 310 Burger Street • Pietermaritzburg 3201 • KwaZulu-Natal • South Africa,
Telephone (033) 341 1111
E-mail: Info@umngeni.co.za • Website: <https://www.umngeni-uthukela.co.za/>

Board Members: Adv. SB Khuzwayo SC (Chairperson) | Ms. NN Mkhize (Deputy Chairperson) | Mr. TJ Cornish | Adv. LN Gopaul | Ms. DG Hoorzuk | Ms. S Masango | Ms. TS Mhlongo | Mr. SW Mkhize | Adv. KI Mshengu | Mr. SM Mtolo | Ms. H Mvubu | Mr. KS Shandu | Mr. SP Mkhize (**Chief Executive**) | Mr. TS Mkhwanazi (**Chief Financial Officer**)